


ENG-CDR18006-GEC-V1-Redlines.pdf Markup Summary

dsdrice (7)




Subject: Cloud+
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/25/2018 1:51:34 PM
Color: ■

006




Subject: Callout
Page Label: 4
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/25/2018 10:37:34 AM
Color: ■

Is this to be a stabilized access surface? Label if so.



Subject: Callout
Page Label: 4
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/24/2018 1:26:09 PM
Color: ■

ECB, PS?




Subject: Cloud+
Page Label: 5
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/24/2018 1:23:20 PM
Color: ■

Show forebay grading. Are wingwalls needed?




Subject: Callout
Page Label: 5
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/24/2018 1:14:56 PM
Color: ■

Label 100-year floodplain



Subject: Text Box
Page Label: 5
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/25/2018 10:35:11 AM
Color: ■

Label EF JCC



Subject: Cloud+
Page Label: 5
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdrice
Date: 4/24/2018 1:15:19 PM
Color: ■

Shouldn't limits of construction include this?