










# Landscape Plans\_V3\_Redlines.pdf Markup Summary

1/4/2021 10:49:35 AM (1)




**Subject:** Callout  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:49:35 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

2. [Repeat Comment]: Internal Landscaping site data table shows that four (4) trees are provided, however only three (3) trees shown on plan. Please show those four (4) trees noted as provided in the table and justify in Letter of Intent why four are proposed in lieu of six trees as required.

3. [Repeat Comment]: Internal landscaping should be calculated using the entire parcel per Code Section 6.2.2(E)(3)(c). Please revise note on how internal landscaping is calculated.


1/4/2021 10:52:16 AM (1)



**Subject:** Callout  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:52:16 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

5. Please revise to show symbol for Junper shrub.


1/4/2021 10:52:53 AM (1)



**Subject:** Callout  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:52:53 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

1. [Repeat Comment]: Number of Evergreen Plants is inconsistent with Motor Vehicle landscaping site data table. Please correct number provided for consistency with plan and below Evergreen Shrub in plant schedule table (6).

1/4/2021 10:53:19 AM (1)



**Subject:** Callout  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:53:19 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

4. There are 3 MS trees shown on this plan; please revise plant schedule table for consistency with plan.


1/4/2021 10:58:29 AM (1)



**Subject:** Engineer  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:58:29 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

PCD File No. PPR2031





**Subject:** Callout  
**Page Label:** 1  
**Author:** Sophie Kiepe  
**Date:** 1/4/2021 10:58:34 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

6.[Repeat Comment (made by Engineering in Review 1)]: Please add PCD File No. PPR2031