

CITY-COUNTY HEALTH DEPARTMENT

Colorado Springs Colorado El Paso County

PERMIT

Individual Sewage Disposal System (Construction, Alteration or Repair)

Issued To Alfred Snyder Date April 3, 1970

Address of Property Lot 3, Panaramic Acres, Mt. Herman Rd., Monument, Colorado

Builder - Contractor - Owner - Address Same Phone _____

Sewage-Disposal System work to be performed by Same Phone _____

This Permit is issued in accordance with Regulation XII and Article 2 of Chapter 66, Colorado Revised Statutes 1963, as amended by the addition of a new Section 66-2-16. (H.B. 1205, 7-1-65). PERMIT EXPIRES upon completion —installation of sewage-disposal system or at the end of six (6) months from date of issue—whichever occurs first— (unless work is in progress).

October 3, 1970 (Date of Expiration) Director, City-County Health Dept.

Permit Fee \$ 5.00

Mileage (8c/mile to and from site) 40 3.20

Total Fee \$ 8.20

Septic tank 750 gals. Field 125 feet of trench 24 inches wide.

Seepage bed _____ ft. long _____ ft. wide. Seepage pit _____ gallons.

The Health Officer shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative.

2 it in well.

3120

Sub

Alfred Snyder

J.C.O.

NOTE: Leave entire sewage-disposal system uncovered for final inspection.
24-hour advance notice required.