



November 15, 2021

Ryan Howser
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (The Association)

To El Paso County:

The Association has these comments about the following:

Project Name: Mayberry Phase 1 – Ellicott Town Center Amendment
Project Number: PUDSP219

Description: Proposed development of 240 single family lots on approximately 71 acres located off State Highway 94 and Log Rd. in Township 14, Range 63, Sections 14,15.

This area is within the Association's certificated service area. The Association will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Association's Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

The Association requests a ten (10) foot front lot utility easement, a five (5) foot side lot utility easement, and a seven and a half (7.5) foot rear lot utility easement on the plat and all tracts include easements. The Association also requests the platting of the Association's existing facilities with easements on the plat. Additional easements may be required.

The Association has existing facilities near and within this parcel of land. If there is any damage, removal or relocation of facilities it will be at the expense of the applicant.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry
Engineering Coordinator II

This Association is an equal opportunity provider and employer.

