



June 7, 2022

Ryan Howser
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (The Association)

To El Paso County:

The Association has these comments about the following:

Project Name: Mayberry Filing 3 – Final Plat

Project Number: SF2219

Description: Proposed development of 142 single family lots located off State Highway 94 and south Log Rd. in Township 14S, Range 63W, Section 14.

This area is within the Association's certificated service area. The Association will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Association's Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

The Association requests a ten (10) foot front lot utility easement in additional to any public improvement easement, a five (5) foot side lot utility easement, and a seven (7) foot rear lot utility easement along with a twenty (20) foot exterior utility easement on the plat and all tracts include easements. The Association also requests the platting of the Association's existing facilities with easements on the plat. Additional easements may be required.

The Association has existing facilities near and within this parcel of land. If there is any damage, removal or relocation of facilities it will be at the expense of the applicant.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry

Gina Perry
Engineering Coordinator

This Association is an equal opportunity provider and employer.

