



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Widefield Water District PFC.PFOA Treatment System Review, AASI-19-001

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The project has been approved by all the required review agencies and boards reviewed with the submittal. The necessary permits required have been favorably reviewed and obtained, or are in process.
- The construction of the drinking water mitigation system must meet the design criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division.
- Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to:
<https://www.colorado.gov/pacific/cdphe/general-air-permits>
- The water quality basins, if any, must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
01June2019