



Please also provide a summary table of the flows at the design points.

NOTE: ALL DRIVEWAY CULVERTS ALONG BROWN ROAD ARE TO BE 18" RCP AT A MIN SLOPE OF 2%

The narrative indicates a 42" RCP culvert to replace the existing culvert. Revise accordingly.

NOT FOR CONSTRUCTION:  
 THESE PLANS ARE INTENDED FOR SUBMITTAL, REVIEW AND APPROVAL BY CITY/COUNTY PLANNING DEPARTMENT AS AN AID FOR CONSTRUCTION OR LAYOUT.

No.	Description	By	Date

H Scale: 1"=200'  
 V Scale: 1"=20'  
 Designed By: SLG  
 Drawn By: KH  
 Checked By: KH  
 Date: 06/03/19

**Land Development Consultants, Inc.**  
 Planning • Landscapes Architecture  
 Engineering • Surveying  
 www.ldc-inc.com • TEL: (719) 528-6133 • FAX: (719) 528-6848  
 2850 Serranipity Circle West • Colorado Springs, CO 80917

**DEVELOPED DRAINAGE PRAIRIE RIDGE EL PASO COUNTY, COLORADO**

Project Number: 07051  
 Sheet: 2 of 2

F:\07051\07051-Prairie Ridge\Engineering\07051-Drainage.dwg 3 May 2019