



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Cherry Creek Systems Site Development Plan Amendment, PPR-18-048

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- No water or wastewater is proposed for extension into the 300' x 300' asphalt lot area (2.06 acres).
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The new water quality detention basin must be designed to drain completely between storm events to eliminate areas of standing water in an effort to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575-8602
mikemccarthy@elpasoco.com
25Nov2018