



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Reigning Hope, PPR-19-035 (Updated)

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- No public health issues noted with the future indoor arena structure.
- El Paso County Public Health on-site wastewater treatment system (OWTS) records indicate there is one permitted, approved and installed OWTS on the property. The OWTS for the 3-bedroom house was installed in 1974 with an addition to the soil treatment area installed in 2002.
- A New Onsite Wastewater Treatment System (OWTS) Permit (ON0050253) has been applied for and issued for the restroom in the barn that will be used for the business operation. The OWTS must be installed prior to operation.
- All components of the two OWTS's and an additional secondary soil treatment area for each OWTS are required to be protected from compaction by vehicular traffic and livestock. Fencing and/or landscaping are examples of soil treatment area protection methods.
- Horse waste must be managed in an effort to reduce the potential for rodents, insects, and nuisance odors.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719-575-8602
03Feb2020