



May 10, 2021

Mercedes Rivas
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (The Association)

To El Paso County:

The Association has these comments about the following:

Project Name: Sunrise Meadow Subdivision Filing 2 - Lot Line Adjustment
Project Number: VR217
Description: A replat of lots 2, 3 and 4 located off Poco Rd. and Vollmer Rd. in Township 12, Range 65, Section 28.

This area is within the Association's certificated service area. The Association will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Association's Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

The Association requests a ten (10) foot front, side, and rear lot utility easement on the plat easement along with a twenty (20) foot exterior utility easement. The Association also requests the platting of the Association's existing facilities with easement on the plat. Additional easements may be required.

The Association has existing facilities near and within this parcel of land. If there is any damage, removal, or relocation of facilities it will be at the expense of the applicant.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry
Engineering Coordinator II

This Association is an equal opportunity provider and employer.

