

FORM NO.
GWS-76
05/2011

WATER SUPPLY INFORMATION SUMMARY
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER
1313 Sherman St., Room 821, Denver, CO 80203
Main (303) 866-3581 dwr.colorado.gov

Section 30-28-133,(d), C.R.S. requires that the applicant submit to the County, "Adequate evidence that a water supply that is sufficient in terms of quantity, quality, and dependability will be available to ensure an adequate supply of water."

1. NAME OF DEVELOPMENT AS PROPOSED: **Mayberry, Filing 4**

2. LAND USE ACTION: **Final Plat**

3. NAME OF EXISTING PARCEL AS RECORDED: **Tract A Mayberry Colorado Springs Filing No. 3**
SUBDIVISION: **Mayberry**, FILING (UNIT) **4**, BLOCK **n/a**, LOT **n/a**

4. TOTAL ACREAGE: **9.78 acres** | 5. NUMBER OF LOTS PROPOSED **8 Lots** | PLAT MAP ENCLOSED? YES or NO

6. PARCEL HISTORY – Please attach copies of deeds, plats, or other evidence or documentation.
A. Was parcel recorded with county prior to June 1, 1972? YES or NO
B. Has the parcel ever been part of a division of land action since June 1, 1972? YES or NO
If yes, describe the previous action:

7. LOCATION OF PARCEL – Include a map delineating the project area and tie to a section corner.
____ 1/4 of the **NE** 1/4, Section **14**, Township **14** N or S, Range **63** E or W
Principal Meridian (choose only one): Sixth New Mexico Ute Costilla
Optional GPS Location: GPS Unit must use the following settings: Format must be **UTM**, Units must be **meters**, Datum must be **NAD83**, Unit must be set to **true N**, Zone 12 or Zone 13
Easting: _____
Northing: _____

8. PLAT – Location of all wells on property must be plotted and permit numbers provided.
Surveyor's Plat: YES or NO | If not, scaled hand drawn sketch: YES or NO

9. ESTIMATED WATER REQUIREMENTS

USE	WATER REQUIREMENTS	
	Gallons per Day	Acre-Foot per Year
HOUSEHOLD USE # _____ of units	_____	_____
COMMERCIAL USE # _____ of S. F.	_____	_____
IRRIGATION # 0.28 of acres	606	0.68
STOCK WATERING # _____ of head	_____	_____
OTHER: 8 commercial lots	2097	2.35
TOTAL	2703	3.03

10. WATER SUPPLY SOURCE

EXISTING WELL DEVELOPED SPRING

WELL PERMIT NUMBERS
Existing well usage will be conducted through Cherokee Metropolitan District with it's existing wells.

NEW WELLS -
PROPOSED AQUIFERS – (CHECK ONE)
 ALLUVIAL UPPER ARAPAHOE
 UPPER DAWSON LOWER ARAPAHOE
 LOWER DAWSON LARAMIE FOX HILLS
Ellicott Utilities Company Wells DAKOTA
 OTHER: _____

MUNICIPAL
 ASSOCIATION
 COMPANY
 DISTRICT **Cherokee Metropolitan District & Ellicott Utilities Company**

NAME _____
LETTER OF COMMITMENT FOR SERVICE YES or NO

WATER COURT DECREE CASE NUMBERS:
Basin Determination 598-BD - Ellicott Utilities
Basin Determination 599-BD - Ellicott Utilities
91CW01 - Cherokee Metro District

You need to identify the square footage of developed space and apply a 0.1 GPD per square foot and apply an acre-foot conversion. I cannot tell if this is what you have done.

DEVELOPED? YES or NO IF YES, PLEASE FORWARD WITH THIS FORM.

SEPTIC TANK/LEACH FIELD
 LAGOON
 ENGINEERED SYSTEM (Attach a copy of engineering design.)

CENTRAL SYSTEM
DISTRICT NAME: **Ellicott Utilities Company WWTP**
 VAULT
LOCATION SEWAGE HAULED TO: _____
 OTHER: