



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

3745 Mulberry Variance of Use, VA-21-3

Please accept the following comments from El Paso County Public Health for the variance renewal request:

- **Water service for the site is by an individual private well.**
- **Wastewater service for the site is by an existing onsite wastewater treatment system (OWTS). The septic tank and soil treatment area (STA) must be located and protected during construction activity. Compaction of the STA can cause premature failure of the OWTS.**
- **No other public health issue noted with the renewal of the variance.**

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
06Aug2021