RETREAT AT TIMBERRIDGE FILING NO. 1

COUNTY OF EL PASO. STATE OF COLORADO

GENERAL CONSTRUCTION NOTES:

- THE LOCATION OF EXISTING UTILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY AND MAY NOT INCLUDE ALL UTILITIES. THE EXCAVATION CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENDING WORK. THE CONTRACTOR AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE OCCASIONED BY HIS FAILURE TO EXACTLY LOCATED AND PRESENCE ANY AND ALL UTILITIES.
- BEFORE COMMENCING ANY EXCAVATION, CALL 1-800-922-1987 FOR EXISTING UTILITY LOCATIONS.
- THE CONTRACTOR WILL TAKE THE NECESSARY PRECAUTIONS TO PROTECT EXISTING UTILITIES FROM DAMAGE DUE TO THIS OPERATION. ANY DAMAGE TO THE UTILITIES WILL BE REPAIRED AT THE CONTRACTOR'S EXPENSE, AND ANY SERMICE DISRUPTION WILL BE SETTLED BY THE CONTRACTOR.
- ALL BACKFILL, SUB-BASE AND/OR BASE COURSE (CLASS 6) MATERIAL SHALL BE COMPACTED TO THE SOLS ENGINEER'S RECOMMENDATIONS, AND APPROVED BY EL PASO COUNTY PLANNING AND COMMUNITY DEVELOPMENT (PCD).
- ALL STATIONING IS CENTERLINE UNLESS OTHERWISE INDICATED. ALL ELEVATIONS ARE CENTERLINE UNLESS OTHERWISE INDICATED.
- . THE CONTRACTOR SHALL REVECETATE ALL DISTURBED AREAS AS SOON AS POSSBLE AND EROSION CONTROL SHALL BE INSTALLED AND MAINTAINED IN A FUNCTIONAL MANNER AT ALL TIMES. DEVELOPER RESPONSIBLE FOR MAINTAINING DISTURBED AREAS UNTIL REVECETATION IS COMPLETE.
- ALL DISTURBED PAYEMENT EDGES SHALL BE CUT TO NEAT LINES. REPAIR SHALL CONFORM TO THE EPC ECM APPENDIX K = 1.20.
- 8. ADDITIONAL EROSION CONTROL STRUCTURES MAY BE REQUIRED AT THE TIME OF CONSTRUCTION.
- . BUILDING CONTRACTORS WILL BE RESPONSIBLE FOR CONSTRUCTING POSITIVE DRAINAGE AWAY FROM ALL STRUCTURES
- D. ASPHALT THICKNESS AND BASE COURSE THICKNESS (COMPACTED) FOR ROADS SHALL BE PER DESIGN REPORT BY OWNER'S GEOTECHNICAL ENGINEER. OWNER'S GEOTECHNICAL ENGINEER TO BE ON SITE AT TIME OF ROAD CONSTRUCTION TO EVALUATE SOL CONDITIONS AND DETERMINE IF ADDITIONAL MEASURES ARE NECESSARY TO ASSURE STABILITY OF THE NEW ROADS. PAVEMENT DESIGN SHALL BE APPROVED BY PLANNING AND COMMUNITY DEVELOPMENT PRIOR TO CONSTRUCTION.
- . THE CONTRACTOR SHALL REVEGETATE ALL DISTURBED AREAS WITHIN 21 DAYS OF SUBSTANTIAL GRADING COMPLETION. EROSION CONTROL SHALL BE INSTALLED AND MANTANED IN A FUNCTIONAL MANNER AT ALL TIMES. DEVELOPER IS RESPONSBLE FOR MAINTAINING DISTURBED AREAS UNITE, REVECTATION IS COMPLETE.
- 2. TYPE M RIP-RAP WITH 4" OF TYPE II GRANULAR BEDDING AND WIRAFI 180N OR EQUAL MAY BE SUBSTITUTED WHERE TYPE L RIP-RAP WITH WIRAFI FW 700 OR EQUAL IS SPECIFIED.
- 3. ALL MATERIALS AND INSTALLATION PROCEDURES SHALL BE IN COMPLIANCE WITH ANY AND ALL APPLICABLE EL PASO COUNTY STANDARDS.

STANDARD NOTES FOR EL PASO COUNTY CONSTRUCTION PLANS:

- ALL DRAINAGE AND ROADWAY CONSTRUCTION SHALL MEET THE STANDARDS AND SPECIFICATIONS OF THE CITY OF COLORADO SPRINGS/EL PASO COUNTY DRAINAGE CRITERIA MANUAL. VOLUMES 1 AND 2, AND THE EL PASO COUNTY ENGINEERING CRITERIA MANUAL.
- CONTRACTOR SHALL BE RESPONSIBLE FOR THE NOTIFICATION AND FIELD NOTIFICATION OF ALL EXISTING UTILITIES, WHETHER SHOWN ON THE PLANS OR NOT, BEFORE BEGINNING CONSTRUCTION. LOCATION OF EXISTING UTILITIES SHALL BE WEIGHED BY THE CONTRACTOR PRIOR TO CONSTRUCTION. CALL BIT TO CONTRACT HE UNITY NOTIFICATION CENTER OF COLORADO (UNICC).
- CONTRACTOR SHALL KEEP A COPY OF THESE APPROVED PLANS, THE GRADING AND EROSON CONTROL PLAN, THE STORMWATER MANAGEMENT PLAN (SMMP). THE SOLIS AND GEOTECHNICAL REPORT, AND THE APPROPRIATE DESIGN AND CONSTRUCTION STANDARDS AND SPECIFICATIONS of THE PASS COUNTY DERINGERING OFFIERM MANUAL (ECU).

 OF THE PASS COUNTY DERINGERING COUNTY DERINACE CRITERIA MANUAL, VOLUMES 1 AND 2.

 C. COLORADO DEPARTMENT OF TRANSPORTATION (COOT) STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION COUNTY DERINACE CRITERIA MANUAL, VOLUMES 1.


- NOTWITHSTANDING ANYTHING DEPICTED IN THESE PLANS IN WORDS OR GRAPHIC REPRESENTATION, ALL DESIGN AND CONSTRUCTION RELATED TO RODMS, STORM DEMANDED AND EROSION CONTROL SHALL CONFIGN TO THE STANDARDS MID REQUIREMENTS OF THE MOST RECENT OF THE MOST RECENT OF THE PROPERTY OF THE MOST RECENT OF THE PROPERTY OF THE MOST RECENT OF THE PROPERTY OF THE PROPE
- IT IS THE DESIGN ENGINEER'S RESPONSIBILITY TO ACCURATELY SHOW EXISTING CONDITIONS, BOTH CHISTE AND OFFSITE, ON THE CONSTRUCTION PLANS: ANY MODIFICATIONS NECESSARY DUE TO CONFLICTS, CMISSIONS, OR CHANGED CONDITIONS WILL BE ENTIRELY THE DEVELOPMENT OF REPORTURBILITY OR REFORM
- CONTRACTOR SHALL SCHEDULE A PRE-CONSTRUCTION MEETING WITH EL PASO COUNTY PLANNING AND COMMUNITY DEVELOPMENT INSPECTIONS, PRICE TO STARTING CONSTRUCTION.
- IT IS THE CONTRACTOR'S RESPONSIBILITY TO UNDERSTAND THE REQUIREMENTS OF ALL JURISDICTIONAL ACENCIES AND TO OBTAIN ALL REQUIRED PERMITS, INCLUDING BUT NOT LIMITED TO EL PASO COUNTY EROSION AND STORMWATER QUALITY CONTROL PERMIT (ESQCF), REGIONAL BUILDING FLOODPLAIN DEVLOPMENT PERMIT, U.S. ARMY CORPS OF ENGINEERS-ISSUED 401 AND/OR 404 PERMITS, AND COUNTY AND STATE FLOOTIVE DUST PERMITS.
- CONTRACTOR SHALL NOT DEVIATE FROM THE PLANS WITHOUT FIRST OBTAINING WRITTEN APPROVAL FROM THE DESIGN ENGINEER AND PCD. CONTRACTOR SHALL NOTIFY THE DESIGN ENGINEER IMMEDIATELY UPON DISCOVERY OF ANY ERRORS OF INCONSISTENCES.
- 9. ALL STORM DRAIN PIPE SHALL BE CLASS III RCP UNLESS OTHERWISE NOTED AND APPROVED BY PCD.
- CONTRACTOR SHALL COORDINATE GEOTECHNICAL TESTING PER ECM STANDARDS. PAVEMENT DESIGN SHALL BE APPROVED BY EL PASO
 COUNTY PCD PRIOR TO PLACEMENT OF CURB AND GUTTER AND PAVEMENT.
- 1. ALL CONSTRUCTION TRAFFIC MUST ENTER/EXIT THE SITE AT APPROVED CONSTRUCTION ACCESS POINTS.
- 12. SIGHT VISIBILITY TRIANGLES AS IDENTIFIED IN THE PLANS SHALL BE PROVIDED AT ALL INTERSECTIONS. OBSTRUCTIONS GREATER THAN 18 INCHES ABOVE FLOWLINE ARE NOT ALLOWED WITHIN SIGHT TRIANGLES.
- 13. SIGNING AND STRIPING SHALL COMPLY WITH EL PASO COUNTY DEPARTMENT OF PUBLIC WORKS AND MUTCO CRITERIA.
- 14. CONTRACTOR SHALL OBTAIN ANY PERMITS REQUIRED BY EL PASO COUNTY DEPARTMENT OF PUBLIC WORKS, INCLUDING WORK WITHIN THE RIGHT-OF-WAY AND SPECIAL TRANSPORT PERMITS.
- THE LIMITS OF CONSTRUCTION SHALL REMAIN WITHIN THE PROPERTY LINE UNLESS OTHERWISE NOTED. THE OWNER/DEVELOPER SHALL OBTAIN WRITEN PERMISSION AND EASTWINIS. WHERE REQUIRED, FROM ADJOINING PROPERTY OWNER(S) PRIOR TO ANY OFF-SITE DISTURBANCE, GRADING, OF CONSTRUCTION.

SIGNING AND STRIPING NOTES:

- ALL SIGNS AND PAVEMENT MARKINGS SHALL BE IN COMPLIANCE WITH THE CURRENT MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES (MUTCO).
- REMOVAL OF EXISTING PAVEMENT MARKINGS SHALL BE ACCOMPLISHED BY A METHOD THAT DOES NOT MATERIALLY DAVAGE THE PAVEMENT. THE PAVEMENT MARKINGS SHALL BE REMOVED TO THE EXTENT THAT THEY WILL NOT BE MISBLE UNDER DAY OR NIGHT CONDITIONS. AT NO TIME MILL IT BE ACCOPTABLE TO PAIN TOWER EXISTING PAVEMENT MARKING.
- ANY DEVIATION FROM THE STRIPING AND SIGNING PLAN SHALL BE APPROVED BY EL PASO COUNTY PLANNING AND COMMUNITY DEVELOPMENT.
- ALL SIGNS SHOWN ON THE SIGNING AND STRIPFING PLAN SHALL BE NEW SIGNS. EXISTING SIGNS MAY REMAIN OR BE REUSED IF THEY MEET CURRENT EL PASO COUNTY AND MUTCH STANDARDS.
- 5. STREET NAME AND REGULATORY STOP SIGNS SHALL BE ON THE SAME POST AT INTERSECTIONS.
- 6. ALL REMOVED SIGNS SHALL BE DISPOSED OF IN A PROPER MANNER BY THE CONTRACTOR
- ALL STREET NAME SIGNS SHALL MAVE "ID" SERES LETTERS, WITH LOCAL ROADWAY SICHS BEING 4" UPPER-LOWER CASE LETTERING ON 8" BLANK AND NON-LOCAL ROADWAY SIGHS BEING 6" LETTERING, UPPER-LOWER CASE ON 12" BLANK, WITH A WHITE BORDER THAT IS NOT RECESSED. MULTI-LANE ROADWAYS WITH SPEED LIMITS OF 40 MPH OR HIGHER SHALL MAYE 8" UPPER-LOWER CASE LETTERING ON 18" BLANK WITH A WHITE BORDER THAT IS NOT RECESSED. THE WIDTH OF THE NON-RECESSED WHITE BORDERS SHALL MATCH PAGE 255 OF THE 2012 MATCH STANDARD HIGHMAY SIGNS."
- 8. ALL TRAFFIC SIGNS SHALL HAVE A MINIMUM HIGH INTENSITY PRISMATIC GRADE SHEETING.
- ALL LOCAL RESIDENTIAL STREET SIGNS SHALL BE MOUNTED ON A 1.75" X 1.75" SQUARE TUBE SIGN POST AND STUB POST BASE. FOR OTHER APPLICATIONS, REFER TO THE COOT STANDARD S-614-8 REGARDING USE OF THE P2 TUBULAR STEEL POST SLIPBASE DESIGN.
- 10. ALL SIGNS SHALL BE SING E SHEET ALLIVINUM WITH 0.100" MINIMUM THICKNESS
- 11. ALL UNIT UNES/STOP LINES, CROSSWALK LINES, PAVEMENT LEGENDS, AND ARROWS SHALL BE A MINIMUM 125 MIL THICKNESS PREFORMED THICRIDOPLASTIC PAVEMENT MARKINGS WITH TAPPERD LEADING EDECES PER CODT STANDARD S-627-1. MORD AND SMIROL, MARKINGS SHALL BE THE NARROW TYPE. STOP DAKS SHALL BE 24 NI WORTH. CROSSWALKS LINES SHALL BE 12 "MOE AND 6" LOND PRE COOT S-627-1.
- 12. ALL LONGITUDINAL LINES SHALL BE A MINIMUM 15MIL THICKNESS EPOXY PAINT. ALL NON-LOCAL RESIDENTIAL ROADWAYS SHALL INCLUDE BOTH RIGHT AND LEFT EDGE LINE STRIPING AND ANY ADDITIONAL STRIPING AS REQUIRED BY COOT S-627-1.
- THE CONTRACTOR SHALL NOTIFY EL PASO COUNTY PLANNING AND COMMUNITY DEVELOPMENT (719) 520-6819 PRIOR TO AND UPON COMPLETION OF SIGNING AND STRIPING.
- 14. THE CONTRACTOR SHALL OBTAIN A WORK IN THE RIGHT OF WAY PERMIT FROM THE EL PASO COUNTY DEPARTMENT OF PUBLIC WORKS (DPW)
 PRIOR TO ANY SIGNACE OR STRIPING WORK WITHIN AN EXISTING EL PASO COUNTY ROADWAY.

CONSTRUCTION DRAWINGS

AUGUST 2019



BASIS OF BEARINGS:

DATION OF THE SOUTHEAST QUARTER OF THE NORTHEAST QUARTER OF SECTION 28.

THE SOUTH LINE OF THE SOUTHEAST QUARTER OF THE SIXTH PRINCIPAL MEMBRAN, BEING MORNUENTED AT TOWNSHIP 12 SOUTH, RANGE 65 WEST OF THE SIXTH PRINCIPAL MEMBRAN, BEING MORNUENTED AT THE WEST EDIN WHICH IS THE SOUTHWEST CORRER OF THE SOUTHEAST QUARTER OF SAID SECTION 28, BY A 3-1/4* ALUMINUM SURVEYORS CAP STAMPED "ES PLS 10376, 2006", 18 ASSURED TO BERA SEQUEZY A DESTRUCTION SURVEYORS CAP STAMPED "ES PLS 10376, 2006", 18 ASSURED TO BERA SEQUEZY A DESTRUCTION CONTROL OF LAS SEQUEZY A DESTRUCTION CONTROL OF LAS SEQUEZY A DESTRUCTION CONTROL OF LASSES AND THE SECTION OF L

BENCHMARKS:

AGENCIES:

OWNER/DEVELOPER

CIVIL ENGINEER

CLASSIC CONSULTING ENGINEERS & SURVEYORS 519 N. CASCADE AVENUE, SURTE 200 COLORADO SPRINGS, COLORADO 80903 MR. MARC A. WHORTON, P.E. (719) 785-2802

GAS COMPANY:

ELECTRIC COMPANY:

BLACKHILLS ENERGY 37 WIDERELD BOULEVARD WIDERELD, COLORADO 80911 VR. GEORGE M. PETERSON, (719) 392-3491

MOUNTAIN MEW ELECTRIC P.O. BOX 1600 LIMON, COLORADO 80828 MR. LES ULFERS, (719) 495-2283

FIRE DISTRICT:

BLACK FOREST FIRE PROTECTION DISTRICT 11445 TEACHOUT ROAD COLORADO SPRINGS. CO 80908 CHIEF BRYAN JACK, (719) 495-4300

SHEET INDEX SHEET 1 OF 35

TELEPHONE COMPANY

TITLE SHEET

STREET SECTIONS / EROSION CONTROL NOTES SHEET 2 OF 35 SHEET 3-9 OF 35 OVERLOT GRADING & EROSION CONTROL PLAN SHEET 10 OF 35 POCO ROAD PLAN AND PROFILE SHEET 11 OF 35

ANTELOPE RAVINE DR. & HAWK HILLS CT. PLAN AND PROFILE SHEET 15 OF 35 ELK ANTLER LANE & RABBIT TAIL PLACE PLAN AND PROFILE SHEET 15 OF 35 RISON VALLEY TRAIL PLAN AND PROFILE

SHEET 17 OF 35 EXISTING VOLLMER ROAD EAST SHOULDER WIDENING SHEET 18-19 OF 35 PEDESTRIAN RAMPS & USPS CLUSTER BOX DETAILS SHEET 20 OF 35 STREET LIGHT POLE LOCATION PLAN

SHEET 21-25 OF 35 STORM SEWER PLAN AND PROFILES POCO ROAD (2) MP STEEL ARCH CULVERTS CROSSING (ALSO REFERENCE CULVERT DESIGN PLANS BY CONTECH DATED 3/20/20 UNDER SEPARATE DOCUMENT)

SHEET 27-29 OF 35 CHANNEL CHECK STRUCTURES & BANK STABILIZATION PLAN

SHEET 31-32 OF 35 POND PLAN-1 AND DETAILS

SHEET 33-34 OF 35 POND PLAN-2 AND DETAILS SMEET 35 OF 35 DETAIL SHEET

APPROVALS:

DESIGN ENGINEER'S STATEMENT:

DESIGN ENGINEER'S STATEMENT:

HEES DETAILED PLAIS AND SPECIFICATIONS WERE PREPARED UNDER MY DIRECTION AND SUPERVISION. SAID PLANS AND SPECIFICATIONS HAVE BEEN PREPARED ACCORDING TO THE CRITICIAN ESTABLISHED BY THE COUNTY FOR DETAILED ROADWAY, DRAMAGE, CRADING AND ENGINE CHAINS AND SPECIFICATIONS. AND SAID PLANS AND SPECIFICATIONS ARE IN CONCORNITY WITH APPLICABLE MASTER DRAMAGE PLANS AND SPECIFICATIONS FOR THE APPLICABLE MASTER DRAMAGE PLANS AND MASTER TRANSPORTATION PLANS SAID PLANS AND SPECIFICATIONS FOR THE APPLICABLE MASTER DRAMAGE PLANS AND SPECIFICATION FOR THE PROPOSES FOR MACHET THE PRINCIPLE ROADWAY AND DRAMAGE FACILITIES AND ELECTRICAL PLANS AND SPECIFICATIONS.

CORRECT TO THE BESTERFORD WITHOUT AND BELLET, I ACCORD RESPONSIBILITY FOR ANY LIABILITY DIRECTLY CLASSED BY THE NECOCION ACCORDING SOURCES ON MY PART IN REPREVAINT OF THESE DETAILED PLANS AND SPECIFICATIONS.

MARC A WHORTON COLORADO PE 137155
FOR AND ON THE BEHALF OF COASSIC CONSULTING ENGINEERS & SURVEYORS

6/9/2020

OWNER/DEVELOPER'S STATEMENT:

OMPLY WITH THE REQUIREMENTS OF THE EROSION CONTROL PLAN AND AS

6/9/2020

COUNTY PLAN REVIEW IS PROVIDED ONLY FOR GENERAL CONFORMANCE WITH COUNTY DESIGN CRITERIA. THE COUNTY IS NOT RESPONSIBLE FOR THE ACCURACY AND ADCOLACY OF THE DESIGN, DIMENSIONS, AND/OR ELEVATIONS WHICH SHALL BE AT THE JOB SITE. THE COUNTY THROUGH THE APPROVAL OF THIS DOCUMENT ASSUMES NO RESPONSIBILITY FOR COMPLETIONSS.

FILED IN ACCORDANCE WITH THE REQUIREMENTS OF THE EL PASO COUNTY LAND DEVELOPMENT CODE, DRAINAGE CRITERIA MANUAL, VOLUMES 1 AND 2 AND ENGINEERING CRITERIA MANUAL AS AMENDED.

IN ACCORDANCE WITH WITH ECM SECTION 1.12, THESE CONSTRUCTION DOCUMENTS WILL BE VAUID FOR CONSTRUCTION FOR A PERIOD OF 2 YEARS FROM THE DATE SIGNED BY THE EL PASO COUNTY ENGINEER. IF CONSTRUCTION HAS NOT STARTED MITHIN THOSE 2 YEARS, THE PLANS MILL NEED TO BE RESUBBLITTED FOR APPROVAL, INCLUDING PAYMENT OF REVEN FEES AT THE PLANNING AND COMMUNITY DEVELOPMENT DIRECTOR'S DISCRETION.

JENNIFER IRVINE, P.E.
COUNTY ENGINEER / ECM ADMINISTRATOR

PCD No. SF-19-009

(V) 1"= N/A JOB NO.

48 HOURS BEFORE YOU DIG, CALL UTILITY LOCATORS 811

UTILITY NOTIFICATION CENTER OF COLORADO IT'S THE LAW

THE LOCATIONS OF EXISTING UNREGGOOND LITE TES ARE SHOWN IN AN APPROXIMATE WAY DRIVE, THE CONTRACTOR SHALL DELETING THE CONTRACTOR SHALL DELETING THE EXPENSE THE CONTRACTOR SHALL DELETING WORK, THE CONTRACTOR SHALL DESCRIPTION OF THE WORLD WHICH DAMAGES W

).	REVISION	DATE
	REVISED PER COUNTY COMMENTS	08-13-19
	REVISED PER COUNTY COMMENTS	6-5-20
_		
_		
_		
_		

REPARED UNDER MY DIRECT SUPERVISION FOR AND ON BEHALF CLASSIC CONSTITUTE ON THE PROPERTY OF THE

MARC A WHORTON, COCORADO P.E. #37155



RETREAT AT TIMBERRIDGE FILING NO. 1 CONSTRUCTION DRAWINGS TITLE SHEET


04-05-19 MAW (H) 1"= N/A SHEET 1 OF 35

RAWN BY -ECKED BY


STANDARD NOTES FOR EL PASO COUNTY GRADING AND EROSION CONTROL PLANS:

- STORMWATER DISCHARGES FROM CONSTRUCTION SITES SHALL NOT CAUSE OR THREATEN TO CAUSE POLLUTION, CONTAMINATION, OR DEGRADATION OF STATE WATERS. ALL WORK AND EARTH DISTURBANCE SHALL BE DONE IN A MANNER THAT MINIMIZES POLLUTION OF ANY ON-SITE OR OFF-SITE WATERS, INCLUDING WETLANDS.
- NOTWITHSTANDING ANYTHING DEPICTED IN THESE PLANS IN WORDS OR GRAPHIC REPRESENTATION, ALL DESIGN AND CONSTRUCTION RELATED TO ROADS, STORM DRAINAGE AND EROSION CONTROL SHALL CONFORM TO THE STANDARDS AND REQUIREMENTS OF THE MOST RECENT VERSION OF THE RELEVANT ADOPTED EL PASO COUNTY STANDARDS, INCLUDING THE LAND DEVELOPMENT CODE, THE ENGINEERING CRITERIA MANUAL, THE DRAINAGE CRITERIA MANUAL, AND THE DRAINAGE CRITERIA MANUAL VOLUME 2. ANY DEVIATIONS TO REGULATIONS AND STANDARDS MUST BE REQUESTED, AND APPROVED, IN WRITING.
- 3. A SEPARATE STORMWATER MANAGEMENT PLAN (SWMP) FOR THIS PROJECT SHALL BE COMPLETED AND AN EROSION AND STORMWATER QUALITY CONTROL PERMIT (ESQCP) ISSUED PRIOR TO COMMENCING CONSTRUCTION. DURING CONSTRUCTION THE SWMP IS THE RESPONSIBILITY OF THE DESIGNATED QUALIFIED STORMWATER MANAGER OR CERTIFIED EROSION CONTROL INSPECTOR AND SHALL BE LOCATED ON SITE AT ALL TIMES DURING CONSTRUCTION AND SHALL BE KEPT UP TO DATE WITH WORK PROGRESS AND CHANGES IN THE FIELD.
- 4. ONCE THE ESQCP IS APPROVED AND A (NOTICE TO PROCEED" HAS BEEN ISSUED, THE CONTRACTOR MAY INSTALL THE INITIAL STAGE EROSION AND SEDIMENT CONTROL MEASURES AS INDICATED ON THE APPROVED GEC. A PRECONSTRUCTION MEETING BETWEEN THE CONTRACTOR, ENGINEER, AND EL PASO COUNTY WILL BE HELD PRIOR TO ANY CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE APPLICANT TO COORDINATE THE MEETING TIME AND PLACE WITH COUNTY STAFF.
- CONTROL MEASURES MUST BE INSTALLED PRIOR TO COMMENCEMENT OF ACTIVITIES THAT MAY CONTRIBUTE POLLUTANTS TO STORMWATER. TEMPORARY SEDIMENT AND EROSION CONTROL MEASURES FOR ALL SLOPES, CHANNELS, DITCHES, OR ANY DISTURBED LAND AREA SHALL BE COMPLETED IMMEDIATELY UPON COMPLETION OF THE DISTURBANCE.
- 6. ALL TEMPORARY SEDIMENT AND EROSION CONTROL MEASURES SHALL BE MAINTAINED AND REMAIN IN EFFECTIVE OPERATING CONDITION UNTIL PERMANENT SOIL EROSION CONTROL MEASURES ARE IMPLEMENTED AND FINAL STABILIZATION IS ESTABLISHED ALL PERSONS ENGAGED IN LAND DISTURBANCE ACTIVITIES SHALL ASSESS THE ADEQUACY OF CONTROL MEASURES AT THE SITE AND IDENTIFY IF CHANGES TO THOSE CONTROL MEASURES IS NEEDED TO ENSURE THE CONTINUED EFFECTIVE PERFORMANCE OF THE CONTROL MEASURES. ALL CHANGES TO TEMPORARY SEDIMENT AND EROSION CONTROL MEASURES MUST BE INCORPORATED INTO THE STORMWATER MANAGEMENT PLAN.
- TEMPORARY STABILIZATION SHALL BE IMPLEMENTED ON DISTURBED AREAS AND STOCKPILES WHERE GROUND DISTURBING CONSTRUCTION ACTIVITY HAS PERMANENTLY CEASED OR TEMPORARILY CEASED FOR LONGER THAN 14 DAYS.
- 8. FINAL STABILIZATION MUST BE IMPLEMENTED AT ALL APPLICABLE CONSTRUCTION SITES. FINAL STABILIZATION IS ACHIEVED WHEN ALL GROUND DISTURBING ACTIVITIES ARE COMPLETE AND ALL DISTURBED AREAS EITHER HAVE A UNIFORM VEGETATIVE COVER WITH INDIVIDUAL PLAN DENSITY OF 70 PERCENT OF PRE-DISTURBANCE LEVELS ESTABLISHED OR EQUIVALENT PERMANENT ALTERNATIVE STABILIZATION METHOD IS IMPLEMENTED. ALL TEMPORARY SEDIMENT AND EROSION CONTROL MEASURES SHALL BE REMOVED UPON FINAL STABILIZATION AND BEFORE PERMIT CLOSURE.
- ALL PERMANENT STORMWATER MANAGEMENT FACILITIES SHALL BE INSTALLED AS DEFINED IN THE APPROVED PLANS. ANY PROPOSED CHANGES THAT EFFECT THE HYDROLOGY OR HYDRAULICS OS A PERMANENT STORMWATER MANAGEMENT STRUCTURES MUST BE APPROVED BY THE ECM ADMINISTRATOR PRIOR TO IMPLEMENTATION.
- 10. EARTH DISTURBANCES SHALL BE CONDUCTED IN SUCH A MANNER SO AS TO EFFECTIVELY MINIMIZE ACCELERATED SOIL EROSION AND RESULTING SEDIMENTATION. ALL DISTURBANCES SHALL BE DESIGNED, CONSTRUCTED, AND COMPLETED SO THAT THE EXPOSED AREA OF ANY DISTURBED LAND SHALL BE LIMITED TO THE SHORTEST PRACTICAL PERIOD OF TIME. PRE-EXISTING VEGETATION SHALL BE PROTECTED AND MAINTAINED WITHIN 50 HORIZONTAL FEET OF A WATERS OF THE STATE, UNLESS SHOWN TO BE INFEASIBLE AND SPECIFICALLY REQUESTED AND APPROVED.
- 11. COMPACTION OF SOIL MUST BE PREVENTED IN AREAS DESIGNATED FOR INFILTRATION CONTROL MEASURES OR WHERE FINAL STABILIZATION WILL BE ACHIEVED BY VEGETATIVE COVER. AREAS DESIGNATED FOR INFILTRATION CONTROL MEASURES SHALL ALSO BE PROTECTED FROM SEDIMENTATION DURING CONSTRUCTION UNTIL FINAL STABILIZATION IS ACHIEVED. IF COMPACTION PREVENTION IS NOT FEASIBLE DUE TO SITE CONSTRAINTS, ALL AREAS DESIGNATED FOR INFILTRATION AND VEGETATION CONTROL MEASURES MUST BE LOOSENED PRIOR TO INSTALLATION OF THE CONTROL MEASURE(S)
- 12. ANY TEMPORARY OR PERMANENT FACILITY DESIGNED AND CONSTRUCTED FOR THE CONVEYANCE OF STORMWATER AROUND, THROUGH, OR FROM THE EARTH DISTURBANCE AREA SHALL BE A STABILIZED CONVEYANCE DESIGNED TO MINIMIZE EROSION AND THE DISCHARGE OF SEDIMENT OFF SITE.
- 13. CONCRETE WASH WATER SHALL BE CONTAINED AND DISPOSED OF IN ACCORDANCE WITH THE SWMP. NO WASH WATER SHALL BE DISCHARGED TO OR ALLOWED TO RUNOFF TO STATE WATERS, INCLUDING ANY SURFACE OR SUBSURFACE STORM DRAINAGE SYSTEM OR FACILITIES. CONCRETE WASHOUTS SHALL NOT BE LOCATED IN AN AREA WHERE SHALLOW GROUNDWATER MAY BE PRESENT, OR WITHIN 50 FEET OF A SURFACE WATER BODY, CREEK OR STREAM.
- 14. DURING DEWATERING OPERATIONS: UNCONTAMINATED GROUND WATER MAY BE DISCHARGED ON SITE, BUT SHALL NOT LEAVE THE SITE IN THE FORM OF SURFACE RUNOFF UNLESS AN APPROVED STATE DEWATERING PERMIT IS IN PLACE ...
- 15. EROSION CONTROL BLANKETING OR OTHER PROTECTIVE COVERING SHALL BE USED ON SLOPES STEEPER THAN 3:1.
- 16. CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL WASTES FROM THE CONSTRUCTION SITE FOR DISPOSAL IN ACCORDANCE WITH LOCAL AND STATE REGULATORY REQUIREMENTS. NO CONSTRUCTION DEBRIS, TREE SLASH, BUILDING MATERIAL WASTES OR UNUSED BUILDING MATERIALS SHALL BE BURIED, DUMPED OR DISCHAGED AT THE SITE.
- 17. WASTE MATERIALS SHALL NOT BE TEMPORARILY PLACED IN THE STREET, ALLEY OR OTHER PUBLIC WAY, UNLESS IN ACCORDANCE WITH AN APPROVED TRAFFIC CONTROL PLAN. CONTROL MEASURES MAY BE REQUIRED BY EL PASO COUNTY ENGINEERING IF DEEMED NECESSARY, BASED ON SPECIFIC CONDITIONS AND CIRCUMSTANCES.
- 18. TRACKING OF SOILS AND CONSTRUCTION DEBRIS OFF-SITE SHALL BE MINIMIZED. MATERIALS TRACKED OFFSITE SHALL BE CLEANED UP AND PROPERLY DISPOSED OF IMMEDIATELY.
- 19. THE OWNER/DEVELOPER SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL CONSTRUCTION DEBRIS, DIRT, TRASH, ROCK, SEDIMENT, SOIL AND SAND THAT MAY ACCUMULATE IN ROADS, STORM DRAINS AND OTHER DRAINAGE CONVEYANCE SYSTEMS AND STORMWATER APPURTENANCES AS A RESULT OF SITE DEVELOPMENT.
- 20. THE QUANTITY OF MATERIALS STORED ON THE PROJECT SITE SHALL BE LIMITED, AS MUCH AS PRACTICAL, TO THAT QUANTITY REQUIRED TO PERFORM THE WORK IN AN ORDERLY SEQUENCE. ALL MATERIALS STORED ON-SITE SHALL BE STORED IN A NEAT, ORDERLY MANNER, IN THEIR ORIGINAL CONTAINERS, WITH ORIGINAL MANUFACTURER'S LABELS.
- 21. NO CHEMICAL(S) HAVING THE POTENTIAL TO BE RELEASED IN STORMWATER ARE TO BE STORED OR USED ONSITE UNLESS PERMISSION FOR THE USE OF A SPECIFIC CHEMICAL(S) IS GRANTED IN WRITING BY THE ECM ADMINISTRATOR. IN GRANTING APPROVAL FOR THE USE OF SUCH CHEMICAL(S), SPECIAL CONDITIONS AND MONITORING MAY BE REQUIRED.
- 22. BULK STORAGE OF ALLOWED PETROLEUM PRODUCTS OR OTHER LIQUID CHEMICALS IN AXCESS OF 55 GALLONS SHALL REQUIRE ADEQUATE SECONDARY CONTAINMENT PROTECTION TO CONTAIN ALL SPILLS ONSITE AND TO PREVENT ANY SPILLED MATERIALS FROM ENTERING STATE WATERS, ANY SURFACE OR SUBSURFACE STORM DRAINAGE SYSTEM OR FACILITIES.
- 23. NO PERSON SHALL CAUSE THE IMPEDIMENT OF STORMWATER FLOW IN THE CURB AND GUTTER OR DITCH EXCEPT WITH APPROVED SEDIMENT CONTROL MEASURES.
- 24. OWNER/DEVELOPER AND THEIR AGENTS SHALL COMPLY WITH THE "COLORADO WATER QUALITY CONTROL ACT" (TITLE 25, ARTICLE 8, CRS), AND THE "CLEAN WATER ACT" (33 USC 1344), IN ADDITION TO THE REQUIREMENTS OF THE LAND DEVELOPMENT CODE, DCM VOLUME II AND THE ECM APPENDIX I. ALL APPROPRIATE PERMITS MUST BE OBTAINED BY THE CONTRACTOR PRIOR TO CONSTRUCTION (1041, NPDES, FLOODPLAIN, 404, FUGITIVE DUST, ETC.). IN THE EVENT OF CONFLICTS BETWEEN THESE REQUIREMENTS AND LAWS, RULES, OR REGULATIONS OF OTHER FEDERAL, STATE, OR COUNTY AGENCIES, THE MORE RESTRICTIVE LAWS, RULES, OR REGULATIONS SHALL APPLY.
- 25. ALL CONSTRUCTION TRAFFIC MUST ENTER/EXIT THE SITE AT APPROVED CONSTRUCTION ACCESS POINTS.
- 26. PRIOR TO CONSTRUCTION THE PERMITEE SHALL VERIFY THE LOCATION OF EXISTING UTILITIES.
- 27. A WATER SOURCE SHALL BE AVAILABLE ON SITE DURING EARTHWORK OPERATIONS AND UTILIZED AS REQUIRED TO MINIMIZE DUST FROM EARTHWORK EQUIPMENT AND WIND.
- 28. THE SOILS REPORTS FOR THIS SITE HAVE BEEN PREPARED BY ENTECH ENGINEERING, INC. TITLED "SOIL, GEOLOGY, GEOLOGIC HAZARD AND WASTEWATER STUDY THE RETREAT AT TIMBER RIDGE VOLLMER ROAD AND ARROYA LANE", DATED APRIL 12, 2017, REVISED DECEMBER 1, 2017 AND "SUBSURFACE SOIL INVESTIGATION RETREAT AT TIMBERRIDGE, FILING NO. 1 POCO ROAD SAND CREEK CROSSING, DROP STRUCTURES AND DETENTION PONDS" DATED AUGUST 8, 2019. THESE REPORTS SHALL BE CONSIDERED
- 29. AT LEAST TEN (10) DAYS PRIOR TO THE ANTICIPATED START OF CONSTRUCTION, FOR PROJECTS THAT WILL DISTURB ONE (1) ACRE OR MORE, THE OWNER OR OPERATOR OF CONSTRUCTION ACTIVITY SHALL SUBMIT A PERMIT APPLICATION FOR STORMWATER DISCHARGE TO THE COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT, WATER QUALITY DIVISION. THE APPLICATION CONTAINS CERTIFICATION OF COMPLETION OF A STORMWATER MANAGEMENT PLAN (SWMP), OF WHICH THIS GRADING AND EROSION CONTROL PLAN MAY BE A PART. FOR INFORMATION OR APPLICATION MATERIALS CONTACT:


COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT WATER QUALITY CONTROL DIVISION WQCD - PFRMITS 4300 CHERRY CREEK DRIVE SOUTH DENVER, CO 80246-1530 ATTN: PERMITS UNIT




TYPICAL LOT SECTION DETAIL



LOT DRAINAGE TYPES



ELEV. +0.60 ELEV. 0.00 SUBGRADE |




TYPICAL WALKOUT LOT (W/O) OR GARDEN (G)

BASED ON GREATER TYPICAL DEPTH OF PROPOSED LOTS, ALL LOT TEMPLATES ADJUSTED AND ADDITIONAL 5'.


"T" LOTS OR "TRANSITION" LOTS OCCUR IN PLACES WHERE BOTH PROPERTY LINES CANNOT BE GRADED AS THE TYPICAL STANDARD LOT TEMPLATES SHOWN. THESE LOTS WILL STILL BE GRADED TO CREATE POSITIVE DRAINAGE AWAY FROM THE STRUCTURE.

SIDE LOT SWALES ARE REQUIRED ON THE DOWNHILL LOTS, EITHER BY BUILDER OR GRADING CONTRACTOR.



60' R.O.W. TYPICAL RURAL LOCAL CROSS SECTION SCALE: 1" = 10'

SIGN PLACEMENT PER 2009 MUTCD ASPEN VALLEY ROAD FIG. 2A-2 A AND LOCATED 8' BEHIND GRAVEL SHOULDER




SCALE: 1" = 10'

SECONDARY EMERGENCY ACCESS UP TO ARROYA LANE

SIGN PLACEMENT PER 2009 MUTCD FIG. 2A-2 A AND LOCATED 8' BEHIND GRAVEL SHOULDER


NO ADDITIONAL IMPROVEMENTS REQUIRED AT THIS TIME ON THE EXISTING ARROYA LANE AS IT CURRENTLY FUNCTIONS AS A VIABLE EMERGENCY ACCESS DRIVE PER BLACK FOREST FIRE DISTRICT.

FUTURE PLATTING ADJACENT TO ARROYA LANE WILL REQUIRE ADDITIONAL IMPROVEMENTS TO THIS ROADWAY.



50' R.O.W. TYPICAL URBAN LOCAL CROSS SECTION

ANTELOPE RAVINE DRIVE RABBIT TAIL PLACE ELK ANTLER LANE BISON VALLEY TRAIL



60' R.O.W. TYPICAL URBAN LOCAL CROSS SECTION

POCO ROAD

48 HOURS BEFORE YOU DIG, CALL UTILITY LOCATORS

UTILITY NOTIFICATION CENTER OF COLORADO

IT'S THE LAW THE LOCATIONS OF EXISTING UNDERGROUND UTILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE CAUSED BY HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES.

NO.	REVISION	DATE
1	REVISED PER COUNTY COMMENTS	06-10-19
2	REVISED PER COUNTY COMMENTS	01-21-20
3	REVISED PER COUNTY COMMENTS	6-5-20



MARC A. WHORTON, COLORADO RE.

CONSULTING 9 N. Cascade Avenue, Suite 200


olorado Springs, Colorado 80903


RETREAT AT TIMBERRIDGE FILING NO. 1 CONSTRUCTION DRAWINGS


STREET SECTIONS / EROSION CONTROL NOTES


DESIGNED BY | PRA | SCALE DATE 04-05-19 PRA (H) 1"= N/A | SHEET 2 OF 35 DRAWN BY


CHECKED BY |(V) 1" = N/A | JOB NO.(719)785-0799(Fax)
















































(V) 1"= N/A JOB NO. 1185.00

CHECKED BY




THE LOCATIONS OF EXISTING UNDERGROUND UTILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR

SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR SHALL

PRESERVE ANY AND ALL UNDERGROUND UTILITIES.

BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH

MIGHT BE CAUSED BY HIS FAILURE TO EXACTLY LOCATE AND



UNPLATTED FUTURE STERING RANCH DEVELOPMENT

PREPARED UNDER MY DIRECTUSUPERVISION FOR AND ON BEHALF OF CLASSIC CONSULTING ENGINEERS AND SURVEYORS, LLC UTILITY NOTIFICATION CENTER OF COLORADO IT'S THE LAW


6/10/2020 MARC. A. WHORTON, COLORADO R.E. #37155 Colorado Springs, Colorado 80903 (719)785-0799(Fax)





RETREAT AT TIMBERRIDGE FILING NO. 1 CONSTRUCTION PLANS


STREET LIGHT POLE LOCATION PLAN


					. "		ı
DESIGNED BY	MAW	SCALE	DATE	0	4-05	-20	
DRAWN BY	MAW	(H) 1"= 200)' SHEET	20	OF	35	
CHECKED BY		(V) 1"= N/	A JOB NO).	1185.	00	
































STEEL GRATE QUANTITIES

SECTION VIEW

SECTION A-A

INLET ON GRADE (FLOW FROM ONE DIRECTION)

SECTION A-A

INLET AT BOTTOM OF VERTICAL CURVE

(FLOW FROM TWO DIRECTIONS)

SECTION D-D

STANDARD INLET GRATE

Colorado Department of Transportation

Project Development Branch DD/LTA

THIS SLOPE SHALL BE SHOWN ON THE PLANS

- HEIGHT OF DIKE

SYMMETRICAL ABOUT & SUPER TO SHALL RIDAWAY & RIDAWAY &

MATCH MEDIAN SLOPE

L- A INLET WITH DITCH PAVING


EARTHWORK ASSOCIATED WITH DIKE INCLUDED IN THE COST OF THE INLET


SECTION B-B


INLET CONNECTED TO A SKEWED CROSS PIPE

10:1 MAX.

NORMAL MEDIAN DITCH GRADE -







SLOT DETAIL IN 3½" x ¼" FLATS SAME AS IN STANDARD INLET GRATE

STANDARD PLAN NO.


M-604-10


Sheet No. 1 of 1

CLOSE MESH GRATE

INLET, TYPE C


SECTION E-E






SCALE 1" = 50' HORZ.

1" = 5' VERT.



RAIN GARDEN

WQCV REQUIRED = 1,045 CF WQCV PROVIDED = 3,572 CFUNDERDRAIN ORIFICE DIA. = 13/16 IN. 6" SLOTTED UNDERDRAIN SPACED 15' O.C.



SEE RETREAT AT TIMBERRIDGE FILING NO. 1 GRADING AND EROSION CONTROL PLAN FOR EROSION CONTROL DETAILS.

9 N. Cascade Avenue, Suite 200

48 HOURS BEFORE YOU DIG, CALL UTILITY LOCATORS

UTILITY NOTIFICATION CENTER OF COLORADO IT'S THE LAW

THE EXT
THE LOCATIONS OF EXISTING UNDERGROUND UTILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE CAUSED BY HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES.

	NO.	REVISION	DATE
	1	REVISED PER COUNTY COMMENTS	08-13-19
	2	REVISED PER COUNTY COMMENTS	04-16-20
	3	REVISED PER COUNTY COMMENTS	6-9-20
ı			
L			

REVIEW: PREPARED UNDER MY DIRECT SUPERVISION FOR AND ON BEHALF OF CLASSIC CONSULTING ENGINEERS AND SURVEYORS, LLC 6/10/2020

MARC A. WHORTON, COLORADO R.E. #37155





colorado Springs, Colorado 80903 (719)785-0799(Fax)


RETREAT AT TIMBERRIDGE FILING NO. 1 CONSTRUCTION PLANS


RAIN GARDEN AND DETAILS


DESIGNED BY	MAW	SCALE	DATE	04-05-19
DRAWN BY	MAW	(H) 1"= 30'	SHEET 3	0 OF 35
CHECKED BY		(V) 1"= N/A	JOB NO.	1185.00











CONTECH ENGINEERED SOLUTIONS, LLC DESIGN OF CONCRETE SPREAD FOOTINGS, CONCRETE HEADWALLS AND WINGWALLS FOR A TWIN 24'X10'-4" MULTI-PLATE ARCH STRUCTURE (617696); RETREAT AT TIMBER RIDGE, EL PASO, COLORADO


INDEX


- 1. TITLE SHEET/INDEX
- PLAN, PROFILE & FOOTINGS
- ELEVATION VIEWS AND WINGWALL SECTION
- DOWNSTREAM HEADWALL DETAILS
- DOWNSTREAM SECTIONS AND DETAILS
- UPSTREAM HEADWALL DETAILS
- UPSTREAM SECTIONS AND DETAILS
- 8. SPECIFICATIONS





- 1.) CONCRETE SHALL BE f'c = 3,500 psi.
- 2.) ALL REINFORCEMENT SHALL BE
- ASTM A-615, GRADE 60. 3.) FOOTING IS DESIGNED FOR A 3,500 psf ALLOWABLE BEARING CAPACITY. THIS VALUE MUST BE FIELD VERIFIED PRIOR TO CONSTRUCTION.
- 4.) SCOUR IS NOT ADDRESSED HEREIN AND IS THE RESPONSIBILITY OF OTHERS THAN


				_		
		(_		
			Engine	ers		
		TITL	E SHEET	/ IN	IDEX	
Drawn By		Date	CONTECH EN			
1 1	JBE	03/20/20	DESIGN OF CO			
	Approved Date		CONCRETE HEADWALLS AND WINGWALLS FOR A TWIN 24'x10'-4" MULTI-PLATE ARCH			
Ву			STRUCTURE (6176			
<u> </u>					COLORADO	
Scale			Project No.	Rev.	Sheet	
	GRAF	PHIC	CBC-23088	-	1	of 8













WEEP HOLE DETAIL NOT TO SCALE




NOTES FOR EXPANSION JOINT:

A FILTER CLOTH THREE FEET IN WIDTH AND DOUBLE
THICKNESS SHALL BE APPLIED TO ALL TRANSVERSE JOINTS
IN THE FOOTING AND WALLS. THE MATERIAL SHALL BE CENTERED ON THE JOINT AND THE EDGES SEALED WITH A MASTIC OR WITH TWO SIDED TAPE. THE FILTER CLOTH SHALL BE A GEOTEXTILE MEETING THE APPROVAL OF THE ENGINEER.




KEYED CONSTRUCTION JOINT DETAIL NOT TO SCALE








- 1.) CONCRETE SHALL BE f'c = 3,500 psi.
- 2.) ALL REINFORCEMENT SHALL BE ASTM A-615, GRADE 60.
- 3.) FOOTING IS DESIGNED FOR A 4,000 psf
 LFRD FACTORED BEARING CAPACITY. THIS VALUE
 MUST BE FIELD VERIFIED PRIOR TO CONSTRUCTION.
- 4.) SCOUR IS NOT ADDRESSED HEREIN AND IS THE RESPONSIBILITY OF OTHERS THAN CBC ENGINEERS.







FOR A TWIN 24'x10'-4" MULTI-PLATE ARCH STRUCTURE (617696); RETREAT AT TIMBER RIDGE EL PASO, COLORADO

5 of 8 GRAPHIC CBC-23088










- 1.) CONCRETE SHALL BE f'c = 3,500 psi.
- 2.) ALL REINFORCEMENT SHALL BE ASTM A-615, GRADE 60.
- 3.) FOOTING IS DESIGNED FOR A 4,000 psf LFRD FACTORED BEARING CAPACITY. THIS VALUE MUST BE FIELD VERIFIED PRIOR TO
- CONSTRUCTION. 4.) SCOUR IS NOT ADDRESSED HEREIN AND IS THE RESPONSIBILITY OF OTHERS THAN CBC ENGINEERS.



GEOTEXTILE

(TYP)

SCREEN (TYP)

WINGWALL/HEADWALL

FOOTING



LIPSTREAM SECTIONS AND DETAILS

UP3	INEAM			ND DETAILS
Drawn	Date CONTECH ENGINEERED SOLUTIONS			
Ву	By DESIGN OF CONCRETE SPRE JBE 03/20/20 CONCRETE HEADWALLS AND			E SPREAD FOOTINGS,
JBE				LLS AND WINGWALLS
Approved	Date FOR A TWIN 24'x10'-4" MULTI-PL			" MULTI-PLATE ARCH
Ву		STRUCTURE (6176	TREAT AT TIMBER RIDGE,	
		`EL I	PAŚO, C	COLORADO
Scale		Project No.	Rev.	Sheet
GRAPHIC		CBC-23088	-	7 of 8

I - GENERAL

1.0 STANDARDS AND DEFINITIONS

- 1.1 STANDARDS All standards refer to latest edition unless otherwise noted.
 - 1.1.1 ASTM D-698-70 (Method C) "Standard Test Methods for Moisture. Density Relations of Soils and Soil Aggregate Mixtures Using 5.5-lb (2.5 kg.) Rammer and 12inch (305-mm) Drop".
 - 1.1.2 ASTM D-2922 "Standard Test Method for Density of Soil and Soil Aggregate in Place by Nuclear methods (Shallow Depth)".
 - 1.1.3 ASTM D-1556 "Standard Test Method for Density of Soil in place by the Sand-Cone Method".
 - 1.1.4 ASTM D-1557 "Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort."
 - 1.1.5 All construction and materials shall be in accordance with the latest AASHTO LRFD Bridge Design Specifications.

1.2 **DEFINITIONS**

- **1.2.1** Owner In these specifications the word "Owner" shall mean Elite Properties of America, LLC.
- 1.2.2 Engineer In these specifications the word "Engineer" shall mean the Owner designated engineer.
- 1.2.3 Design Engineer In these specifications the words "Design Engineer" shall mean CBC Engineers and Associates, Ltd.
- 1.2.4 Contractor In these specifications the word "Contractor" shall mean the firm or corporation undertaking the execution of any work under the terms of these specifications.
- **1.2.5** Approved In these specifications the word "approved" shall refer to the approval of the Engineer or his designated representative.
- 1.2.6 As Directed In these specifications the words "as directed" shall refer to the directions to the Contractor from the Owner or his designated representative.

2.0 GENERAL CONDITIONS

2.1 The Contractor shall furnish all labor, material and equipment and perform all work and services except those set out and furnished by the Owner, necessary to complete in a satisfactory manner the site preparation, excavation, filling, compaction, grading, footing construction, headwall/wingwall construction as shown on the plans and as described therein.

This work shall consist of all mobilization clearing and grading, grubbing, stripping, removal of existing material unless otherwise stated, preparation of the land to be filled, filling of the land, spreading and compaction of the fill, and all subsidiary work necessary to complete the grading of the cut and fill areas to conform with the lines, grades, slopes, and specifications.

This work is to be accomplished under the observation of the Owner or his designated representative.

2.2 Prior to bidding the work, the Contractor shall examine, investigate and inspect the construction site as to the nature and location of the work, and the general and local conditions at the construction site, including, without limitation, the character of surface or subsurface conditions and obstacles to be encountered on and around the construction site; and shall make such additional investigation as he may deem necessary for the planning and proper execution of

If conditions other than those indicated are discovered by the Contractor, the Owner should be notified immediately. The material which the Contractor believes to be a changed condition should not be disturbed so that the owner can investigate the condition.

2.3 The construction shall be performed under the direction of an experienced engineer who is familiar with the design plan.

II – FOOTINGS

1.0 EXCAVATION FOR FOOTINGS

- 1.1 Footing excavation shall consist of the removal of all material, of whatever nature, necessary for the construction of foundations.
- 1.2 It shall be the responsibility of the Contractor to identify and relocate all existing utilities which conflict with the proposed footing locations shown on the plan. The Contractor must call the appropriate utility company at least 48 hours before any excavation to request exact field location of utilities, and coordinate removal and installation of all utilities with the respective utility company.
- 1.3 The side of all excavations shall be cut to prevent sliding or caving of the material above the footings.
- 1.4 Excavated material shall be disposed in accordance with the plan established by the Engineer.
- 1.5 The footings for the MULTI-PLATE arch, and headwalls/wingwalls are designed for an allowable bearing capacity of the non-yielding foundation material of 3,500 psf and a friction factor of 0.45. These values shall be verified in the field before construction. The evaluation and design of any required foundation improvement to achieve the design allowable bearing capacity and friction factor, and to protect against frost and scour and settlement, is the responsibility of others than CBC.

2.0 CONCRETE FOOTING DIMENSIONS

The footings shall be reinforced in accordance with the construction drawings.

III - HEADWALLS/WINGWALLS

- 1.0 The headwalls/wingwalls shall consist of reinforced concrete conforming to Chapter IV of these specifications and to Division II, Section 8, of the AASHTO Standard Specifications for Highway Bridges having a minimum compression strength of 4,000 psi.
- 2.0 Reinforcing steel shall conform to ASTM A-615, Grade 60, having minimum yield strength of
- 3.0 The headwalls shall be anchored to the MULTI-PLATE arch in the manner shown on the plans and shall be formed and poured in accordance with the plan dimensions.
- 4.0 Round weep holes spaced not over 5 feet on center shall be placed in the walls above finished grade as shown on the construction drawings. A granular envelope, consisting of #57 stone (clean 3/4" aggregate) or equivalent, shall be placed behind each weep hole for a distance of approximately 1 foot from all edges of the weep hole. A free-draining geotextile screen shall be placed between the weep hole and the stone to prevent erosion of the stone.
- 5.0 The select backfill behind the headwalls must be a well-graded, angular, durable granular material conforming to the select backfill specifications for the MULTI-PLATE arch placed and compacted to achieve a minimum internal friction angle of 34 degrees and a maximum unit weight of 120 pcf. The material must be placed in strict conformance with the project specifications, the manufacturer's requirements, and industry standards. The select backfill behind the wingwalls extending to a minimum distance of 15.0 feet behind the back face of the walls must be a well-graded, angular, durable granular material placed and compacted to achieve a minimum internal friction angle of 34 degrees and a maximum unit weight of 120 pcf. These values must be field verified.
- 6.0 All Federal, State, and Local regulations shall be strictly adhered to relative to excavation sideslope geometry and any required excavation shoring.

IV – CONCRETE FOR FOOTINGS AND HEADWALLS/WINGWALLS

CODES AND STANDARDS

1.1 Reinforced concrete shall conform to the requirements of AASHTO Standard Specifications for Highway Bridges, Division II - Construction, Section 8, "Concrete Structures", for Class A concrete, having a minimum compressive strength of 4,000 psi.

2.0 STANDARDS FOR MATERIALS

- **2.1** Portland Cement Conforming to ASTM Specification C-150, Type I or II.
 - 2.2 Water The water shall be drinkable, clean free from injurious amounts of oils, acids, alkalis, organic materials, or deleterious substances.
 - 2.3 Aggregates Fine and coarse aggregates shall conform to current ASTM Specification C-33 "Specification for Concrete Aggregates" except that local aggregates which have been shown by tests and by actual service to produce satisfactory qualities may be used when approved by
 - **2.4** Submittals Test data and/or certifications to the Owner shall be furnished upon request.

3.0 PROPORTIONING OF CONCRETE

3.1 COMPOSITION

- **3.1.1** The concrete shall be composed of cement, fine aggregate, coarse aggregate and water.
- **3.1.2** The concrete shall be homogeneous, readily placeable and uniformly workable and shall be proportioned in accordance with ACI-211.1.
- 3.1.3 Proportions shall be established on the basis of field experience with the materials to be employed. The amount of water used shall not exceed the maximum 0.45 water/cement ratio, and shall be reduced as necessary to produce concrete of the specified consistency at the time of placement.
- 3.1.4 An air-entraining admixture, conforming to the requirements of ASTM C260, shall be used in all concrete furnished under this contract. The quantity of admixture shall be such as to produce an air content in the freshly mixed concrete of 6 percent plus or minus 1 percent as determined in accordance with ASTM C231 or C173.

3.2 Qualities Required - As indicated in the table below:

TABLE IV-1

QUALITIES REQUIRED					
ITEM	QUALITY REQUIRED				
AASHTO Class	A				
Type of Cement	I or II				
Compressive Strength fc @ 28 days	4,000 psi				
Slump inches	2 - 4 in				

- 3.3 Maximum Size of Coarse Aggregates Maximum size of coarse aggregates shall not be larger than 19 mm (3/4 inches).
- 3.4 Rate of Hardening of Concrete Concrete mix shall be adjusted to produce the required rate of hardening for varied climatic conditions:

Under 40°F Ambient Temperature - Accelerate calcium chloride at 2% is acceptable when used within the recommendations of ACI-306R "Cold Weather Concreting." Admixtures containing chloride ion in excess of 1% by weight of admixture shall not be used in reinforced concrete.

4.0 MIXING AND PLACING

- 4.1 Equipment Ready Mix Concrete shall be used and shall conform to the "Specifications for Ready-Mix Concrete," ASTM C-94. Approval is required prior to using job mixed concrete.
- 4.2 Preparation All work shall be in accordance with ACI-304, "Recommended Practice for Measuring, Mixing, Transporting and Placing Concrete." All construction debris and extraneous matter shall be removed from within the forms. Concrete shall be placed on clean surfaces, free from water. Concrete that has to be dropped four (4) feet or more shall be placed through a tremie.
- 4.3 All concrete shall be consolidated by internal mechanical vibration immediately after placement. Vibrators shall be of a size appropriate for the work, capable of transmitting vibration to concrete at frequencies of not less than 4,500 impulses per minute.

5.0 FORM WORK

- 5.1 Forms shall be of wood, steel or other approved material and shall be set and held true to the dimensions, lines and grades of the structure prior to and during the placement of concrete.
- 5.2 Forms shall not be removed until the concrete has sufficient strength to prevent concrete damage and/or drainage.

6.0 CURING

6.1 Fresh concrete shall be protected from rains, flowing water and mechanical injury for a period of four (4) days. Loads shall not be placed on the concrete until it has reached its design strength.

7.0 REINFORCING STEEL

7.1 MATERIAL

7.1.1 All reinforcing bars shall be deformed bars (ASTM-A615) Grade 60.

7.2 BENDING AND SPLICING

- 7.2.1 Bar reinforcement shall be cut and bent to the shapes shown on the plans Fabrication tolerances shall be in accordance with ACI 315. All bars shall be bent cold. unless otherwise permitted.
- 7.2.2 All reinforcement shall be furnished in the full lengths indicated on the plans unless otherwise permitted. Except for splices shown on the plans and splices for No. 5 or smaller bars, splicing of bars will not be permitted without written approval. Splices shall be staggered as far as possible.
- 7.2.3 In lapped splices, the bars shall be placed and wired in such a manner as to maintain the minimum distance to the surface of the concrete shown on the plans.
- 7.2.4 Substitution of different size bars will be permitted only when authorized by the engineer. The substituted bars shall have an area equivalent to the design area, or larger.


7.3 PLACING AND FASTENING

- 7.3.1 Steel reinforcement shall be accurately placed as shown on the plans and firmly held in position during the placing and setting of concrete. Bars shall be tied at all intersections around the perimeter of each mat and at not less than 2 foot centers or at every intersection, whichever is greater, elsewhere. Welding of cross bars (tack welding) will not be permitted for assembly of reinforcement.
- 7.3.2 Reinforcing steel shall be supported in its proper position by use of mortar blocks, wire bar supports, supplementary bars or other approved devices. Such devices shall be of such height and placed at sufficiently frequent intervals so as to maintain the distance between the reinforcing and the formed surface or the top surface within 1/4 inch of that indicated on the plans.

V - FILTER FABRIC (GEOTEXTILE SCREEN)

- 1.0 Filter fabric shall be placed at all locations shown on the construction drawings, and as necessary between all dissimilar materials to prevent soil migration and to maintain a soil-tight system.
- 2.0 Filter fabric cloth shall conform to Contech specification for C60-NW or equivalent and shall meet the following ASTM tests:
 - **2.1** ASTM D4751 Apparent opening size equal to #70 U.S. Standard Sieve Size.
 - 2.2 ASTM D4632 (Grab Tensile Test) Minimum Strength = 160 pounds.
 - **2.3** ASTM D4632 (Grab Elongation) 30-70%.
 - **2.4** ASTM D4533 (Trapezoidal Tear) Minimum Strength = 60 pounds.
 - 2.5 ASTM D4355 (Stabilized for Heat and Ultra-Violet Degradation) 70% strength retained.
- 3.0 The minimum fabric coefficient of permeability (ASTM D4491) shall be 0.24 cm/sec.
- The fabric shall be non-woven with a minimum thickness (ASTM D5199) of 60 mils.
- Fabric shall not be placed over sharp or angular rocks that could tear or puncture it.
- 6.0 Care should be exercised to prevent any puncturing or rupture of the filter fabric. Should such rupture occur the damaged area should be covered with a patch of filter fabric using an overlap minimum of one (1) foot.





CBC-23088

GRAPHIC