



ORIGINAL PERMIT APPLICANT(S)

CHERYL A. EVERITT
WILLIAM M. EVERITT

APPROVED WELL LOCATION

Water Division: 1 Water District: 1
Designated Basin: KIOWA-BIJOU
Management District: N/A
County: EL PASO
Parcel Name: N/A
Physical Address: 17055 WEST GOSHAWK ROAD
 COLORADO SPRINGS, CO 80908

SW 1/4 NW 1/4 Section 23 Township 11.0 S Range 65.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 530961.5 Northing: 4325644.2

PERMIT TO USE AN EXISTING WELL

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-107(7) for the use of an existing well constructed under permit no. 155716 and the Findings and Order of the Colorado Ground Water Commission dated March 26, 2018, for Determination of Water Right No. 3510-BD.
- 4) The use of ground water from this well is limited to domestic use inside 1 single family dwelling, including the watering of domestic animals and the irrigation of up to 1 acre of lawns and gardens. The place of use shall be limited to the 20 acre land area claimed in the above described Order of the Commission.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The annual withdrawal of ground water from this well shall not exceed 1 acre-foot, subject to the total annual withdrawal limitations and conditions as specified by the above referenced Order of the Commission.
- 7) This well must have been constructed to withdraw water only from the Dawson aquifer. The total depth of the well shall not exceed 1050 feet, which corresponds to the base of the aquifer. At a minimum, plain casing shall be installed and grouted through all nonconsolidated materials and shall extend a minimum of 80 feet into the bedrock formation to prevent production from other zones.
- 8) The owner shall mark the well in a conspicuous location with the well permit number and name of aquifer as appropriate, and shall take necessary means and precautions to preserve these markings.
- 9) This well shall have been constructed within 200 feet of the location specified on this permit. This well shall not be located within 600 feet of another large-capacity well completed in the Dawson aquifer.
- 10) The entire length of the hole shall be geophysically logged as required by Rule 9 of the Statewide Nontributary Ground Water Rules prior to installing casing.
- 11) A totalizing flow meter or Commission approved measuring device must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (collected at least annually) and submitted to the Ground Water Commission upon request.
- 12) The return flows from the inhouse supply component of this well use have been claimed as a replacement source, pursuant to the Findings and Order of the Commission dated March 26, 2018. As a result, the return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 13) No more than 98% of the ground water withdrawn annually shall be consumed. The Commission may require well owners to demonstrate periodically that no more than 98% of the water withdrawn is being consumed.

WELL PERMIT NUMBER 81940-F

RECEIPT NUMBER 3685699

14) Issuance of this permit cancels permit no. 155716.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.



Date Issued: 4/25/2018

Expiration Date: N/A

Issued By SHANNON PORTER

PERMIT HISTORY

03-14-2025	CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO ERROL L. MURPHY
03-14-2025	CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO RENATE R. MURPHY
03-14-2025	CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO EVALENE L. MURPHY
06-19-2019	CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO GEORGE B. ROLSTON
06-19-2019	CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO CASSANDRA J. ROLSTON