



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Wirenut, PPR-22-34

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

- The 2.97-acre commercial lot will be provided water and wastewater services by Cherokee Metropolitan District.
- There is a finding for sufficiency in terms of water quality for drinking water obtained from this Colorado Department of Public Health and Environment, Water Quality Control Division, regulated public water system. PWSID # CO0121125.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area, have potentially higher radon levels than other areas of the country.
- The water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
23July2022