

☎ 303.859.0344

✉ chris@strykersiteservices.com

🌐 strykersiteservices.com



PO Box 1558 | Denver, CO. 80201

June 25th, 2021

El Paso County
Planning and Community Development
2880 International Circle
Colorado Springs, CO. 80910

RE: Proposed T-Mobile Generator Add (DN04161)

To Whom it may concern,

T-Mobile is proposing to add a diesel-powered backup generator to the existing Telecommunication Facility located at 12 E. Clover Circle. The proposed generator will be placed on the ground level near the existing radio/electrical equipment. Generator noise levels compare favorably with most central air units at 70 decibels, making this unit suitable for installation in neighborhood and business environments. The required ground space is approx. 180 sq. ft. (15' x 12'). If you have any questions or require additional information, please do not hesitate to call.

Thank you,

Chris C. Stryker

Chris C. Stryker
Manager, Stryker Site Services, LLC
Contractor for T-Mobile
(303) 859-0344 (voice)

please add the following to the letter of intent:

- Owner name, contact telephone number, and email for responsible party
- Applicant name (if not owner), contact telephone number, and email for responsible party
- Property tax schedule number
- Current zoning of the property
- A discussion summarizing the proposed request and compliance with the applicable requirements of the Land Development Code.
- A discussion regarding how the proposed request complies with the definition of the proposed use and any applicable use specific standards within the Land Development Code.

