EL PASO COUNTY GRADING AND EROSION CONTROL PLAN SUBMITTAL CHECKLIST

Revised 5/21/07

1) Vicinity map.	Resolved - DTorres 06/10 2019 1:54:44 PM
2) North arrow and acceptable scale (1"=20' to 1"=100').	Resolved - DTorres 06/10/2019 1:54:52 PM
3) Existing and proposed Contours 2 feet or less (except for hillside).	testived - DTorres 16/10/2019 1:57:31 PM
4) Standard EPC Grading and Erosion Control Notes included.	Resolved - DTorres 06/10/2019 1:57:38 PM
5) Delineate mapped FEMA 100-yr floodplain.	Resolved - DTorres 06/10/2019 1:57:47 PM
6) Construction site boundaries clearly delineated.	Resolved - DTorres 06/10/2019 1:57:47 PM
7) Areas of soil disturbance shown.	Resolved - DTorres 06/10/2019 1:57:47 PM
8) All proposed construction BMPs and Construction BMP details shown.	Resolved - DTorres 06/10/2019 1:57:47 PM
9) Show existing vegetation.	Resolved - DTorres 06/10/2019 1:57:47 PM
10) Existing and proposed water courses including springs, streams, wetlands, Detention	Resol ed - DTorres 06/10/2019 1:57:47 PM
ponds, roadside ditches, irrigation ditches and other water surfaces.	
11) Show any existing structures.	Resolved - DTorres 06/10/2019 1:57:47 PM
12) Show all existing utilities.	Resolved - DTorres 06/10/2019 1:57:47 PM
13) Submit geotechnical investigation from soils engineer.	Resolved - DTorres 06/10/2019 1:57:47 PM
14) Conclusions from soils report and geologic hazards report incorporated in grading design.	Resolved - DTorres 06/10/2019 1:57:47 PM
15) Show existing and proposed property lines and subdivision boundary.	Resolved - DTorres 06/10/2019 1:57:47 PM
16) All existing and proposed easements (permanent and construction) including required off	Unresolved - DTorres 06/10/2019 3:10:04 PM
site easements.	
17) Any offsite grading clearly shown and called out.	Resolved - DTorres 06/10 2019 1:57:47 PM
18) Existing and proposed storm drainage facilities as necessary to show all BMPs.	Resolved - DTorres 06/10/2019 1:57:47 PM
19) Temporary sediment ponds provided for disturbed drainage areas greater than 1 acre.	Resolved - DTorres 06/10 2019 1:57:47 PM
20) Proposed slopes steeper than 3:1 with top and toe of slope delineated.	Resolved - DTorres 06/10/2019 1:57:47 PM
21) Erosion control blanketing shown on slopes steeper than 3:1.	Resolved - DTorres 06/10/2019 1:57:47 PM
22) Retaining walls greater than or equal to 4ft in height require design by P.E. and building	Resolved - DTorres 06/10/2019 1:57:47 PM
permit from Regional Building Department. Locations to be shown on the plan (not located in	
County ROW).	
23) Vehicle tracking shown at all construction entrances.	Resolved - DTorres 06/10/2019 1:57:47 PM
24) The erosion control plan is to be certified by a Colorado Registered P.E. with appropriate	Resolved - DTorres 06/10/2019 1:57:47 PM
signature blocks for EPC and the Engineer and the statement "The Owner will comply with the	
requirements of the Erosion Control Plan" signed by the owner.	
25) Required Signature blocks:	Resolved - DTorres 06/10/2019 1:57:47 PM