

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID: SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
Dibromochloropropane	< 0.02 ug/L	EPA 504.1	0.02 ug/L	10/25/18	SPF	0.2
Ethylene dibromide	< 0.01 ug/L	EPA 504.1	0.01 ug/L	10/25/18	SPF	0.05
Aldrin	< 0.05 ug/L	EPA 505	0.05 ug/L	10/24/18	SPF	
Chlordane	< 0.2 ug/L	EPA 505	0.2 ug/L	10/24/18	SPF	2
Dieldrin	< 0.01 ug/L	EPA 505	0.01 ug/L	10/24/18	SPF	
Endrin	< 0.01 ug/L	EPA 505	0.01 ug/L	10/24/18	SPF	2
Heptachlor epoxide	< 0.02 ug/L	EPA 505	0.02 ug/L	10/24/18	SPF	0.2
Hexachlorobenzene	< 0.1 ug/L	EPA 505	0.1 ug/L	10/24/18	SPF	1
Hexachlorocyclopentadiene	< 0.1 ug/L	EPA 505	0.1 ug/L	10/24/18	SPF	50
Lindane	< 0.02 ug/L	EPA 505	0.02 ug/L	10/24/18	SPF	0.2
Methoxychlor	< 0.1 ug/L	EPA 505	0.1 ug/L	10/24/18	SPF	40
Polychlorinated biphenyl's	< 0.1 ug/L	EPA 505	0.1 ug/L	10/24/18	SPF	0.5
Toxaphene	< 1 ug/L	EPA 505	1 ug/L	10/24/18	SPF	3
2,4,5-TP	< 0.2 ug/L	EPA 515.4	0.2 ug/L	10/31/18	mbs	50
2,4,-D	< 0.1 ug/L	EPA 515.4	0.1 ug/L	10/31/18	mbs	70
Dalapon	< 1.0 ug/L	EPA 515.4	1.0 ug/L	10/31/18	mbs	200
Dicamba	< 0.5 ug/L	EPA 515.4	0.5 ug/L	10/31/18	mbs	
Dinoseb	< 0.2 ug/L	EPA 515.4	0.2 ug/L	10/31/18	mbs	7
Pentachlorophenol	< 0.04 ug/L	EPA 515.4	0.04 ug/L	10/31/18	mbs	1
Picloram	< 0.1 ug/L	EPA 515.4	0.1 ug/L	10/31/18	mbs	500

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

240 South Main Street / Brighton, CO 80601-0507 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507 / Fax: 303-659-2315

Report To: Jerry Hannigan

Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan

Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
Alachlor	< 0.2 ug/L	EPA 525.2	0.2 ug/L	10/30/18	LEH	2
Atrazine	< 0.1 ug/L	EPA 525.2	0.1 ug/L	10/30/18	LEH	3
Benzo(a)pyrene	< 0.02 ug/L	EPA 525.2	0.02 ug/L	10/30/18	LEH	0.2
Butachlor	< 0.25 ug/L	EPA 525.2	0.25 ug/L	10/30/18	LEH	
Di(2-ethylhexyl)adipate	< 0.6 ug/L	EPA 525.2	0.6 ug/L	10/30/18	LEH	400
Di(2-ethylhexyl)phthalate	< 0.6 ug/L	EPA 525.2	0.6 ug/L	10/30/18	LEH	6
Heptachlor	< 0.04 ug/L	EPA 525.2	0.04 ug/L	10/30/18	LEH	0.4
Metolachlor	< 0.25 ug/L	EPA 525.2	0.25 ug/L	10/30/18	LEH	
Metribuzin	< 0.25 ug/L	EPA 525.2	0.25 ug/L	10/30/18	LEH	
Propachlor	< 0.25 ug/L	EPA 525.2	0.25 ug/L	10/30/18	LEH	
Simazine	< 0.07 ug/L	EPA 525.2	0.07 ug/L	10/30/18	LEH	4
3-Hydroxycarbofuran	< 0.6 ug/L	EPA 531.1	0.5 ug/L	10/24/18	MBS	
Aldicarb	< 0.6 ug/L	EPA 531.1	0.6 ug/L	10/24/18	MBS	
Aldicarb sulfone	< 1.0 ug/L	EPA 531.1	1.0 ug/L	10/24/18	MBS	
Aldicarb sulfoxide	< 0.7 ug/L	EPA 531.1	0.7 ug/L	10/24/18	MBS	
Carbaryl	< 0.5 ug/L	EPA 531.1	0.5 ug/L	10/24/18	MBS	
Carbofuran	< 0.9 ug/L	EPA 531.1	0.9 ug/L	10/24/18	MBS	40
Methomyl	< 0.5 ug/L	EPA 531.1	0.5 ug/L	10/24/18	MBS	
Oxamyl	< 1.0 ug/L	EPA 531.1	1.0 ug/L	10/24/18	MBS	200
Glyphosate	< 6.0 ug/L	EPA 547	6.0 ug/L	10/29/18	Outside Lab	700

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 ml = Most Probable Number Index/ 100 ml
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 181018072

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
Endothall	< 9 ug/L	EPA 548.1	9 ug/L	10/23/18	SPF	100
Diquat	< 0.4 ug/L	EPA 549.2	0.4 ug/L	10/23/18	Sean	20
1,1,1,2-Tetrachloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,1,1-Trichloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	200
1,1,2,2-Tetrachloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,1,2-Trichloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
1,1-Dichloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,1-Dichloroethylene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	7
1,1-Dichloropropene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,2,3-Trichlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,2,3-Trichloropropane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,2,4-Trichlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	70
1,2,4-Trimethylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,2-Dichloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
1,2-Dichloropropane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
1,3,5-Trimethylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,3-Dichloropropane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
1,3-Dichloropropene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Benzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
Bromobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Bromochloromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072	Date Received: 10/18/18
Client PO: Paid CC	Date Reported: 11/12/18
Client Project: Settlers View Subdivision	Matrix: Water - Drinking

Customer Sample ID: SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
Bromodichloromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Bromoform	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Bromomethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Carbon Tetrachloride	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
Chlorodibromomethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Chloroethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Chloroform	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Chloromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
cis-1,2-Dichloroethylene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	70
Dibromomethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Dichlorodifluoromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Dichloromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
Ethylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	700
Fluorotrichloromethane	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Hexachlorobutadiene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Isopropylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
m-Dichlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Monochlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	100
Naphthalene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
n-Butylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
n-Propylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
o-Chlorotoluene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 ml = Most Probable Number Index/ 100 ml
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 181018072

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
o-Dichlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	600
Para-Dichlorobenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	75
p-Chlorotoluene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
p-Isopropyltoluene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
sec-Butylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Styrene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	100
tert-Butylbenzene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	
Tetrachloroethylene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
Toluene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	1000
Total Trihalomethanes	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	80
trans-1,2-Dichloroethylene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	100
Trichloroethylene	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	5
Vinyl chloride	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	2
Xylenes (total)	< 0.5 ug/L	EPA-524.2	0.5 ug/L	10/30/18	LEH	10000

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 ml = Most Probable Number Index/ 100 ml
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

240 South Main Street / Brighton, CO 80601-0507 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507 / Fax: 303-659-2315

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr., Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>Debra W. Hunsaker & Associates</u>	Contact Name: <u>STANLEY HANSEN</u>	Company Name:	Contact Name:	PWSID:	System Name:
Address: <u>1930 Spruce Valley Dr</u>	Address:	City:	State:	City:	State:
City: <u>Mesa Verde State Co Zip: 80132</u>	City:	State:	Zip:	City:	State:
Phone:	Fax:	Phone:	Fax:	County:	
Email:		Email:		Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Sampler Name: <u>Tom Marten</u>	PO No.:	Send Forms to State: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			

PHASE I, II, V Drinking Water Analyses (check analysis)

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./ang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha	Radium 226	Radium 228	Radon	Uranium
10/13/13	1:00	S15			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		X				

CAL Task No. 181018072 JT

JML

Instructions: # DBD18090015 / SEE ATTACHED QDR

Relinquished By: Date/Time: 10/13/13 Received By: Stanley Hansen Date/Time: 10/13/13

Delivered Via: HB Relinquished By: HB Date/Time: 10/13/13

Temp. 7.1 °C/liter Sample Pres. Yes No

Seals Present Yes No Headspace Yes No

Date/Time: _____

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
Chloride	1.6 mg/L	EPA 300.0	0.1 mg/L	10/19/18	SEA	
Fluoride	0.43 mg/L	EPA 300.0	0.09 mg/L	10/19/18	SEA	4
Nitrate Nitrogen	0.87 mg/L	EPA 300.0	0.05 mg/L	10/19/18	SEA	10
Nitrite Nitrogen	< 0.03 mg/L	EPA 300.0	0.03 mg/L	10/19/18	SEA	1
Sulfate	4.7 mg/L	EPA 300.0	0.1 mg/L	10/19/18	SEA	
Cyanide-Total	< 0.005 mg/L	EPA 335.4	0.005 mg/L	10/23/18	VDB	0.02
Total						
Iron	< 0.005 mg/L	EPA 200.7	0.005 mg/L	10/24/18	MBN	0.3
Sodium	7.8 mg/L	EPA 200.7	0.1 mg/L	10/24/18	MBN	N/A
Aluminum	0.004 mg/L	EPA 200.8	0.001 mg/L	10/23/18	DBM	0.05
Antimony	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.006
Arsenic	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.01
Barium	0.052 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	2
Beryllium	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.004
Cadmium	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.005
Chromium	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.1
Manganese	< 0.0008 mg/L	EPA 200.8	0.0008 mg/L	10/23/18	DBM	0.05
Mercury	< 0.0001 mg/L	EPA 200.8	0.0001 mg/L	10/22/18	DBM	0.002
Nickel	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	N/A

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 181018072

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID: SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By	MCL
<i>Total</i>						
Selenium	0.002 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.05
Silver	< 0.0001 mg/L	EPA 200.8	0.0001 mg/L	10/23/18	DBM	
Thallium	< 0.001 mg/L	EPA 200.8	0.001 mg/L	10/22/18	DBM	0.002
Zinc	0.014 mg/L	EPA 200.8	0.001 mg/L	10/23/18	DBM	5

Abbreviations/ References:

ML = Minimum Level = LRL = RL
MCL = Maximum Contaminant Level per The EPA
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

240 South Main Street / Brighton, CO 80601-0507 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507 / Fax: 303-659-2315

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr., Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>Seaside W. Household & Associates</u>	Contact Name: <u>STEVEN HANSEN</u>	Company Name:	Contact Name:	PWSID:	System Name:
Address: <u>1763D Spoken Valley Dr</u>	City: _____ State: _____ Zip: _____	Address:	City: _____ State: _____ Zip: _____	Address:	City: _____ State: _____ Zip: _____
City: <u>Moab</u> State: <u>CO</u> Zip: <u>80132</u>	City: _____ State: _____ Zip: _____	City: _____ State: _____ Zip: _____	City: _____ State: _____ Zip: _____	County:	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Phone: _____ Fax: _____	Phone: _____ Fax: _____	Phone: _____ Fax: _____	Phone: _____ Fax: _____	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Send Forms to State: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Email: _____	Email: _____	Email: _____	Email: _____	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Sampler Name: <u>Tom Martin</u>	PO No.:	PO No.:	PO No.:	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

CAL Task No. 181018072

JR

JML

PHASE I, II, V Drinking Water Analyses (check analysis)

Subcontract Analyses

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha ^{beta}	Radium 226	Radium 228	Radon	Uranium
10/15/18	1:00	S15			X	X	X	X	X	X	X	X	X	X				X	X	X	X	X			X				

Instructions: # Q3018090015

CLAUDE / SEE ATTACHED QURE

C/S Info:

Delivered Via: HD

Seals Present Yes No Headspace Yes No

Relinquished By: [Signature] Date/Time: 10/15/18 Received By: [Signature] Date/Time: 10/18/18 Delivered Via: HD Relinquished By: [Signature] Date/Time: _____ C/S Charge Temp. 7.1 °C/ltr N Received By: [Signature] Sample Pres. Yes No Date/Time: _____

Analytical Results

TASK NO: 181018072

Report To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan
Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Customer Sample ID SVS
Sample Date/Time: 10/18/18 1:00 PM
Lab Number: 181018072-01

Test	Result	Method	ML	Date Analyzed	Analyzed By
Bicarbonate	42.7 mg/L as CaCO3	SM 2320-B	0.1	10/23/18	VDB
Calcium as CaCO3	26.3 mg/L	EPA 200.7	0.1	10/24/18	MBN
Carbonate	< 0.1 mg/L as CaCO3	SM 2320-B	0.1	10/23/18	VDB
Hydroxide	< 0.1 mg/L as CaCO3	SM 2320-B	0.1	10/23/18	VDB
Langelier Index	-2.51 units	SM 2330-B		10/25/18	SAN
pH	6.22 units	SM 4500-H-B	0.01	10/18/18	MBN
Temperature	20 °C	SM 4500-H-B	1	10/18/18	MBN
Total Alkalinity	42.7 mg/L as CaCO3	SM 2320-B	0.1	10/23/18	VDB
Total Dissolved Solids	104 mg/L	SM 2540-C	5	10/24/18	ISG

Abbreviations/ References:

ML = Minimum Level = LRL = RL
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 ml's = Most Probable Number Index/ 100 ml's
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>SANDRA W. HANCOCK'S ASSOCIATES</u>	Contact Name: <u>SANDRA HANCOCK</u>	Company Name:	Contact Name:	PWSID:	System Name:
Address: <u>19630 Spruce Valley Dr</u>		Address:		Address:	
City: <u>Mountain View State CO</u>	State: <u>CO</u>	City:	State:	City:	State:
Zip: <u>80132</u>	Zip:	City:	State:	City:	State:
Phone:	Fax:	Phone:	Fax:	County:	
Email:		Email:		Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Sampler Name: <u>TOM WATSON</u>	PO No.:	Send Forms to State: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			

CAL Task No. 181018072 IF JML PHASE I, II, V Drinking Water Analyses (check analysis) Subcontract Analyses

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha ^{Beta}	Radium 226	Radium 228	Radon	Uranium
10/19/18	1:00	SV15			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X

Instructions: CYANIDE / SEE ATTACHED QURE # Q3018090015 C/S Info: HA Seals Present Yes No Headspace Yes No

Relinquished By: [Signature] Date/Time: 10/12/18 Received By: [Signature] Date/Time: 10/18/18 Delivered Via: HA Relinquished By: [Signature] Date/Time: 10/18 C/S Charge Temp: 7.1 Received By: [Signature] Sample Pres Yes No Date/Time: 10/18



Hazen Research, Inc.
4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Lab Control ID: 18M02988

Received: Oct 19, 2018

Reported: Oct 31, 2018

Purchase Order No.

None Received


Customer ID: 20040H

Account ID: Z01034

Stuart Nielson
Colorado Analytical Laboratories, Inc.
PO Box 507
240 South Main Street
Brighton, CO 80601

ANALYTICAL REPORT

*Report may only be copied in its entirety.
Results reported herein relate only to discrete samples
submitted by the client. Hazen Research, Inc. does not warrant
that the results are representative of anything other than the
samples that were received in the laboratory*

By: 
Jessica Axen
Analytical Laboratories Director



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Lab Control ID: 18M02988

Received: Oct 19, 2018

Reported: Oct 31, 2018

Purchase Order No.

None Received

Customer ID: 20040H

Account ID: Z01034

ANALYTICAL REPORT

Stuart Nielson
 Colorado Analytical Laboratories, Inc.

Lab Sample ID		18M02988-001						
Customer Sample ID		181018075-01 - SVS sampled on 10/18/18 @ 1300 by Tom Maher						
Parameter	Units	Code	Result	Precision* +/-	Detection Limit	Method	Analysis Date / Time	Analyst
Gross Alpha	pCi/L	T	1.9	1.6	0.1	SM 7110 B	10/29/18 @ 0826	SS
Gross Beta	pCi/L	T	<3.9	2.4	3.9	SM 7110 B	10/29/18 @ 0826	SS

Certification ID's: CO/EPA CO00008; CT PH-0152; KS E-10265; NJ CO008; NYSELAP (NELAC Certified) 11417; RI LAO00284; WI 998376610, TX T104704256-15-6

*Variability of the radioactive decay process (counting error) at the 95% confidence level, 1.96 sigma.

Codes: (T) = Total (D) = Dissolved (S) = Suspended (R) = Total Residual (AR) = As Received < = Less Than

Analytical Results

TASK NO: 181018072

Report To: Jerry Hannigan

Company: Jerome W. Hannigan and Associates, Inc
19360 Spring Valley Road
Monument CO 80132

Bill To: Jerry Hannigan

Company: Jerome W. Hannigan and Associates,
19360 Spring Valley Road
Monument CO 80132

Task No.: 181018072
Client PO: Paid CC
Client Project: Settlers View Subdivision

Date Received: 10/18/18
Date Reported: 11/12/18
Matrix: Water - Drinking

Lab Number	Customer Sample ID	Sample Date/Time	Test	Result	Method	Date Analyzed
181018072-01C	SVS	10/18/18 1:00 PM	Total Coliform	Absent	SM 9223	10/19/18
			E-Coli	Absent	SM 9223	10/19/18

Abbreviations/ References:

Absent = Coliform Not Detected

Present = Coliform Detected - Chlorination Recommended

Date Analyzed = Date Test Completed

SM = "Standard Methods for the Examination of Water and Wastewater"; APHA, 19th Edition; 1995



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
 240 South Main Street
 Brighton, CO 80601

Lakewood Lab
 12860 W. Cedar Dr, Suite 100A
 Lakewood CO 80228

Phone: 303-659-2313
 Fax: 303-659-2315
www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>Sandrine W. Hunsford & Associates</u>	Contact Name: <u>Stewart Hunsford</u>	Company Name:	Contact Name:	PWSID:	System Name:
Address: <u>19630 Spawny Valley Dr</u>	Address:	City:	State:	City:	State:
City: <u>Montevideo State CO</u>	City: <u>Montevideo</u>	State: <u>CO</u>	Zip: <u>80132</u>	City:	State:
Phone:	Phone:	County:	Zip:	County:	Zip:
Fax:	Fax:	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Email:	Email:	Send Forms to State: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Sampler Name: <u>TOM MARTEN</u>	PO No.:				

PHASE I, II, V Drinking Water Analyses (check analysis)

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal!	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha ^{beta}	Radium 226	Radium 228	Radon	Uranium					
10/13/02	1:00	S15			X	X	X	X	X	X	X	X	X	X			X	X	X	X	X	X			X									
Instructions: <u>See attached RDR</u>					*22 + 2 BROWS																													
Requisitioned By: <u>GWANDE</u>					Date/Time: <u>10/13/02</u>					Received By: <u>ADAM</u>					Date/Time: <u>10/18/02</u>					Delivered Via: <u>HD</u>					Requisitioned By: <u>ADAM</u>					Date/Time: <u>10/18/02</u>				
C/S Info:					Seals Present Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>					Temp: <u>7.1</u> °C/°F					Sample Pres. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>														