

FORM NO.
GWS-10
03/92

STATE OF COLORADO
OFFICE OF THE STATE ENGINEER
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

For Office Use only

RECEIVED

RECEIVED

DEC 11 1998

MAR 03 1999

WATER SOURCES
STATE ENGINEER
COLORADO

WATER SOURCES
STATE ENGINEER
COLORADO

FOR INSTRUCTIONS, SEE REVERSE SIDE

STATEMENT OF BENEFICIAL USE

WELL PERMIT NUMBER 5195F-R

1. WELL OWNER

NAME(S) City of Fountain
Mailing Address 116 South Main Street
City, St. Zip Fountain, CO 80817
Phone (719) 382-7591

1-21-99

2. WELL LOCATION: COUNTY El Paso OWNER'S WELL DESIGNATION Well No. 7

(Address) (City) (State) (Zip)

SW 1/4 of the NW 1/4, Sec. 4 Twp. 17 N. or X S. Range 65 E. or X W. 6th P.M.

Distances from Section Lines 2,210 Ft. from X N. or S. Line, 340 Ft. from E. or X W. Line.

3. The well is being used for the following purpose(s): Industrial, municipal
This well supplies water for the Pikes Peak International Raceway

4. Water from the well was first used beneficially
under this permit number, for the above described purposes on September 21 19 98.
(Do not report a date which is before the issued date of this permit)

The pumping rate claimed is 900 RBW FTM WATER gallons per minute.

6. The average annual amount of water diverted is 100 acre feet.

7. The land area irrigated (watered) by water from this well is: 0 Acres or Square feet,
(Number)

described as: N/A

(Legal Description)
or as N/A Subdivision Lot(s) Block Filing/Unit

8. Well drilled by: Lesh Drilling, Inc. Lic. No: 21-B

Pump installed by: Lesh Drilling, Inc. Lic. No: 21-B

9. Meter Mfg. by McCrometer Serial No.: 98-8-1148W Date Installed: 5-15-98

I (we) have read the statements made herein, know the contents thereof, and state that they are true to my (our) knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a Class 1 misdemeanor.]

10. Name/Title (Please type or print) Gary B. Thompson, P.E.
W. W. Wheeler and Associates, Inc.
Consulting Engineers for City of Fountain
Signature Gary B. Thompson
Date 12-8-98

FOR OFFICE USE ONLY

State Engineer
Court Case No.

Div. 2 Co. 21 WD 10 Basin MD

Date
Use

INSTRUCTIONS FOR THE COMPLETION OF STATEMENT OF BENEFICIAL USE

IF THE PERMIT WAS APPROVED PURSUANT TO C.R.S. 37-90-137(2), THE STATEMENT OF BENEFICIAL USE MUST BE RECEIVED BY THE STATE ENGINEER PRIOR TO THE EXPIRATION OF THE PERMIT.

IF THE PERMIT WAS APPROVED PURSUANT TO C.R.S. 37-90-107, THE STATEMENT OF BENEFICIAL USE MUST BE RECEIVED WITHIN THREE YEARS FROM THE DATE THE PERMIT WAS ISSUED.

STATEMENTS OF BENEFICIAL USE ARE NOT REQUIRED FOR PERMITS ISSUED UNDER C.R.S. 37-90-105 OR 37-92-602.

NOTE: IF THE PERMIT WAS APPROVED PURSUANT TO C.R.S. 37-90-137(4), THEN YOU MUST USE FORM NO. GWS-18 "NOTICE OF WELL COMPLETION" AND FORM NO. GWS-19 "NOTICE OF COMMENCEMENT OF BENEFICIAL USE".

The Statement must be typewritten or printed in **BLACK INK**. Initial and date any changes you make on the form. **INCOMPLETE FORMS ARE NOT ACCEPTABLE AND WILL BE RETURNED. ATTACH ADDITIONAL SHEETS IF MORE SPACE IS NEEDED.**

NO FEE IS REQUIRED IF THE STATEMENT IS SUBMITTED TIMELY. IF NOT SUBMITTED TIMELY, THE PERMIT MAY EXPIRE, AN APPLICATION FOR A NEW PERMIT AND ADDITIONAL FEES MAY BE REQUIRED.

The Well Permit Number must be indicated in the space provided at the top of the form.

1. Print the **well owner's** name and include the mailing address and phone number.
2. If the well location is different than the mailing address of the owner, include the address where the well is located. If the owner has more than one well, provide well name or number as designated by the owner; i.e. North-Well. The actual well location must include 1/4, 1/4, Range, Township, Section and distances from Section lines. Mark the appropriate boxes for North or South and East or West directions.
3. Describe the use(s) to which the water has actually been applied. Permitted uses are described in the conditions of approval of the permit.
4. Enter the **date of first beneficial use UNDER THIS PERMIT**. This is the date water from the well was first used beneficially for the purposes described in item 3. The date claimed cannot predate the issuance of the permit. It is not the date the form is completed, nor is it the date the well was test pumped.
5. Enter the **pumping rate** claimed. The rate cannot exceed the permitted maximum rate or the actual pumping rate in gallons per minute reported on the pump installation and test report, whichever is less: 449 gallons per minute is equivalent to one cubic foot of water per second.
6. Enter the **annual amount of water diverted** in acre feet. The amount claimed cannot exceed the physical capacity of the well or the permitted amount as limited by any conditions of approval. One acre foot is equivalent to 325,900 gallons. An ordinary home with lawn and garden irrigation diverts an average of less than one acre foot. Average in house use which does not include lawn and garden irrigation (watering) diverts 1/3 acre foot.
7. Report the area irrigated either as acres or square feet by filling in the correct number and checking the appropriate box. You must describe the specific area irrigated using either the legal description of that land or by referencing a portion of the Subdivision, Lot, Block and Filing or Unit number. Lawn and garden watering is considered irrigation. If the well is not used for irrigation, place a zero in the acres/square feet irrigated blank. One acre is equivalent to 43,560 square feet. One acre foot is equivalent to 43,560 cubic feet of water.
8. ~~Indicate the Well Construction and Pump Installation Contractors and their License Numbers. If you did the work yourself, so indicate. You must submit work reports if you constructed the well and/or installed the pump yourself.~~
9. If a **totalizing flow meter** is required as a condition of the permit, indicate the meter manufacturer name, it's serial number and the date of installation.
10. The well owner must sign the Statement. Print or type your name in the first block if it is different from Item No. 1. If signing as a representative of a company who owns the well, then your title must also be included in the first block. Sign the second block and date the last block.

If you have questions, contact the Denver Office or the Division Office where your well is located.

DIVISION 1
800 8th Ave Rm 321
Greeley CO 80631
(303) 352-8712

DIVISION 5 Box 396
50633 US Hwy 6 & 24
Glenwood Spgs CO 81601
(303) 945-5665

DIVISION 2 Box 5728
310 E. Abriendo Ste. B
Pueblo CO 81004
(719) 542-3368


DIVISION 6 Box 773450
1120 So. Lincoln Ave Ste 101
Steamboat Spgs CO 80477
(303) 879-0272

DIVISION 3 Box 269
422 4th St
Alamosa CO 81101
(719) 589-6683

DIVISION 7 Box 1880
1474 Main St
Durango CO 81302
(303) 247-1845

DIVISION 4 Box 456
1540 E Niagara
Montrose CO 81402
(303) 249-6622

DENVER OFFICE
Rm 821
1313 Sherman St
Denver CO 80203
(303) 866-3581

FORM NO. 69-32 10/94		PUMP INSTALLATION AND TEST REPORT STATE OF COLORADO, OFFICE OF THE STATE ENGINEER		For Office Use only
1.	WELL PERMIT NUMBER <u>(98-VE-149) 5195F-R</u>	RECEIVED JUN 01 1998 <small>WATER RESOURCES STATE ENGINEER COLORADO</small>		
2.	OWNER NAME(S) <u>Raceway Associates I.T.C.</u> Mailing Address <u>3286 Fitzgerald Road</u> City, St. Zip <u>Rancho Cordova, CA 95742</u> Phone (916) <u>851-0535</u>			
<div style="text-align: right; margin-right: 50px;">Div 2</div>				
3.	WELL LOCATION AS DRILLED: SW <u>1/4</u> NW <u>1/4</u> , Sec. <u>4</u> Twp. <u>17S</u> Range <u>65</u> W DISTANCES FROM SEC. LINES: <u>2210</u> ft. from <u>north</u> Sec. line. and <u>340</u> ft. from <u>west</u> Sec. line. <small>(north or south) (east or west)</small> SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____ STREET ADDRESS AT WELL LOCATION: _____			
4.	PUMP DATA: Type <u>Turbine</u> Installation Completed <u>5-15-98</u> Pump Manufacturer <u>Worthington</u> Pump Model No. <u>12 M 90-4</u> Design GPM <u>900</u> at RPM <u>1760</u> , HP <u>75</u> , Volts <u>480</u> , Full Load Amps _____ Pump Intake Depth <u>56'</u> Feet, Drop/Column Pipe Size <u>8" X 1 1/2</u> inches, Kind <u>open column</u> ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM: TURBINE DRIVER TYPE: <input checked="" type="checkbox"/> Electric <input type="checkbox"/> Engine <input type="checkbox"/> Other _____ Design Head <u>240</u> feet, Number of Stages <u>4</u> , Shaft size <u>1 1/2</u> inches.			
5.	OTHER EQUIPMENT: Airline Installed <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No, Orifice Depth ft. _____ Monitor Tube Installed <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No, Depth ft. _____ Flow Meter Mfg. <u>McCrometer</u> Meter Serial No. <u>98-8-1148W</u> Meter Readout <input checked="" type="checkbox"/> Gallons, <input type="checkbox"/> Thousand Gallons, <input checked="" type="checkbox"/> Acre feet, <input type="checkbox"/> Beginning Reading _____			
6.	TEST DATA: <input type="checkbox"/> Check box if Test data is submitted on Supplemental Form. <div style="display: flex; justify-content: space-between;"> <div> Date _____ Total Well Depth <u>63'</u> Static Level <u>37'</u> Date Measured <u>5-15-98</u> </div> <div> Time _____ Rate (GPM) <u>900</u> Pumping Lvl. <u>57'</u> </div> </div>			
7.	DISINFECTION: Type <u>H.T.H.</u> Amt. Used <u>6 ozs.</u>			
8.	Water Quality analysis available. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
9.	Remarks _____ _____ _____ _____ _____			
10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]				
CONTRACTOR <u>Lesh Drilling, Inc.</u> Phone <u>(970) 834-2868</u> Lic. No. <u>21-B</u> Mailing Address <u>P.O. Box 56, Ault, CO 80610</u>				
Name/Title (Please type or print) <u>Edwin D. Lesh, Jr. - Pres.</u>		Signature 		Date <u>5-28-98</u>

INSTRUCTIONS FOR PUMP INSTALLATION REPORT

The report must be typed or printed in **BLACK INK**. All changes on the form must be initialed and dated. Attach additional sheets if more space is required. Each additional sheet must be identified at the top by the well owner's name, the permit number, form name/number and a sequential page number. Report depths in feet below ground surface.

This form may be reproduced by photocopy methods, or by computer generation with prior approval by the State Engineer. Photocopy reproductions must retain margins and print quality of the original form.

The original form must be submitted to the State Engineer's Office within 60 days after completing the well or 7 days after the permit expiration date, whichever is earlier.

A copy of the form must be provided to the well owner.

If this form is submitted in conjunction with the Well Completion and Test Report, form number GWS-31, **ONLY THE PERMIT NUMBER AND OWNER NAME NEED TO BE COMPLETED** in items 1 and 2.

1. Complete the Permit Number in full.
2. Fill in Name and Mailing Address of Well Owner where correspondence should be sent.
3. Complete the blocks for the actual location of the well. For wells located in subdivisions the lot, block and subdivision information must also be provided.
4. Indicate the type of pump installed and complete the requested information. When installing pumps greater than 50 gpm, complete the additional information in this area.
5. Provide the information on other equipment which may be installed in the well.
6. Report test data as required by Rule 13.9. Spaces are provided to report all measurements made during the test. The report should show that the test complied with the provisions of the rules. If a test was not performed explain when it will be done. If available, report clock time when measurements were taken.
7. Record the type and the amount of disinfection used, how placed and the length of time left in the hole.
8. Indicate if a water quality analysis was performed and submit a copy of the report if available.
9. Use the remarks area to note any additional information including additional equipment installed, water supply construction problems.
10. Fill in Company Name and Address of Contractor who installed pumping equipment. The report must be signed by the licensed contractor responsible for the installation of pumping equipment.

WELL CONSTRUCTION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

1. WELL PERMIT NUMBER <u>98-VE-149 5195-F-2</u>		<div>RECEIVED</div> <div>JUN 01 1998</div> <div>WATER RESOURCES STATE ENGINEER COLO.</div> <div>Div 2 47897-F</div>																																																																		
2. OWNER NAME(S) <u>Raceway Associates L.L.C.</u> Mailing Address <u>3286 Fitzgerald Road</u> City, St. Zip <u>Rancho Cordova, CA 95742</u> Phone (916) <u>851-0535</u>																																																																				
3. WELL LOCATION AS DRILLED: SW 1/4 NW 1/4, Sec. 4 Twp. 17S Range 65W DISTANCES FROM SEC. LINES: <u>2210</u> ft. from <u>north</u> Sec. line. and <u>340</u> ft. from <u>west</u> Sec. line. OR <small>(north or south) (east or west)</small> SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____ STREET ADDRESS AT WELL LOCATION: _____																																																																				
4. GROUND SURFACE ELEVATION _____ ft. DRILLING METHOD <u>Reverse Rotary</u> DATE COMPLETED <u>5-7-98</u> TOTAL DEPTH <u>63</u> ft. DEPTH COMPLETED <u>63</u> ft.																																																																				
<div>5. GEOLOGIC LOG:<table border="1" style="width:100%"><thead><tr><th>Depth</th><th>Description of Material (Type, Size, Color, Water Location)</th></tr></thead><tbody><tr><td>0 - 2</td><td>Topsoil</td></tr><tr><td>2 - 5</td><td>Brown colored sandy clay</td></tr><tr><td>5 - 8</td><td>Small sized gravel</td></tr><tr><td>8 - 28</td><td>Brown colored clay</td></tr><tr><td>28 - 43</td><td>Medium sized, loose gravel with water loss</td></tr><tr><td>43 - 46</td><td>Buff colored clay</td></tr><tr><td>46 - 58</td><td>Medium to coarse gravel with some cemented streaks & bad water loss</td></tr><tr><td>58 - 63</td><td>Weathered shale</td></tr></tbody></table></div> <div>6. HOLE DIAM. (in.)<table border="1" style="width:100%"><thead><tr><th>From (ft)</th><th>To (ft)</th></tr></thead><tbody><tr><td><u>32</u></td><td><u>0</u></td></tr><tr><td>_____</td><td>_____</td></tr><tr><td>_____</td><td>_____</td></tr></tbody></table></div> <div>7. PLAIN CASING<table border="1" style="width:100%"><thead><tr><th>OD (in)</th><th>Kind</th><th>Wall Size</th><th>From (ft)</th><th>To (ft)</th></tr></thead><tbody><tr><td><u>16"</u></td><td><u>steel</u></td><td><u>.250</u></td><td><u>1' above</u></td><td><u>38</u></td></tr><tr><td><u>16"</u></td><td><u>steel</u></td><td><u>.250</u></td><td><u>58</u></td><td><u>63</u></td></tr><tr><td>_____</td><td>_____</td><td>_____</td><td>_____</td><td>_____</td></tr></tbody></table>PERF. CASING: Screen Slot Size: <u>10</u> <u>16"</u> <u>stainless</u> <u>.250</u> <u>38</u> <u>58</u> <u>steel</u> _____</div> <div>8. FILTER PACK: Material <u>silica sand</u> Size <u>4 - 8</u> Interval <u>10' - 63'</u></div> <div>9. PACKER PLACEMENT: Type _____ Depth _____</div> <div>10. GROUTING RECORD:<table border="1" style="width:100%"><thead><tr><th>Material</th><th>Amount</th><th>Density</th><th>Interval</th><th>Placement</th></tr></thead><tbody><tr><td><u>cement</u></td><td><u>3 cu yds</u></td><td><u>6 gal</u></td><td><u>0-10</u></td><td><u>poured</u></td></tr><tr><td>_____</td><td>_____</td><td>_____</td><td>_____</td><td>_____</td></tr><tr><td>_____</td><td>_____</td><td>_____</td><td>_____</td><td>_____</td></tr></tbody></table></div> <div>REMARKS: _____ _____ _____</div>			Depth	Description of Material (Type, Size, Color, Water Location)	0 - 2	Topsoil	2 - 5	Brown colored sandy clay	5 - 8	Small sized gravel	8 - 28	Brown colored clay	28 - 43	Medium sized, loose gravel with water loss	43 - 46	Buff colored clay	46 - 58	Medium to coarse gravel with some cemented streaks & bad water loss	58 - 63	Weathered shale	From (ft)	To (ft)	<u>32</u>	<u>0</u>	_____	_____	_____	_____	OD (in)	Kind	Wall Size	From (ft)	To (ft)	<u>16"</u>	<u>steel</u>	<u>.250</u>	<u>1' above</u>	<u>38</u>	<u>16"</u>	<u>steel</u>	<u>.250</u>	<u>58</u>	<u>63</u>	_____	_____	_____	_____	_____	Material	Amount	Density	Interval	Placement	<u>cement</u>	<u>3 cu yds</u>	<u>6 gal</u>	<u>0-10</u>	<u>poured</u>	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Depth	Description of Material (Type, Size, Color, Water Location)																																																																			
0 - 2	Topsoil																																																																			
2 - 5	Brown colored sandy clay																																																																			
5 - 8	Small sized gravel																																																																			
8 - 28	Brown colored clay																																																																			
28 - 43	Medium sized, loose gravel with water loss																																																																			
43 - 46	Buff colored clay																																																																			
46 - 58	Medium to coarse gravel with some cemented streaks & bad water loss																																																																			
58 - 63	Weathered shale																																																																			
From (ft)	To (ft)																																																																			
<u>32</u>	<u>0</u>																																																																			
_____	_____																																																																			
_____	_____																																																																			
OD (in)	Kind	Wall Size	From (ft)	To (ft)																																																																
<u>16"</u>	<u>steel</u>	<u>.250</u>	<u>1' above</u>	<u>38</u>																																																																
<u>16"</u>	<u>steel</u>	<u>.250</u>	<u>58</u>	<u>63</u>																																																																
_____	_____	_____	_____	_____																																																																
Material	Amount	Density	Interval	Placement																																																																
<u>cement</u>	<u>3 cu yds</u>	<u>6 gal</u>	<u>0-10</u>	<u>poured</u>																																																																
_____	_____	_____	_____	_____																																																																
_____	_____	_____	_____	_____																																																																
11. DISINFECTION: Type <u>H.T.H.</u> Amt. Used <u>6 ozs.</u>																																																																				
12. WELL TEST DATA: <input checked="" type="checkbox"/> Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test. TESTING METHOD _____ Static Level _____ ft. Date/Time measured _____ Production Rate _____ gpm. Pumping level _____ ft. Date/Time measured _____ Test length (hrs.) _____ Remarks _____																																																																				
13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13) (a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.] CONTRACTOR <u>Lesh Drilling, Inc.</u> Phone <u>(970) 834-2868</u> Lic. No. <u>21-B</u> Mailing Address <u>P.O. Box 56 Ault, CO 880610-0056</u> Name/Title (Please type or print) <u>Edwin D. Lesh, Jr. - Pres.</u> Signature _____ Date <u>5-28-98</u>																																																																				

The report must be typed or printed in **BLACK INK**. All changes on the form must be initialed and dated. Attach additional sheets if more space is required. Each additional sheet must be identified at the top by the well owner's name, the permit number, form name/number and a sequential page number. Report depths in feet below ground surface.

This form may be reproduced by photocopy methods, or by computer generation with prior approval by the State Engineer. Photocopy reproductions must retain margins and print quality of the original form.

The original form must be submitted to the State Engineer's Office within 60 days after completing the well or 7 days after the permit expiration date, whichever is earlier.

A copy of the form must be provided to the well owner.

1. Complete the **Well Permit Number** in full.
2. Fill in **Name and Mailing Address of Well Owner** where correspondence should be sent.
3. Complete the blocks for the **actual** location of the well where drilled. If the owner has more than one well serving this property, provide the identification (**Owner's Designation**) for this well. **DO NOT USE THE OWNER SUPPLIED LOCATION** unless a survey has been provided. For wells located in subdivisions the lot, block and subdivision information must also be provided.
4. Report the ground surface elevation in feet above sea level if available. This value may be obtained from a topographic map. Describe the drilling method used to construct the well and the date completed. Indicate the total depth drilled and the actual completed depth of the well.
5. Fully describe the materials encountered in drilling. Do not use formation names unless they are in conjunction with a description of materials.
Examples of descriptive terms include:
Grain size—Boulders, gravel, sand, silt, clay.
Hardness—Loose, soft, tight, hard, very hard.
Color—All materials. Most critical in sedimentary rock.
Depth when water is encountered (if it can be determined).
6. Provide the diameters of the drilled bore hole.
7. The outside diameter, kind, wall thickness and interval of casing lengths must be indicated.
8. Indicate the type and size of filter (gravel) pack and the interval where placed.
9. Indicate the type and setting depth for any packers installed.
10. The density of the grout slurry must be reported and may be indicated as pounds per gallon, gallons of water per sack, total gallons of water and number of sacks used, etc. Specify the grout placement method, i.e. tremie pipe or positive displacement. The percentage of additives mixed with the grout should be reported under remarks.
11. Record the type and the amount of disinfection used, how placed and the length of time left in the hole.
12. Report well test data as required by Rule 10.7. Spaces are provided to report all measurements made during the test. The report should show that the test complied with the provisions of the rules. If a test was not performed explain when it will be done. If available, report clock time when measurements were taken.
13. Fill in **Company Name and Address of Contractor** who constructed the well. The report must be signed by the licensed contractor responsible for the construction of the well.

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

21

APPLICANT

CITY OF FOUNTAIN,
116 S MAIN ST
FOUNTAIN CO 80817-

(719)382-7591

WELL PERMIT NUMBER

5195

F R

DIV. 2

CNTY. 21

WD 10

DES. BASIN

MD

Lot: Block: Filing: Subdiv:

APPROVED WELL LOCATION

EL PASO COUNTY

SW 1/4

NW 1/4

Section 4

Twp 17 S

RANGE 65 W

6th P.M.

DISTANCES FROM SECTION LINES

2210 Ft. from

North

Section Line

340 Ft. from

West

Section Line

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(2) for the replacement of an existing well, permit no. 5195-F (decreed by the Division 2 Water Court as well no. 7, case no. W-1528). The old well must be plugged according to the Water Well Construction Rules. A Well Abandonment Report must be submitted within sixty (60) days after construction of the new well, affirming that the old well was plugged.
- 4) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.
- 5) Approval of this replacement permit shall not result in an expanded use of ground water. The use of ground water from this well is limited to municipal, industrial, irrigation, and domestic.
- 6) The maximum pumping rate shall not exceed 1,073 GPM.
- 7) The average annual amount of ground water to be appropriated shall not exceed 100 acre-feet.
- 8) A metering method must be established for this well pursuant to the Amended Rules Governing the Measurement of Tributary Ground Water Diversions Located in the Arkansas River Basin.
- 9) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 10) This well shall be constructed at least 600 feet from any existing well completed in the same aquifer that is not owned by the applicant.
- 11) This well shall be constructed not more than 200 feet from the location decreed for well no. 7 in case no. W-1528.
- 12) Verbal approval, 98-VE-149, was given for construction of this well on April 24, 1998. Cross referenced to monitoring hole acknowledgment MH- 33190.

APPROVED
KVH

State Engineer

Receipt No. 0429609

DATE ISSUED

SEP 21 1998

By

EXPIRATION DATE

SEP 21 1999

Greg Poway of W.W. Whorley
called 11-19-98.
old well has not been plugged yet
because of conflict over who
owns it. Racoon Assoc. /
Fountain / CSDA Springs.
will ~~submit~~ written request
for extension.

FORM NO.
GWS-9
7/89

STATE OF COLORADO
OFFICE OF THE STATE ENGINEER
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

For Office Use only

RECEIVED

APR 12 1999

WATER RESOURCES
STATE ENGINEER
COLORADO

TYPE OR PRINT IN BLACK INK

WELL ABANDONMENT REPORT

ABANDONED WELL NUMBER IF REGISTERED 5195-F.R.

1. INDIVIDUAL/COMPANY RESPONSIBLE FOR PLUGGING

NAME(S) Lesh Drilling, Inc.
Mailing Address P.O. Box 56
City, St. Zip Ault, CO 80610
Phone (970) 834-2868

2. ACTUAL WELL LOCATION: COUNTY E1 Paso

PROPERTY ADDRESS 16650 Midway Ranch Rd. P.O. Box 430 Fountain, CO 80817-
(Address) Pike's Peak Int'l Raceway (City) Fountain (State) CO (Zip) 80817

SW 1/4 NW 1/4, Sec. 4 Twp. 17 ☐ N. ☒ S., Range 65 ☐ E. ☒ W. 6th P.M.

Distances from Section Lines 2210 Ft. from ☒ N. ☐ S. Line, 340 Ft. from ☐ E. or ☒ W. Line.

3. I (we), report that an existing well was plugged and abandoned for the following reason(s):

- ☒ The well was plugged and abandoned as required under the conditions of approval of Well Permit No. Emergency verbal 98-VE-149, well permit #5195-F.R.
- ☐ The well was not in use and was abandoned.
- ☐ Other (please explain) _____

4. The well was plugged and abandoned according to the Water Well Construction and Pump Installation Rules on March, 1999.

5. The well was plugged with the following materials placed at the indicated intervals:

AMOUNT AND TYPE OF MATERIAL	METHOD OF PLACEMENT	INTERVAL
<u>Topsoil</u>	<u>Dumped</u>	from <u>0</u> feet to <u>6</u> feet
<u>Cement</u>	<u>Poured</u>	from <u>6</u> feet to <u>10</u> feet
<u>Clean washed gravel</u>	<u>Poured</u>	from <u>10</u> feet to <u>54</u> feet
		from _____ feet to _____ feet
INTERVALS OF CASING REMOVED/RIPPED IN FEET		from _____ feet to _____ feet
		from _____ feet to _____ feet

6. I (we) have read the statements made herein and know the contents thereof, and that they are true to my (our) knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

Name/Title (Please type or print)

Edwin D. Lesh, Jr.-Pres. Lic21

Signature

Date

4-9-99

-INFORMATION- It is the responsibility of the well owner to have the well properly plugged and abandoned. The well construction contractor is responsible for notifying the well owner of the plugging and abandonment requirement. This form may be reproduced by photocopy or word processing means.

August, 1988

RULE 11 ABANDONMENT STANDARDS

11.1 General

11.1.1 The plugging and sealing of all wells and test holes is necessary to prevent contamination of ground water and the migration of water through the unused borehole. It is the ultimate responsibility of the well owner to have a well properly plugged and abandoned. The well construction contractor is responsible for notifying the well owner of the plugging and abandonment requirement pursuant to this Rule 11.

11.1.2 Persons authorized to install pumping equipment may plug and abandon wells which do not require the removal of casing from more than one aquifer or the ripping or perforating of casing opposite confining layers.

11.1.3 All materials used for backfilling shall be clean, free from contaminants and chemically inert.

11.2 Unconfined Wells - Wells completed into unconfined aquifers shall be abandoned by filling with either on-site materials, clean sand or gravel to the static water level, then with chemically inert materials to the ground surface. A permanent watertight cover shall be installed at the top of the casing. The casing may be cut off up to five (5) feet below ground level provided the watertight cover is welded or permanently attached to the top of the casing and the hole is backfilled to the land surface.

11.2.1 Cathodic protection holes, dewatering wells, horizontal drains, monitoring and observation holes, percolation holes, piezometer holes, sump pumps and test holes shall be abandoned either pursuant to Rule 11.2 or by removing all casing which was installed and by filling the hole(s) with drill cuttings or chemically inert materials to within five (5) feet of the ground surface. The top five (5) feet of the hole shall be sealed with materials equal to or less permeable than the top foot of the surrounding soils.

11.3 Confined Wells

11.3.1 Wells which were constructed through more than one aquifer shall be abandoned by placing a grout plug at the confining layer above each aquifer. If records do not show that the casing opposite each confining layer has been grouted when originally installed, the casing shall be either completely removed from the hole, or perforated or ripped opposite such layer prior to placing the grout plug. No plug shall be less than twenty (20) feet in length.

11.3.2 The well casing except for the grout plug intervals shall be completely filled to the land surface with chemically inert materials. A watertight cover will be permanently welded or attached to the top of the casing. The casing may be cut off up to five (5) feet below land surface provided the watertight cover is welded or permanently attached to the top of the casing and the hole is backfilled to the land surface.

STATE OF COLORADO

OFFICE OF THE STATE ENGINEER

Division of Water Resources
Department of Natural Resources

1313 Sherman Street, Room 818
Denver, Colorado 80203
Phone (303) 866-3581
FAX (303) 866-3589



December 9, 1998

Roy Romer
Governor

James S. Lochhead
Executive Director

Hal D. Simpson
State Engineer

Gregory L. Dewey
W.W. Wheeler and Associates, Inc.
3700 South Inca Street
Englewood, CO 80110

RE: Well Permit nos. 5195-F-R & 47897-F
City of Fountain, Pike Peak International Raceway Wells

Dear Mr. Dewey:

The above 2 well permits were issued as replacements of 2 existing wells, which result in a need for the original wells to be plugged. Your letter of December 1, 1998 requests an extension to the requirement that the old wells be plugged within 60 days of constructing the new wells. This request is due to the complex nature of the agreements between the City of Fountain, the City of Colorado Springs, and Raceway Associates LLC, resulting in an uncertainty as to who has responsibility for the old wells. Your letter does state that Fountain will ensure the wells will be plugged.

An extension of the time in which the wells are to be plugged is hereby granted. Well Abandonment Reports documenting that the old wells were plugged must be submitted along with, or no later than, the submittal of the statements of beneficial use for each well. If you have further questions give me a call.

Sincerely,

Keith Vander Horst
Water Resources Engineer

cc: Division 2

W. W. Wheeler and Associates, Inc.
Water Resources Engineers

3700 South Inca Street, Englewood, CO 80110
Phone (303) 761-4130 FAX (303) 761-2802

RECEIVED

TRANSMITTAL LETTER

DEC 11 1998

WATER RESOURCES
STATE ENGINEER
COLORADO

December 8, 1998

RE: #603.2 - Pikes Peak International Raceway, Well No. 7
TO: Division of Water Resources
1313 Sherman Street, Room 818
Denver, CO 80203
FROM: Greg Dewey
MESSAGE: Enclosed is a copy of the Statement of Beneficial Use for Well No. 7 (Permit
5195-F-R). Please call if you have any questions.



116 S. Main St.
Fountain
Colorado
80817
719/382-8521
FAX: 719/382-5194

RECEIVED

MAR 03 1999

WATER RESOURCES
STATE ENGINEER
COLO

March 1, 1999

Office of the State Engineer
Division of Water Resources
Department of Natural Resources
1313 Sherman Street, Room 818
Denver, CO 80203

Attn: Sandy Johnson

RE: Well Permit No. 5195FR

Dear Sandy,

I am returning the corrected "Statement of Beneficial Use" for Well Permit No. 5195FR.

The statement now correctly claims the pumping rate at 900 G.P.M.

Please call me at (719)382-4158 if you have any concerns on this matter.

Sincerely,

Ron Woolsey
Superintendent, Water Department

Enclosure

RW/cs

STATE OF COLORADO

OFFICE OF THE STATE ENGINEER

Division of Water Resources
Department of Natural Resources

1313 Sherman Street, Room 818
Denver, Colorado 80203
Phone: (303) 866-3581
FAX: (303) 866-3589

May 17, 2000



Bill Owens
Governor

Greg E. Walcher
Executive Director

Hal D. Simpson, P.E.
State Engineer

<http://water.state.co.us/default.htm>

Gary B. Thompson
W. W. Wheeler & Associates
3700 S. Inca Street
Englewood, CO 80110

RE: Fountain Racetrack Wells Substitute Water Supply Plan
NW ¼, Sec. 4, T17S, R65W, 6th P.M.
Water Division 2, Water District 10

Dear Gary B. Thompson:

We received your letter of February 19, 1999 requesting renewal of the Substitute Water Supply Plan for the Fountain Racetrack Wells for the plan year April 1, 1999 through March 31, 2000 and your verbal request of May 17, 2000 to extend the plan through to March 31, 2001. The wells in this plan are permit nos. 5195-FR (a redrill of 5195-F) and 47897-F (a redrill of 6921-F). These are also designated as ID nos. 1005620 and 1005624, respectively. These wells divert water from the alluvial aquifer of Fountain Creek, and are used for the operation of the Pikes Peak International Raceway. As such, they are subject to the Amended Rules and Regulations Governing the Diversion and Use of Tributary Ground Water in the Arkansas Basin, Colorado ("Rules").

Total out-of-priority pumping by the active wells in this plan is proposed not to exceed 100 acre-feet for the plan year. However, plan year pumping is estimated to be 36.3 acre-feet based on last year's pumping. Based on this estimate and actual pumping from the previous plan, and a wellhead depletion factor of 100%, the estimated out-of-priority stream depletions to be replaced during the plan year is 31.4 acre-feet.

The city of Fountain proposes to replace this water with excess augmentation credits available from its plan for augmentation decreed in case numbers W-4396 and 85CW110. It is estimated that 33 acre-feet of stream depletions will occur past the March 31, 2001 expiration date of this plan due to diversion of ground water during the life of this and previous plans. Replacement of these depletions, to the extent they cause out-of-priority depletions, may be accomplished by priority commitment of augmentation credits available from the aforementioned Water Court cases.

The State and Division Engineers have reviewed the plan and the adequacy of each source of water provided for use as augmentation water, including where necessary, the historical consumptive use of each water right, and return flows from diversion of water into the Arkansas River Basin or other fully consumable waters proposed for use as augmentation water. In accordance with Section 25-8-207(7), C.R.S. and Senate Bill 89-181 Rules and Regulations adopted on February 4, 1992, the State Engineer has determined that the replacement supply is of a quality to meet the requirements of use to senior appropriators.

Based on stream depletions determined in accordance with the Amended 1996 Well Use Rules decreed in case no. 95CW211, and consistent with other provisions of the Rules, the State and Division Engineers have determined that, subject to the terms and conditions set forth below, it appears the plan to divert tributary ground water will provide sufficient augmentation water in amount, time, and location to replace out-of-priority depletions to senior surface water rights in Colorado, to the extent required by Rule 11, and all depletions to usable Stateline flow caused by such diversions and may therefore be approved pursuant to Rule 7.


This substitute water supply plan is hereby approved pursuant to Section 37-80-120, C.R.S., subject to the following conditions:

1. The Fountain Racetrack Wells shall not divert more than 100 acre-feet of ground water without first obtaining an amendment to the plan.
2. This plan is only for the two wells listed above, and amendment of this plan would be required prior to inclusion of any other wells.
3. An application for a plan for augmentation must be filed with the Division 2 Water Court within one (1) year. Renewal of this plan may depend on progress made toward a permanent plan. Approval of this plan does not imply approval by this office of any related litigation.
4. The City of Fountain agrees to replace out-of-priority depletions occurring after the expiration date of the plan (March 31, 2001) which are caused by diversions of ground water during the life of the plan. A commitment to use available future augmentation credits pursuant to Water Court cases W-4396 and 85CW110 shall be assumed unless a letter to the contrary is received within two weeks as discussed under item 10 below.
5. The City of Fountain Wells will provide an accounting of this plan to the Division Engineer's office, and the District 10 Water Commissioner, as has been requested. Accounting must include all information requested, including, but not limited to pumping by the wells and deliveries of replacement water. The Division Engineer reserves the right to modify reporting requirements on an as needed basis.
6. The City of Fountain must notify the State and Division Engineers if its wells in this plan are not in compliance with the terms of this plan.
7. In accordance with amendments to Section 25-8-202(7), C.R.S. and "Senate Bill 89-181 Rules and Regulations" adopted on February 4, 1992, the State Engineer shall continue to determine whether or not the replacement supply is of a quality to meet the requirements of senior appropriators. As such, water quality data or analysis may be requested at any time to determine if the water quality is appropriate for downstream water users.
8. This approval is of a temporary nature where as the uses of the wells in the plan are of an indefinite nature that will require a court decreed plan for augmentation. Any request for renewal of this plan must include a description of progress made toward obtaining a permanent source of replacement water, and a target date for filing an application for a permanent plan with the water court.

9. Should a request for renewal of this plan be needed, such renewal must be submitted to this office at least 45 days prior to the expiration date of this plan, or February 15, 2001.
10. Acceptance of these conditions is assumed unless a letter to the contrary is received in the offices of the Division Engineer (310 E. Abriendo, Suite B, Pueblo, CO 81003) and the Water Commissioner (Eddie Taylor, 2126 North Weber Street, Colorado Springs, CO 80907) within two weeks of receipt of this letter.

Should you have any questions, please contact Heidi Frey of this office or Dennis Bagenstos, Augmentation Coordinator, in our Division 2 office in Pueblo at (719) 542-3368.

Sincerely,



Ken Knox
Assistant State Engineer

Cc: Steve Witte, Division Engineer
Eddie Taylor, Water Commissioner
David W. Robbins, Hill & Robbins
John B. Draper, Montgomery & Andrews
Dale E. Book, Spronk Water Engineers