



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Colorado Springs Police Department Weapon Range, PPR-19-43

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The wastewater service proposed is a sealed holding vault requiring pumping when the vault is approaching capacity. Prior to considering a holding vault for approval, El Paso County Public Health will need the following information and answers:
 - The Onsite Wastewater Treatment System (OWTS) Regulations, Chapter 8 of the El Paso County Board of Health Regulations, require an approved OWTS with a soil treatment area to be installed when there is sufficient installation area. See 8.12.C.1-10., of the above referenced regulations.
 - Please justify the selection of a holding vault for this project based on the regulation section noted.
- Water service is proposed to be piped in from an existing service.
 - What service is the proposed water line connected to?
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
15Dec2019