



ENG-CDR21010-R3-CDs-Vollmer-North.pdf Markup Summary

1 (3)




Subject: Callout
Page Index: 1
Date: 4/4/2022 3:39:19 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 1

Match slopes should be at edge of grading



Subject: Callout
Page Index: 1
Date: 4/4/2022 4:35:24 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 1

Does not match plan sheet. Plan shows 13' lane. please coordinate between section & plan.



Subject: Callout
Page Index: 1
Date: 4/8/2022 3:49:32 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 1

(there should be some shelf space here behind the curb)


2 (1)



Subject: Text Box
Page Index: 2
Date: 3/29/2022 2:23:37 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 2


Unresolved:
Include detail for sawcut and mill/overlay

3 (2)




Subject: Callout
Page Index: 3
Date: 4/4/2022 4:06:15 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 3

Label this line




Subject: Callout
Page Index: 3
Date: 4/4/2022 4:07:01 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 3

Turn of striping. Show on signing & striping plan




Subject: Callout
Page Index: 4
Date: 4/4/2022 4:09:13 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 4

Label line




Subject: Callout
Page Index: 4
Date: 4/4/2022 4:09:45 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 4

Label lines



Subject: Callout
Page Index: 4
Date: 4/4/2022 4:11:51 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 4

Turn off striping. Show on signing & striping plan



Subject: Callout
Page Index: 4
Date: 4/7/2022 8:14:03 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 4

Label cl-cl intersection




Subject: Callout
Page Index: 4
Date: 4/7/2022 8:16:10 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 4

Callouts not needed since continuous plan set now




Subject: Callout
Page Index: 5
Date: 4/4/2022 4:14:32 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 5

Turn off striping. Show on signing & striping plan




Subject: Callout
Page Index: 5
Date: 4/4/2022 4:15:39 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 5

Label these lines



Subject: Callout
Page Index: 5
Date: 4/4/2022 4:16:13 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 5


Label match point



Subject: Callout
Page Index: 5
Date: 4/7/2022 8:17:06 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 5


existing ROW

6 (17)




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:25:15 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Label line




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:25:52 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Property line




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:26:07 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Property line




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:28:10 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Label existing easement



Subject: Callout
Page Index: 6
Date: 4/4/2022 4:28:54 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Label match point for sidewalk




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:29:25 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

proposed sidewalk



Subject: Callout
Page Index: 6
Date: 4/4/2022 4:31:28 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Turn off existing slopes




Subject: Callout
Page Index: 6
Date: 4/4/2022 4:31:46 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Remove label




Subject: Text Box
Page Index: 6
Date: 4/7/2022 8:19:16 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Match Line



Subject: Callout
Page Index: 6
Date: 4/7/2022 8:19:34 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

CL-CL intersection
label




Subject: Callout
Page Index: 6
Date: 4/7/2022 8:20:11 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Extend profile to 57+00




Subject: Text Box
Page Index: 6
Date: 4/7/2022 8:20:19 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6



Subject: Text Box
Page Index: 6
Date: 4/7/2022 8:25:03 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Add coordinates




Subject: Callout
Page Index: 6
Date: 4/7/2022 8:25:55 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Existing or proposed culvert? Please label

Label pcr's
on all curb
returns


Subject: Text Box
Page Index: 6
Date: 4/7/2022 8:26:45 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 6

Label pcr's on all curb returns



Subject: Callout
Page Index: 6
Date: 4/11/2022 12:06:22 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 6

Full-depth asphalt is not allowed



Subject: Text Box
Page Index: 6
Date: 4/11/2022 12:09:45 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 6


or extend the profile on sheet 5 to the north

7 (9)



Subject: Text Box
Page Index: 7
Date: 4/7/2022 8:27:18 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Homestead North Construction Plans by JR Engineering



Subject: Callout
Page Index: 7
Date: 4/7/2022 8:27:54 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Label drainage easement



Subject: Callout
Page Index: 7
Date: 4/7/2022 8:28:13 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Proposed MH




Subject: Callout
Page Index: 7
Date: 4/7/2022 8:28:21 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Proposed MH




Subject: Callout
Page Index: 7
Date: 4/7/2022 8:28:38 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Proposed on-grade inlet



Subject: Callout
Page Index: 7
Date: 4/7/2022 8:28:57 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Proposed on-grade inlet




Subject: Callout
Page Index: 7
Date: 4/7/2022 8:29:25 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7

Label CL-CL intersection



Subject: Text Box
Page Index: 7
Date: 4/7/2022 8:30:37 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7


L9



Subject: Callout
Page Index: 7
Date: 4/7/2022 8:31:19 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7


Min K value is 96 for Arterial Road w/45 mph posted speed

8 (7)



Subject: Text Box
Page Index: 8
Date: 4/7/2022 8:31:56 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8

Match ex sidewalk



Subject: Callout
Page Index: 8
Date: 4/7/2022 8:32:24 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8

Show & label driveway culvert



Subject: Text Box
Page Index: 8
Date: 4/7/2022 8:33:17 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8

existing




Subject: Callout
Page Index: 8
Date: 4/7/2022 8:33:57 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8

Indicate if this road is existing, future, etc.
Reference plan set if it's proposed or future




Subject: Callout
Page Index: 8
Date: 4/7/2022 8:34:26 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8

Show all utilities



Subject: Callout
Page Index: 8
Date: 4/11/2022 12:12:53 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 8

Label existing or future sidewalk



Subject: Length Measurement
Page Index: 8
Date: 4/11/2022 12:14:32 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 8

40'-0"



Subject: Callout
Page Index: 9
Date: 4/4/2022 4:36:21 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9

Section shows a 12' lane. Coordinate between section and plan and revise accordingly.



Subject: Callout
Page Index: 9
Date: 4/4/2022 5:01:55 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9

This sign does not show as being installed on any other plan sets and is not shown on Google as existing. Please coordinate that this is an existing sign or if it needs to be installed with this plan set.



Subject: Callout
Page Index: 11
Date: 4/4/2022 5:05:30 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 11

Label all proposed turn arrows




Subject: Callout
Page Index: 11
Date: 4/7/2022 8:35:49 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 11

Missing sign label




Subject: Callout
Page Index: 11
Date: 4/7/2022 8:36:32 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 11

Add chevron signs around curve. Check MUTCD for guidance in placement



Subject: Callout
Page Index: 11
Date: 4/7/2022 8:37:09 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 11


45 mph sign



Subject: Callout
Page Index: 11
Date: 4/7/2022 8:38:38 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 11


Check for posted speed prior to new construction. If 55 mph, will need to have 45 mph sign at beginning of new construction (see next sheet) then 35 mph sign here

12 (2)



Subject: Callout
Page Index: 12
Date: 4/7/2022 8:39:38 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 12


Per comment on previous sheet, if posted speed prior to Poco is 55 mph, then will need to be a 45 mph sign.



Subject: Callout
Page Index: 12
Date: 4/7/2022 8:40:32 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 12


When is NB right turn lane being added? Retreat at Timber Ridge Filing 2 calls for it.

14 (2)



Subject: Callout
Page Index: 14
Date: 4/11/2022 12:25:41 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 14

bench?



Subject: Callout
Page Index: 14
Date: 4/11/2022 12:26:34 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 14

show tie-ins