


ENG-CDR21010-R5-CDs-Vollmer North.pdf Markup Summary


5 (1)



Subject: Callout
Page Index: 5
Date: 9/23/2022 12:12:58 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 5

Provide owner and reception number

7 (1)



Subject: Callout
Page Index: 7
Date: 9/16/2022 11:25:32 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 7


Min K value is 96 for Arterial Road w/45 mph posted speed

8 (2)



Subject: Text Box
Page Index: 8
Date: 9/16/2022 11:26:31 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8


existing



Subject: Callout
Page Index: 8
Date: 9/16/2022 11:28:14 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 8


Missing bearing label from previous plan set

9 (4)




Subject: Callout
Page Index: 9
Date: 9/16/2022 11:29:21 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9

Show outlet protection




Subject: Callout
Page Index: 9
Date: 9/16/2022 11:29:52 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9

Label outlet protection & give dimensions or provide detail



Subject: Callout
Page Index: 9
Date: 9/16/2022 11:30:45 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9


Show pipes



Subject: Callout
Page Index: 9
Date: 9/16/2022 11:32:12 AM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: 9

Include HGL's in pipes and WS elev in sand filter at outlet


10 (1)




Subject: Callout
Page Index: 10
Date: 9/23/2022 12:16:52 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 10

label or remove these lines

11 (2)



Subject:
Page Index: 11
Date: 9/23/2022 12:18:02 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 11



Subject: Callout
Page Index: 11
Date: 9/23/2022 12:18:22 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 11

turn off?

