

COLORADO

Division of Water Resources

Department of Natural Resources

WELL PERMIT NUMBER 88939-F

RECEIPT NUMBER 10033519

P.M.

ORIGINAL PERMIT APPLICANT(S)

6225 VESSEY LLC

APPROVED WELL LOCATION

Water Division: 1	Water District:	8	
Designated Basin:	N/A		
Management District:	N/A		
County:	EL PASO		
Parcel Name:	IVILO HEIGHT	S	
Lot: 1		Block:	Filing:
Physical Address:	6225 VESSEY SPRINGS, CO	ROAD COLOF 80908	RADO
SE 1/4 NW 1/4 Section 6 Township 12.0 S Range 65.0 W Sixth			
UTM COORDINATES (Meters, Zone:13, NAD83)			

524968.0 Easting: Northing: 4321035.0

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a 2) variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- Approved pursuant to CRS 37-90-137(4) on the condition that this well is operated in accordance with the augmentation plan 3) approved by the Division 1 Water Court in Case No. 22CW3087. If the well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
- Approved for the change in use of an existing well constructed under permit no. 87817. The issuance of this permit hereby 4) cancels permit no. 87817.
- 5) The use of groundwater from this well is limited to one (1) single family dwelling, 5,500 square feet of lawn and garden irrigation, and the watering of eight (8) horses or equivalent livestock.
- Production from this well is limited to the Dawson aguifer. 6)
- 7) The pumping rate of this well shall not exceed 15 GPM.
- The average annual amount of groundwater to be withdrawn shall not exceed 0.66 acre-feet and the total volume of 8) groundwater to be withdrawn shall not exceed 198 acre-feet.
- 9) The entire length of the hole shall be geophysically logged as required by Rule 9 of the Statewide Nontributary Ground Water Rules prior to installing casing.
- 10) The owner shall mark the well in a conspicuous location with well permit number(s), name of the aguifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 11) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- This well shall be located not more than 200 feet from the location specified on this permit. 12)
- The return flow from the use of this well must be through an individual wastewater disposal system of the non-evaporative type 13) where the water is returned to the same stream system in which the well is located.
- This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and 14) regulations.

WELL PERMIT NUMBER 88939-F

RECEIPT NUMBER 10033519

NOTE: This well is withdrawing water from a non-renewable aquifer. While the withdrawals from this aquifer are administered based on a 100 year aquifer life, water level declines may prevent this well from diverting the permitted amounts for that 100 years.

NOTE: To ensure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

Debbie Gronzalo

Date Issued: 2/28/2024

Issued By DEBRA GONZALES

Expiration Date: N/A