

ENG-PUDSP21002-R1-CDs-Storm.pdf Markup Summary


3 (1)



Subject: Callout
Page Index: 3
Date: 3/11/2021 4:27:28 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 3

verify if this is renamed


5 (1)



Subject: Callout
Page Index: 5
Date: 3/11/2021 4:28:24 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 5

See TIS and PUDSP comments.


6 (1)



Subject: Cloud+
Page Index: 6
Date: 3/11/2021 4:31:30 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 6

Only limited striping is needed, if any. Maybe just double-yellow. See TIS.


8 (1)



Subject: Callout
Page Index: 8
Date: 3/11/2021 4:49:48 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 8

See comment letter regarding adding a pedestrian crossing (ramps)

13 (1)



Subject: Callout
Page Index: 13
Date: 3/11/2021 4:41:13 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 13

Move the forebay as far from the pond outlet as possible

