



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	TC&C, LLC
Project:	Rollin Ridge
Entech Job #	210369

CONCRETE TEST

CM			Test #:	3		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:	
7/21/2021	4	4000	1:45 PM	24	7/22/2021	
Specimen Type		Test Type		Type of Cure		
Cylinders 4x8		Field		Lab		
Contractor:		Supplier:		Mix Design Number		
PPC Construction		Pete Lien		90DJ50		
Truck Number		Ticket Number		Batch Time:		
995		712116		1:08 PM		

Location:
 Curb & Gutter; Median; South side of the intersection of Hodgen Road & Cherry Crossing Drive.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.5	6.2	142.2	83	

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3380				
Average:	Average:	Average:	Average:	Average:
3380				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
7/28/2021	8/18/2021		7/30/2021	

Remarks:
 7 Day Results

Specifications: 4000 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
-----------------------------------------------------	------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *[Signature]*