



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	TC&C, LLC
Project:	Rollin Ridge
Entech Job #	210369

CONCRETE TEST

JC			Test #:			2		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:			
6/4/2021	4	4500	2:45 PM	24	6/5/2021			

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Lab

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
305	987730	1:24 PM

Location:
 Outlet box at the pond structure, 25' South & 250' West off of the Southwest corner of Hodgen Road & Highway 83.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.5	6	140.7	64	76

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3320	3830		4550	
			4660	
Average:	Average:	Average:	Average:	Average:
3320	3830		4605	
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/11/2021	7/2/2021		7/30/2021	

Remarks:
 56 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 1@28, 2@56
---	------------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *RLJ*

