



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	TC&C, LLC
Project:	Rollin Ridge
Entech Job #	210369

CONCRETE TEST

JB			Test #:	5		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:	
8/30/2021	4	4500	12:06 PM	24	8/31/2021	

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Lab

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
2278	992392	10:26 AM

Location:
 Trickle Channel, southern end of trench.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
4.5	5.5	139.9	88	80

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3590	4790			
	5260			
	4960			
Average:	Average:	Average:	Average:	Average:
3590	5000			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
9/6/2021	9/27/2021		7/30/2021	

Remarks:
 28 Day Results

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 5-8% Air	1@7, 3@28

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *RPJ*

