



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	TC&C, LLC
Project:	Rollin Ridge
Entech Job #	210369

CONCRETE TEST

CH			Test #: 4		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
8/27/2021	4	4500	2:30 PM	24	8/28/2021

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Lab

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
2211	713216	1:10 PM

Location:
 Walls for Outlet Structure at Pond B.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3	6.0	143.1	88	85

<i>7-Day Strength</i>	<i>28-Day Strength</i>	<i>-Day Strength</i>	<i>56-Day Strength</i>	<i>-Day Strength</i>
3400	5340			
	5560			
	5690			
Average:	Average:	Average:	Average:	Average:
3400	5530			
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
9/3/2021	9/25/2021		7/30/2021	

Remarks:
 28 Day Results

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 5-8% Air	1@7, 3@28

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By:

