



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Cordero Minor Subdivision, MS-17-001

Please accept the following comments from El Paso County Public Health regarding the 2-lot minor subdivision project referenced above:

- **Water for lots will be provided by private wells.**
- **Wastewater treatment for the lot will be provided by onsite wastewater treatment systems (OWTS). No soil data was submitted with the project, however, there is an existing non-engineer designed, permitted and approved OWTS installed on the property, which indicates the soil is acceptable for OWTS installation.**
- **The new onsite wastewater treatment system requires full compliance with the El Paso County Board of Health, Chapter 8, Onsite Wastewater Treatment System Regulations.**
- **Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
07Feb2019**