



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Bigari Extended Family Housing, AL-17-015

Please accept the following comments from El Paso County Public Health in support of the special use project referenced above:

- **Water service for the existing home and the proposed 1-bedroom modular house is by an individual well.**
- **Wastewater service for the project is provided by an existing onsite wastewater treatment system (OWTS) that was installed in 1996 and sized and approved for a 4 bedroom house; however, an addition to the OWTS was made in 1999 and the OWTS was approved for 6 bedrooms. The existing house has 5 bedrooms. Therefore, the 1-bedroom modular house is approved to connect to the existing approved OWTS.**
- **An OWTS Minor Repair Permit is required to be obtained from El Paso County Public Health for the installation of the new building sewer line connection from the modular house to the existing septic tank. All minimum OWTS installation setbacks must be maintained.**

**Mike McCarthy R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
13July2017**