



**ORIGINAL PERMIT APPLICANT(S)**

BJ HOWELL  
 DREAMA WALTON

**APPROVED WELL LOCATION**

Water Division: 2      Water District: 10  
 Designated Basin: N/A  
 Management District: N/A  
 County: EL PASO  
 Parcel Name: CRYSTAL PARK CHRISTIAN COMMUNITY  
 Lot: 5104      Block:      Filing: 2

SE 1/4 NW 1/4 Section 18 Township 14.0 S Range 67.0 W Sixth P.M.

**UTM COORDINATES (Meters, Zone:13, NAD83)**

Easting: 505899.0      Northing: 4298491.0

**PERMIT TO CONSTRUCT A NEW WELL**

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT**  
**CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(2) on the condition that this well is operated in accordance with the Crystal Park Investors, a Partnership and Crystal Park Christian Community Corp., Successors in interest to Crystal Park Development Co. Augmentation Plan approved by the Division 2 Water Court in case no. W-4568. If this well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
- 4) Approved for a well on a residential site of 0.70 acres described as lot 5104, filing 2, Crystal Park Subdivision, El Paso County.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
- 7) The maximum annual consumptive use of groundwater from this well, in combination with all other wells constructed pursuant to Division 2 Water Court case no. W-4568 shall not exceed 13 acre feet per year.
- 8) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 9) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 10) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: This permit will expire on the expiration date unless the well is constructed and a pump is installed by that date. A Well Construction and Yield Estimate Report (GWS-31) and Pump Installation and Production Equipment Test Report (GWS-32) must be submitted to the Division of Water Resources to verify the well has been constructed and the pump has been installed. A one-time extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTICE: This permit has been approved subject to the following changes: the full name of the subdivision is Crystal Park Christian Community, the UTM coordinate values were determined from the distances from section lines submitted with the permit application. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

WELL PERMIT NUMBER 81019-F

RECEIPT NUMBER 3679785

*Ailis A. Thyne*

Issued By AILIS THYNE

Date Issued: 6/19/2017

Expiration Date: 6/19/2018