



Environmental Health Review Comments

PPR2512: 7610 Maverick Rd. Islamic Society of Colorado Springs

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

1. EPCPH comments from May 2025 required additional information be submitted pertaining to the proposed Onsite Wastewater Treatment System (OWTS) to ensure the system and space would be adequately sized.
 - a. An advanced treatment unit will be required for any OWTS installed based on anticipated waste strength to exceed the required minimum quality standard of 180mg/L.
 - b. Flow equalization will be required as part of the design to address the surge flow usage anticipated for this facility.
 - c. An OWTS permit application meeting the requirements of the regulations in effect at time of submission will be required.
2. Properties within 400' or a municipal or sanitation district, as measured by way of public access, or legal easement, to any part of the applicant's property will be required to connect to the district's wastewater service.

For any additional questions or comments, please contact us at HEAEH_Landuse@elpasoco.com. While every effort is made for timely responses, allow 2 to 3 business days for a response from our field staff.