

***El Paso County Land Development Code  
Water Quality Requirements and Results  
For Mustang Place Subdivision  
Sampled December 20, 2021***

<b>Compound</b>	<b>Units</b>	<b>MCL/SMCL</b>	<b>Result</b>	
Antimony	mg/l	0.006	0	ND
Arsenic	mg/l	0.01	0	ND
Barium	mg/l	2	0.0341	
Beryllium	mg/l	0.004	0	ND
Cadmium	mg/l	0.005	0	ND
Chromium	mg/l	0.1	0	ND
Cyanide (Total)	mg/l	0	0	ND
Fluoride	mg/l	4	0.5	
Mercury	mg/l	0.002	0	ND
Nitrate as N	mg/l	10	0.08	
Nitrite as N	mg/l	1	0	ND
Selenium	mg/l	0.05	0	ND
Thallium	mg/l	0.002	0	ND
Aluminum	mg/l	0.05	0	ND
Chloride	mg/l	250	2.6	
Langelier Index			-0.61	
Iron	mg/l	0.3	0.09	
Manganese	mg/l	0.05	0.0511	
pH		6.5 - 8.5	7.67	
Silver	mg/l	0.1	0	ND
Sulfate	mg/l	250	50.2	
TDS	mg/l	500	204	
Zinc	mg/l	5	0.018	
Gross Alpha/Beta	pCi/l	15	5.2	
Combined Radium 226+228	pCi/l	5	3.4	
Total Coliform	#/100 ml	Absent	Absent	

Green = Result below MCL - Acceptable Water Quality