



# ENG-CDR23021-R1-CDs-GEC-S2.pdf Markup Summary

1 (8)




**Subject:** SW - Textbox with Arrow  
**Page Index:** 1  
**Date:** 2/21/2024 10:18:04 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

Revise to match GEC Checklist Item "ii"



**Subject:** SW - Textbox with Arrow  
**Page Index:** 1  
**Date:** 2/21/2024 10:18:04 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

Revise to match GEC Checklist Item "gg"



**Subject:** SW - Textbox  
**Page Index:** 1  
**Date:** 2/21/2024 10:18:27 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

Add text:

EDARP Filing Number 2321



**Subject:** Text Box  
**Page Index:** 1  
**Date:** 2/21/2024 5:03:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

See comment letter also.




**Subject:** Text Box  
**Page Index:** 1  
**Date:** 2/22/2024 12:45:55 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

add detailed roundabout plan sheets




**Subject:**  
**Page Index:** 1  
**Date:** 2/22/2024 12:55:14 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

PERMITS  
79+38.45  
RANGE 64 WEST OF THE  
OF COLORADO

**Subject:**  
**Page Index:** 1  
**Date:** 2/22/2024 12:55:52 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

6+38.45


DR. TO REX RD.  
S  
45  
OF THE 6TH PRINCIPAL ME  
O

**Subject:** Callout  
**Page Index:** 1  
**Date:** 2/22/2024 12:56:05 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [1] 28 Cover

79+32


2 (4)



**Subject:** Callout  
**Page Index:** 2  
**Date:** 2/21/2024 11:26:57 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [2] 29 Details


Delete "PCD"

PASO COUNTY EROSION AND STORMWATER QUALITY FLOODPLAIN DEVELOPMENT PERMIT, U.S. ARMY CORPS OF ENGINEERS, AND COUNTY AND STATE FUGITIVE DUST PERMITS SHALL NOT DEVIATE FROM THE PLANS WHICH SHALL BE APPROVED BY THE DESIGN ENGINEER AND PCD. CONSTRUCTION SHALL BE IMMEDIATELY STOPPED UPON DISCOVERY OF ANY EROSION OR STORMWATER QUALITY VIOLATION UNLESS OTHERWISE APPROVED BY THE DESIGN ENGINEER AND PCD. THE DESIGN ENGINEER SHALL COORDINATE GEOTECHNICAL TESTS AND SHALL BE APPROVED BY EL PASO COUNTY PCD FOR ROAD PAVEMENT. INSTRUCTIONS TRAFFIC MUST ENTER/EXIT THE SITE AS SHOWN ON THESE PLANS. ALL IMPROVEMENTS SHALL BE PERFORMED AS SHOWN ON THESE PLANS.

**Subject:** Callout  
**Page Index:** 2  
**Date:** 2/21/2024 11:26:57 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [2] 29 Details


change to "EPC"



**Subject:**  
**Page Index:** 2  
**Date:** 2/22/2024 3:36:43 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [2] 29 Details

HALL BE 24" IN WIDTH. CROSSWALKS LINES SHALL BE 12" WIDE AND 8' LONG PER CDOT S-627-1.



**Subject:** Callout  
**Page Index:** 2  
**Date:** 2/22/2024 3:36:53 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [2] 29 Details

Provide updated notes

3 (2)



**Subject:** Callout  
**Page Index:** 3  
**Date:** 2/22/2024 5:28:43 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 30 Legend


(show on plans)



**Subject:** Callout  
**Page Index:** 3  
**Date:** 2/22/2024 5:30:37 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 30 Legend

Sangria 1117 (Davis)

4 (3)




**Subject:** Callout  
**Page Index:** 4  
**Date:** 2/21/2024 11:27:48 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 31 TYPICAL ROAD SECTION

Show existing MVEA easement?



**Subject:** Callout  
**Page Index:** 4  
**Date:** 2/22/2024 4:07:45 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 31 TYPICAL ROAD SECTION


Add "Urban"



**Subject:** Text Box  
**Page Index:** 4  
**Date:** 2/22/2024 4:08:22 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 31 TYPICAL ROAD SECTION


Include what Design and Posted speeds are for this road classification

6 (1)




**Subject:** Callout  
**Page Index:** 6  
**Date:** 2/22/2024 3:25:58 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [6] 33 DEMOLITION PLAN

Update hatch to current sheet




**Subject:** Callout  
**Page Index:** 7  
**Date:** 2/22/2024 3:27:14 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 34 DEMOLITION PLAN

Update hatch to current sheet




**Subject:** Callout  
**Page Index:** 7  
**Date:** 2/22/2024 3:28:34 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 34 DEMOLITION PLAN

Add match line



**Subject:** Callout  
**Page Index:** 8  
**Date:** 2/21/2024 12:35:32 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Label grades




**Subject:** Cloud  
**Page Index:** 8  
**Date:** 2/22/2024 3:29:25 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Line Table		Curve Table	
Line #	Length	Curve #	Radius
L1	300.12	C1	1180.02

Provide legend for various linetypes and hatchings


**Subject:** Text Box  
**Page Index:** 8  
**Date:** 2/22/2024 3:59:36 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Provide legend for various linetypes and hatchings




**Subject:** Callout  
**Page Index:** 8  
**Date:** 2/22/2024 4:02:34 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Use same storm name/call out as on plan view




**Subject:** Callout  
**Page Index:** 8  
**Date:** 2/22/2024 4:03:48 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Did not see L1 labeled in plan view



**Subject:** Callout  
**Page Index:** 8  
**Date:** 2/22/2024 4:04:16 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE


Missing existing grade line



**Subject:** Callout  
**Page Index:** 8  
**Date:** 2/22/2024 4:14:10 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [8] 35 PLAN & PROFILE

Revise curve to meet minimum K-value for sag curve per ECM Table 2-14

9 (2)



**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/22/2024 4:35:41 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 36 PLAN & PROFILE


What is this? Please label or turn off



**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/22/2024 4:18:23 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 36 PLAN & PROFILE


Label trail & sidewalk

10 (8)




**Subject:**  
**Page Index:** 10  
**Date:** 2/21/2024 12:40:17 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

= 53.66




**Subject:** Callout  
**Page Index:** 10  
**Date:** 2/21/2024 12:55:30 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

Increase to meet criteria (96)




**Subject:** Callout  
**Page Index:** 10  
**Date:** 2/21/2024 12:43:46 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

Delete "future"




**Subject:** SW - Textbox with Arrow  
**Page Index:** 10  
**Date:** 2/21/2024 2:37:13 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

Clarify that this is "Sand Filter C"



**Subject:** Callout  
**Page Index:** 10  
**Date:** 2/22/2024 4:36:26 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

Manhole will need to be larger than connecting pipes




**Subject:** Callout  
**Page Index:** 10  
**Date:** 2/22/2024 4:37:19 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

Show how proposed grading ties into existing ground



**Subject:** Callout  
**Page Index:** 10  
**Date:** 2/22/2024 4:37:57 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE


Plan view cuts short of where improvements end (Sta 81+32.86) per profile. Please extend to show



**Subject:** Highlight  
**Page Index:** 10  
**Date:** 2/22/2024 4:38:01 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [10] 37 PLAN & PROFILE

####


11 (4)



**Subject:** SW - Textbox with Arrow  
**Page Index:** 11  
**Date:** 2/21/2024 9:43:15 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [11] 38 GRADING & EROSION CONTROL PLAN


Check dams to be installed a minimum of every 1.5' of vertical fall. Notate spacing and/or include a table for multiple slopes, based on your selected detail.

Since you have already provided a table, add to it which check dam type you anticipate because that will effect the spacing.




**Subject:** SW - Textbox  
**Page Index:** 11  
**Date:** 2/21/2024 9:43:06 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [11] 38 GRADING & EROSION CONTROL PLAN

GEC Checklist Item "s" - provide more drainage flow arrows. Only a couple are currently shown.



**Subject:** SW - Textbox  
**Page Index:** 11  
**Date:** 2/21/2024 9:47:40 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [11] 38 GRADING & EROSION CONTROL PLAN


Provide details for all temp BMPs shown on GEC Plans.



**Subject:** SW - Textbox with Arrow  
**Page Index:** 11  
**Date:** 2/21/2024 10:09:36 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [11] 38 GRADING & EROSION CONTROL PLAN


Consider need for a VTC here.

12 (5)



**Subject:** SW - Textbox with Arrow  
**Page Index:** 12  
**Date:** 2/21/2024 9:48:01 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 39 GRADING & EROSION CONTROL PLAN

Clarify that this is "Sand Filter C"




**Subject:** SW - Textbox with Arrow  
**Page Index:** 12  
**Date:** 2/21/2024 9:48:59 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 39 GRADING & EROSION CONTROL PLAN

TSBs are required for disturbed areas >1ac.

Is this going to be used as a TSB? If so, label accordingly. And:

Provide details of temporary sediment basin including riser pipe diameter and perforation sizing, number of rows of holes, required volume, location of outlet pipe and spillway, and tributary area to the sediment basin. And provide contours for sediment basin.




**Subject:** SW - Textbox with Arrow  
**Page Index:** 12  
**Date:** 2/21/2024 10:07:57 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 39 GRADING & EROSION CONTROL PLAN

Show all proposed grading within the LOD.



**Subject:** SW - Textbox with Arrow  
**Page Index:** 12  
**Date:** 2/21/2024 10:09:02 AM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 39 GRADING & EROSION CONTROL PLAN

Consider need for a VTC here.



**Subject:** Callout  
**Page Index:** 12  
**Date:** 2/23/2024 9:14:21 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 39 GRADING & EROSION CONTROL PLAN

Approved CLOMR required prior to construction. LOMR required post-construction.

---


## 13 (42)

---



**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/21/2024 12:58:02 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

the hatched areas, if needed, should be concrete. Discuss with Staff



**Subject:**  
**Page Index:** 13  
**Date:** 2/21/2024 1:07:58 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

W13-1 (20MPH)





**Subject:**  
**Page Index:** 13  
**Date:** 2/21/2024 1:08:14 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/21/2024 1:08:42 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

One-way signs per MUTCD update




**Subject:**  
**Page Index:** 13  
**Date:** 2/21/2024 1:09:15 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/21/2024 1:09:36 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Verify distance from intersection



**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/22/2024 2:34:19 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

W13-1 is not required




**Subject:**  
**Page Index:** 13  
**Date:** 2/22/2024 3:57:54 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping


R6-4

12" WALK LIN


**Subject:** 12"  
**Page Index:** 13  
**Date:** 2/22/2024 3:58:02 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/22/2024 3:59:20 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping  
Are bike exits and entrances going to be provided?




**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/22/2024 4:59:53 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/22/2024 5:00:46 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/22/2024 5:01:05 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping



**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/22/2024 5:01:52 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping





---

**Subject:** 4" YELLOW LINE  
**Page Index:** 13  
**Date:** 2/22/2024 5:01:59 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping





---

**Subject:** Delete  
**Page Index:** 13  
**Date:** 2/22/2024 5:02:04 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping





---

**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/22/2024 5:02:30 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping





---

**Subject:** 4" YELLOW LINE  
**Page Index:** 13  
**Date:** 2/22/2024 5:03:12 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




---

**Subject:** Delete  
**Page Index:** 13  
**Date:** 2/22/2024 5:03:15 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping



---

**Subject:** 4" YELLOW LINE  
**Page Index:** 13  
**Date:** 2/22/2024 5:03:39 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:**   
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Delete  
**Page Index:** 13  
**Date:** 2/22/2024 5:03:43 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Delete



**Subject:**  
**Page Index:** 13  
**Date:** 2/22/2024 5:04:08 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

4" DASHED WHITE



**Subject:**  
**Page Index:** 13  
**Date:** 2/22/2024 5:04:23 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

4" YELLOW LINE



**Subject:** Delete  
**Page Index:** 13  
**Date:** 2/22/2024 5:04:30 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Delete



**Subject:**  
**Page Index:** 13  
**Date:** 2/22/2024 5:05:01 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping


4" YELLOW LINE




**Subject:** Delete  
**Page Index:** 13  
**Date:** 2/22/2024 5:05:06 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Delete


CONCRETE  
ER CITY DT

Subject: CITY  
Page Index: 13  
Date: 2/22/2024 5:05:20 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping


12" WIL  
CROSS

Subject: 12"  
Page Index: 13  
Date: 2/22/2024 5:10:17 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping


12" WIL  
ROSSWA

Subject: 12"  
Page Index: 13  
Date: 2/22/2024 5:10:20 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping


12" WIL  
CROSS

Subject: 12"  
Page Index: 13  
Date: 2/22/2024 5:10:23 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping

12" WIL  
CROSS

Subject: 12"  
Page Index: 13  
Date: 2/22/2024 5:10:27 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping

ER CITY  
!1

Subject: CITY  
Page Index: 13  
Date: 2/22/2024 5:10:33 PM  
Author: Jeff Rice - EPC Engineering Review  
Color:   
Layer:  
Space:  
Page Label: [13] 40 Dawlish Roundabout Striping

PATTERNED  
Type-R TY DTI

**Subject:**  
**Page Index:** 13  
**Date:** 2/22/2024 5:11:16 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping


CITY

Use updated notes




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/22/2024 5:13:01 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Use updated notes




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/22/2024 5:33:23 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Place within center island or reduce truck apron based on truck tracking




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/22/2024 5:34:23 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

Is this needed?




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/23/2024 8:23:47 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

show triangles, dotted lane edge striping at entrances per MUTCD Fig. 3D-1




**Subject:** Length Measurement  
**Page Index:** 13  
**Date:** 2/23/2024 8:25:59 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

18'-0"




**Subject:** Callout  
**Page Index:** 13  
**Date:** 2/23/2024 8:27:15 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping


see other comments about concrete pans extending to where striping is shown on this plan



**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/23/2024 8:35:58 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping



**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/23/2024 8:36:17 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping




**Subject:** Arrow  
**Page Index:** 13  
**Date:** 2/23/2024 8:36:32 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [13] 40 Dawlish Roundabout Striping

14 (6)




**Subject:**  
**Page Index:** 14  
**Date:** 2/22/2024 2:50:19 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading

2.7



**Subject:**  
**Page Index:** 14  
**Date:** 2/22/2024 2:50:34 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading


2.1



---

**Subject:** Highlight  
**Page Index:** 14 2.2%  
**Date:** 2/22/2024 4:52:46 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading


---



---

**Subject:**  
**Page Index:** 14 6'  
**Date:** 2/23/2024 8:42:18 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading


---



---

**Subject:** Callout  
**Page Index:** 14 10'  
**Date:** 2/23/2024 8:42:42 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading

---




---

**Subject:** Callout  
**Page Index:** 14 show culvert and utilities  
**Date:** 2/23/2024 8:44:06 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [14] 41 Dawlish Roundabout Grading

---

15 (2)


---



---

**Subject:**  
**Page Index:** 15 2.2  
**Date:** 2/22/2024 2:51:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [15] 42 Dawlish Roundabout Grading

---



---

**Subject:**  
**Page Index:** 15 2.7  
**Date:** 2/22/2024 2:52:06 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [15] 42 Dawlish Roundabout Grading





**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:07:11 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

the hatched areas, if needed, should be concrete.  
Discuss with Staff



**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 2:54:58 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:32:43 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

One-way signs (R6-1) per MUTCD update



**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 2:53:36 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:03:16 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

Verify distance from intersection




**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:01:42 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

W13-1 may not be required if speed differential is <15 MPH




**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:08:09 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

gray these back or hide?




**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/23/2024 8:34:17 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping


EPC prefers W11-2 placed here with R1-6 for exiting traffic (optional in MUTCD)



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 3:26:59 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/23/2024 8:37:05 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 3:26:55 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping


verify yield sign locations



**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 3:34:00 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

12"

12" W/LINES



**Subject:** Callout 24"  
**Page Index:** 16  
**Date:** 2/22/2024 3:37:25 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

12" WIL

**Subject:** 12"  
**Page Index:** 16  
**Date:** 2/22/2024 3:37:33 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

12" WIL  
LINES

**Subject:** 12"  
**Page Index:** 16  
**Date:** 2/22/2024 3:37:46 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

R6-4

**Subject:** R6-4  
**Page Index:** 16  
**Date:** 2/22/2024 3:41:19 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

ATTENDED  
ER CITY DTI

**Subject:** CITY  
**Page Index:** 16  
**Date:** 2/22/2024 5:11:40 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

12" WIDE  
LINES (W

**Subject:** 12" W  
**Page Index:** 16  
**Date:** 2/22/2024 5:11:45 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping





---

**Subject:** Delete  
**Page Index:** 16  
**Date:** 2/22/2024 5:13:24 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping


Delete

12" WII

---


**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:13:32 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

12"




---

**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:13:49 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




---

**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:13:59 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




---

**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:14:05 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




---

**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:14:15 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:14:29 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:14:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:15:02 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

4" YELLOW LINE




**Subject:** Delete  
**Page Index:** 16  
**Date:** 2/22/2024 5:15:08 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

Delete




**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:15:29 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

CITY



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:18:21 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/22/2024 5:18:14 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

CONCRETE  
ER CITY DTI


**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:18:52 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

CITY

ATTENDED  
ER CITY DTI


**Subject:**  
**Page Index:** 16  
**Date:** 2/22/2024 5:19:07 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping

CITY




**Subject:** Callout  
**Page Index:** 16  
**Date:** 2/22/2024 5:32:51 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping


Place within center island or reduce truck apron based on truck tracking



**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/23/2024 8:34:38 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




**Subject:** Arrow  
**Page Index:** 16  
**Date:** 2/23/2024 8:37:12 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [16] 43 Rex Roundabout Striping




**Subject:** SW - Textbox with Arrow  
**Page Index:** 17  
**Date:** 2/21/2024 2:37:37 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading


Clarify that this is "Sand Filter C"



**Subject:** Highlight  
**Page Index:** 17  
**Date:** 2/22/2024 4:56:31 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading




**Subject:** Highlight  
**Page Index:** 17  
**Date:** 2/22/2024 4:56:33 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading



**Subject:** Callout  
**Page Index:** 17  
**Date:** 2/23/2024 8:40:39 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading




**Subject:**  
**Page Index:** 17  
**Date:** 2/23/2024 8:40:46 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading




**Subject:**  
**Page Index:** 17  
**Date:** 2/23/2024 8:40:53 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [17] 44 Rex Roundabout Grading






**Subject:** SW - Textbox with Arrow  
**Page Index:** 18  
**Date:** 2/21/2024 2:37:48 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading


Clarify that this is "Sand Filter C"




**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 3:43:35 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 3:43:36 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 3:43:38 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading




**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 3:43:40 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading




**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:21:02 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading

2.4%




---

**Subject:**  
**Page Index:** 18 2.2  
**Date:** 2/22/2024 5:21:18 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



---


**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:23:34 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



---


**Subject:** Callout  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:06 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading

Concrete pans should extend as far as possible to a point on all inner radii.




---

**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:24:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



---

**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:17 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



---


**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:18 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading




**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:20 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:21 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:24 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading



**Subject:**  
**Page Index:** 18  
**Date:** 2/22/2024 5:25:25 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [18] 45 Rex Roundabout Grading

19 (3)

**NOTES:**  
 ALLS AND SPECIFICATIONS  
 USE CITY OF MONUMENT  
 FOR DESIGN AND  
 MARKINGS SHALL BE IN  
 FEDERAL HIGHWAY

**Subject:** Highlight  
**Page Index:** 19  
**Date:** 2/22/2024 5:14:52 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [19] 46 STRIPING PLAN

CITY OF MONUMENT



**Subject:** Callout  
**Page Index:** 19  
**Date:** 2/22/2024 5:15:07 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [19] 46 STRIPING PLAN


change to El Paso County

Remove any items in the legend which are not shown in the plan view

**Subject:** Text Box  
**Page Index:** 19  
**Date:** 2/22/2024 5:16:06 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [19] 46 STRIPING PLAN

Remove any items in the legend which are not shown in the plan view

20 (4)



**Subject:** Callout  
**Page Index:** 20  
**Date:** 2/21/2024 1:22:43 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [20] 47 STRIPING PLAN

Label lane and taper lengths, verify per ECM/TIS

**NOTES:**  
ALLS AND SPECIFICATIONS  
5 USE CITY OF MONUMENT  
FOR DESIGN AND  
\* MARKINGS SHALL BE IN  
GENERAL HIGHWAY


**Subject:** Highlight  
**Page Index:** 20  
**Date:** 2/22/2024 5:12:31 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [20] 47 STRIPING PLAN

CITY OF MONUMENT

- 8] RIGHT TURN LANE (SOLID WHITE, 6' WIDE, R)
  - 9] LEFT TURN LANE (SOLID WHITE, 6' WIDE, R)
  - 10] TYPE III BARRICADE (TEMPORARY)
- arrow (narrow type)

**Subject:** Callout  
**Page Index:** 20  
**Date:** 2/23/2024 8:39:43 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [20] 47 STRIPING PLAN


arrow (narrow type)



**Subject:** Callout  
**Page Index:** 20  
**Date:** 2/23/2024 8:46:19 AM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [20] 47 STRIPING PLAN


2nd arrow required (use narrow arrow design for all)

21 (6)




**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:16:34 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

Call out lining, cross-section




**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:17:07 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

Call out easement, future ROW




**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:17:46 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

show pipe, outfall




**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:18:12 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

show outfall pipe / conveyance



**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:18:53 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

Show proposed ROW




**Subject:** Callout  
**Page Index:** 21  
**Date:** 2/21/2024 3:19:10 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [21] 48 POND PLAN - TSB

Label property line

---

22 (8)




**Subject:** SW - Textbox with Arrow  
**Page Index:** 22  
**Date:** 2/21/2024 2:38:16 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER

Clarify that this is  
"Sand Filter C"

Show location


**Subject:** Text Box  
**Page Index:** 22  
**Date:** 2/21/2024 3:21:06 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER

Show location




**Subject:** Callout  
**Page Index:** 22  
**Date:** 2/21/2024 3:21:34 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER

Label grading by others?




**Subject:**  
**Page Index:** 22  
**Date:** 2/21/2024 3:21:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER




**Subject:** Callout  
**Page Index:** 22  
**Date:** 2/21/2024 3:23:59 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER

extend easement



**Subject:** Callout  
**Page Index:** 22  
**Date:** 2/21/2024 3:25:09 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER

label contours



**Subject:** Callout  
**Page Index:** 22  
**Date:** 2/21/2024 3:26:19 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER


18" minimum



**Subject:** Callout  
**Page Index:** 22  
**Date:** 2/21/2024 3:26:57 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [22] 49 POND PLANS - SAND FILTER


show spillway flowpath and easement

24 (6)




**Subject:** SW - Textbox with Arrow  
**Page Index:** 24  
**Date:** 2/21/2024 2:40:05 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE

This is labeled as "EDB B" on the FDR. Revise to remove discrepancy.




**Subject:**  
**Page Index:** 24  
**Date:** 2/21/2024 2:40:55 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE




**Subject:** Text Box  
**Page Index:** 24  
**Date:** 2/22/2024 5:24:50 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE

HGL's need to be provided




**Subject:** Callout  
**Page Index:** 24  
**Date:** 2/22/2024 5:25:11 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE

Provide riprap outlet protection




**Subject:** Highlight  
**Page Index:** 24  
**Date:** 2/22/2024 5:25:27 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE




**Subject:** Highlight  
**Page Index:** 24  
**Date:** 2/22/2024 5:26:17 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 51 STORM PLAN & PROFILE

25 (10)




**Subject:**  
**Page Index:** 25  
**Date:** 2/21/2024 3:30:51 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE



**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/21/2024 4:06:09 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE

Show HGLs




**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/21/2024 4:06:50 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE

Show all contours



**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/21/2024 4:07:56 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE


please remove or gray back lot easements/setbacks



**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/21/2024 4:08:33 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE


label easement and width






**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/22/2024 5:27:09 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE

Show and label riprap outlet protection.



**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/22/2024 5:27:54 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE

Larger manhole will be needed to accommodate number and size of pipes at this location



**Subject:** Callout  
**Page Index:** 25  
**Date:** 2/22/2024 5:28:33 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE

Label and provide detail for riprap outlet protection



**Subject:** Highlight  
**Page Index:** 25  
**Date:** 2/22/2024 5:32:47 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE


52



**Subject:** Highlight  
**Page Index:** 25  
**Date:** 2/22/2024 5:33:17 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 52 STORM PLAN & PROFILE


52

26 (7)



**Subject:** Callout  
**Page Index:** 26  
**Date:** 2/22/2024 5:29:08 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

Label riprap protection




**Subject:** Callout  
**Page Index:** 26  
**Date:** 2/22/2024 5:29:28 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

Show and label riprap protection


TORM MH (4' DIA)  
 TA 702 292' ???  
 IN 7010.84  
 IN 7004.03 (NW 4  
 IN OUT 7003.93 (NE

**Subject:** Highlight  
**Page Index:** 26  
**Date:** 2/22/2024 5:29:33 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

?? ???' ???



**Subject:** Highlight  
**Page Index:** 26  
**Date:** 2/22/2024 5:29:55 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE



**Subject:** Callout  
**Page Index:** 26  
**Date:** 2/22/2024 5:30:35 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

Grading should match to pipe invert

+50  
 EET 51


**Subject:** Highlight  
**Page Index:** 26  
**Date:** 2/22/2024 5:32:55 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

51

+50  
 EET 51


**Subject:** Highlight  
**Page Index:** 26  
**Date:** 2/22/2024 5:33:03 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 53 STORM PLAN & PROFILE

5




**Subject:** SW - Textbox with Arrow  
**Page Index:** 27  
**Date:** 2/21/2024 2:39:20 PM  
**Author:** Glenn Reese - EPC Stormwater  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 54 STORM PLAN & PROFILE

Clarify that this is "Sand Filter C"




**Subject:** Callout  
**Page Index:** 27  
**Date:** 2/21/2024 4:46:54 PM  
**Author:** Jeff Rice - EPC Engineering Review  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 54 STORM PLAN & PROFILE

show conveyance and easement




**Subject:** Callout  
**Page Index:** 27  
**Date:** 2/22/2024 5:35:55 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 54 STORM PLAN & PROFILE

Riprap outlet protection



**Subject:** Callout  
**Page Index:** 27  
**Date:** 2/22/2024 5:35:38 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 54 STORM PLAN & PROFILE

Inlet grate elevation should match grading



**Subject:** Callout  
**Page Index:** 27  
**Date:** 2/22/2024 5:36:41 PM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 54 STORM PLAN & PROFILE

Riprap outlet protection