



# Flying Horse East Master Development Drainage Plan

[PCD File No. SKP242](#)

December 20, 2024

HR Green Project No: 2402059.3

**Prepared For:**

Mr. Drew Balsick

Vice President / Project Manager

Flying Horse Development, LLC

2138 Flying Horse Club Drive

Colorado Springs, CO 80921

(719) 785-3237

**Prepared By:**

HR Green Development, LLC

Contact: Gregory Panza, PE

[gpanza@hrgreen.com](mailto:gpanza@hrgreen.com)

720-602-4956



## Table of Contents

- Engineer’s Statement .....1
- Developer’s Statement .....1
- El Paso County:.....1
- I. General Purpose, Location and Description.....2
  - a. Purpose and Scope .....2
  - b. Drainage Basins Investigations .....2
  - c. Stakeholder Process .....2
  - d. Agency Jurisdictions.....2
  - e. General Project Description .....2
  - f. Data Sources .....3
  - g. Applicable Criteria and Standards.....3
- II. Project Characteristics.....4
  - a. Location in Drainage Basin, Offsite Flows, Size .....4
  - b. Compliance with El Paso County .....4
  - c. Site Characteristics.....5
  - d. Major Drainage Ways and Structures .....5
  - e. Existing and Proposed Land Use .....5
- III. Hydrologic Analysis .....5
  - a. Methodology .....5
  - b. Major Basins and Subbasins.....7
  - c. Basin Hydrology .....24
- IV. Hydraulic Analysis ..... 26
  - a. Major Drainageways.....26
- V. Environmental Evaluations ..... 26
  - a. Significant Existing or Potential Wetland and Riparian Areas Impacts .....26
  - b. Stormwater Quality Considerations and Proposed Practices .....26
  - c. Permitting Requirements .....27
  - d. 4-Step Process .....27
- VI. Alternatives Evaluation ..... 28
- VII. Selected Plan..... 28



- a. Plan Hydrology .....28
- b. System Improvements.....28
- VIII. Drawings..... 28
- IX. Summary ..... 28
- X. References ..... 29

## List of Figures

- Figure 1 – Proposed Site Development Map .....3

## List of Tables

- Table 1 – Project Site Offsite Subbasins Contributing Area and Flow .....4
- Table 2 – Residential Land Use Max Estimated Densities.....5
- Table 3 – Land Use and Associated Impervious Percentage .....6
- Table 4 – Existing Drainage Subbasins' Locations and Characteristics .....8
- Table 5 - Proposed Drainage Subbasins' Locations and Characteristics ..... 12
- Table 6 – Offsite Subbasin Receiving Detention Pond Parameters..... 24
- Table 7 – Proposed Detention Pond Volumes with Associated Subbasin Drainage Parameters ..... 24

## Appendices

- A. Maps & Site Photos
- B. Hydrology Calculations
- C. SWMM Calculations
- D. Pond Calculations
- E. Proposed Culvert Calculations
- F. Site Drainage Maps



## Engineer’s Statement

This report and plan for the drainage design of the development, Flying Horse East, was prepared by me (or under my direct supervision) and is correct to the best of my knowledge and belief. Said report and plan has been prepared in accordance with the *El Paso County Drainage Criteria* Manual and is in conformity with the master plan of the drainage basin. I understand that El Paso County does not and will not assume liability for drainage facilities designed by others. I accept responsibility for any liability caused by any negligent acts, errors or omissions on my part in preparing this report.

---

Gregory Panza, PE                      Date

State of Colorado No. 37081

For and on behalf of HR Green Development, LLC

## Developer’s Statement

I, the developer, have read and will comply with all of the requirements specified in this drainage report and plan.

Flying Horse Development, LLC

---

Drew Balsick                              Date

Vice President / Project Manager

Flying Horse Development, LLC

2138 Flying Horse Club Drive

Colorado Springs, CO 80921

## El Paso County:

Filed in accordance with the requirements of the El Paso County Land Development Code, Drainage Criteria Manual, Volumes 1 and 2 and the Engineering Criteria Manual, as amended.

---

Jeffrey Rice, P.E.    **Joshua Palmer, PE**  
Senior Engineer    **County Engineer**

---

Date

# Master Development Drainage Plan – Flying Horse East

## I. General Purpose, Location and Description

### a. Purpose and Scope

The Purpose of this Master Development Drainage Plan (MDDP) is to describe the onsite and offsite drainage patterns, existing and proposed storm infrastructure as it relates to preliminary water quality and stormwater detention, areas tributary to the site and the planned storm water management for the Flying Horse East development. The items discussed in this report are preliminary in nature and final drainage calculations and design will be required as development proceeds. This report provides a general drainage concept and guidance for future development of Flying Horse East.

### b. Drainage Basins Investigations

Flying Horse East is a part of the Arkansas River Basin. The site drains into three major drainage basins: Livestock Company, Drennan, and Upper East Chico. The major basin delineated for El Paso County are shown in Appendix A.

The majority of the site drains into the Livestock Company basin, which eventually drains into Book Ranch Creek, a tributary to Black Squirrel Creek. Black Squirrel Creek travels south until its confluence with the Arkansas River.

The southwest corner of the development drains to either the Upper East Chico basin or the Drennan basin. Both basins drain south towards Chico Creek and Lower Black Squirrel Creek, respectively. Both basins eventually drain into the Arkansas River.

A Drainage Basin Planning Study (DBPS) does not currently exist for any of the basins mentioned above. The MDDP will comply with standard El Paso County regulations regarding drainage within this corridor.

### c. Stakeholder Process

There are no amendments to the current DBPS.

### d. Agency Jurisdictions

Listed below are the jurisdictions that this project will conform to:

El Paso County

Federal Emergency Management Agency

### e. General Project Description

Flying Horse East is in El Paso County. The development is bordered by Highway 94 to the north, Enoch Road to the west, Schriever Airforce Base to the south, and Paddock Road to the east. The area contains approximately 1,820 acres within the whole Section 13 and 14, Township 14 South, Range 64 West of the Sixth Principal Meridian, as well as a portion of Section 23 and 24, Township 14 South, and Range 64 West of the Sixth Principal Meridian.

This MDDP will cover approximately 1822.4 acres with a range of 2789 – 4838 residential units, which is shown in the figure below. This development will include estate lots, low through high density residential lots, commercial development, a hotel, open space and parks, and a business park area.




Figure 1 – Proposed Site Development Map

## f. Data Sources

Listed Below are the technical resources reviewed in the preparation of this MDDP:

- El Paso County Drainage Criteria Manual (DCM)
- Mile High Flood District
- NOAA Atlas 14
- NRCS Soil Survey for El Paso County Area, Colorado
- FEMA FIRM Panel 08041C0785G and Panel 08041C0805G (eff. 12/7/2018)
- El Paso County Assessor Property Records

## g. Applicable Criteria and Standards

Per the El Paso County Criteria Manual, flows from the proposed site will be limited to historic flows to maintain the stability of the existing channels within the drainage basins. The master plan follows the Drainage Criteria Manual for El Paso County which refers to the City of Colorado Springs Drainage Criteria Manuals as amended.

please verify

## II. Project Characteristics

### a. Location in Drainage Basin, Offsite Flows, Size

Flying Horse East is located within both the Black Squirrel Drainage Basin and the Chico Creek Basin. A majority of the development is within the Livestock Company Basin, a subbasin to the Black Squirrel Drainage Basin. This drainage basin encompasses 10.9 square miles of mostly forested area and generally slopes from east to west and outfalls into Monument Creek. Black Squirrel is a subbasin of the Arkansas River. A small section of the development is part of the Upper East Chico Basin, a subbasin to the Chico Creek Basin. The Chico Creek Basin encompasses 16.3 square miles of mostly plains and forest area which generally drains north to south and outfalls into the Arkansas River. This is shown in Appendix A.

As the site generally lies at the top of each of the respective basins, several offsite flows are conveyed onto the site. There are nine offsite subbasins that drain onto the site. Three offsite basins drain north onto another offsite basin which eventually drains onto the site. The remaining six offsite are split, three drain from the north and three from the west. Eight of the offsite subbasins are part of the Livestock Company basin and one is part of the Upper East Chico basin. The basin names, acreage, and respective contributing flows from these basins is shown in the table below:

Table 1 – Project Site Offsite Subbasins Contributing Area and Flow

Basin Name	Major Basin	Acreage	5 Year Flow (cfs)	100 Year Flow (cfs)
OS1	Livestock Company	423.70	9.22	230.99
OS2	Livestock Company	100.46	6.00	55.02
OS3	Livestock Company	3535.15	82.90	1831.23
OS4	Livestock Company	76.90	1.62	59.67
OS5	Livestock Company	7.78	0.15	4.20
OS6	Livestock Company	71.77	0.43	26.86
OS7	Livestock Company	31.27	1.88	25.47
OS8	Livestock Company	53.43	3.86	58.70
OS9	Upper East Chico	215.89	4.20	136.42

These nine basins are generally conveyed through the development via natural drainage ways. The proposed ponds discussed later within this report have been sized to pass through the offsite flows if necessary.

### b. Compliance with El Paso County

This MDDP is in general conformance with the guidelines outlined. The ability of downstream drainage facilities to pass developed runoff from the proposed development must be thoroughly analyzed in the MDDP. will construct multiple full spectrum detention facilities to limit the effect of natural and existing flow patterns.

Existing downstream infrastructure is currently limited to the historic drainage channels and minimal downstream improvements exist. As such, the site restricts offsite flow rates to not exceed existing flow rates. The site's ultimate outfalls will generally be along the same historic tributaries. Although outfall rates will be at or below existing, the cumulative volume of runoff will increase and therefore downstream facilities may see an increase in the duration of flows. This may provide a net benefit to the downstream



Please discuss how the increase in volume will be mitigated to avoid adverse impacts to the downstream.

facilities by providing more water to assist with the sustenance of vegetation. However, it should be noted that increased volume may expedite potential erosion or channel movement.

### c. Site Characteristics

Per the NRCS web soil survey, the site is made up entirely of Type A and B soils, approximately 59% and 41%, respectively. The majority of the site is Truckton sandy loam, 3 to 9 percent slopes; however, the other soils are other types of various sandy loams. There is a small portion of type D, Udic Haplusterts, soil in the northwest corner of the site. See Appendix A for the NRCS soil map.

The current ground cover for the site is mainly undeveloped, with mainly short to mid-grass prairie grasslands and former farmland which consists of non-native weeds and grasses. There is one existing residential property on the north side of the site as well. This portion of the site has very few, if any shrubs and no trees were seen on the site. Site photos are shown in Appendix A.

### d. Major Drainage Ways and Structures

One FEMA regulated drainageway exists within the development, along with two smaller tributaries that drain south towards the Schriever Airforce Base. The streams are currently unna towards Black Squirrel Creek and Chico Creek. One small existing natural pond e the property, but no flood control structures are located on the site.

please coordinate with the planners and remove if a hotel will not be considered. The TIS does not account for a hotel.

Existing major and minor drainage channels within the site are planned to be mai extent possible within parkways and greenways with the development. These will conveyance of storm drainage flows.

### e. Existing and Proposed Land Use

The existing site is open rangeland for a majority of the site with one single family residence (8.5 acres) on the north side of the site. As mentioned above, the current land use is natural undeveloped land.

The proposed land use is shown in Figure 1. The site will be a mixture of low, medium and high-density residential developments along with commercial, a hotel, a school, and several business developments. The site will also have several parks and other green spaces. The current land plan assumes approximately 2789 to 4838 dwelling units will be constructed on the site. The table below details the estimated max density of each residential density.

Table 2 – Residential Land Use Max Estimated Densities

Land Use	MAX DU/AC
Low Density	2.99
Medium Density	4.99
Medium High Density	7.99
High Density	14.00

## III. Hydrologic Analysis

### a. Methodology

Design rainfall was determined utilizing the NOAA Atlas 14 to determine the 5- and 100-year rainfall values for the 1-hour events at the property. The 1-hour rainfall depths are 1.26 and 2.66 in/hr respectively.



per Table 6-6 of DCM paved roadways shall be 100% impervious. Revise.

Composite percent impervious calculations were completed for each subbasin for existing and proposed conditions. The El Paso County Drainage Criteria Manual (EPDCM) Table 3-1 and the Urban Storm Drainage Criteria Manual (USDCM) Table 6.2 were used for reference when correlating land use to percent impervious values. The table below shows the land use to impervious correlation.

Table 3 – Land Use and Associated Impervious Percentage

Land Use/Type	Impervious (%)
Commercial	95
High Density Residential (Multi-family)	65
Medium High Density Residential (Single-family – 0.1377 acre lots)	53
Medium Density Residential (Single-family – 0.25 acre lots)	40
Low Density Residential (Single-family – 0.5 acre lots)	25
Business Park (Offices)	65
Schools	55
Mixed-Use (Commercial Low Density) <sup>1</sup>	65
Roads	95
Grass/Undeveloped	2

1- Mixed-use used commercial low density from the USDCM as this most accurately depicts the areas expected use.

For the existing conditions the National Land Cover Database (NLCD) was utilized. The data was categorized by various types of roads, other impervious surfaces (houses), and unclassified (undeveloped). Roads and other impervious surfaces were set to 95% impervious and undeveloped land was set to 2%. The composite percent impervious for each existing and offsite basin were calculated and shown below in Table 4. For proposed conditions, the proposed site development plan was used. Each land use was assigned an impervious value based on the table above. The NLCD data was used to represent land coverage outside of the property boundary. The composite percent impervious for the proposed and offsite basins is shown below in Table 5.

The rainfall, percent impervious values, and hydrologic soil type from NRCS web soil survey (described above in Section II.c.) were then used as inputs into the Colorado Urban Hydrograph Procedure (CUHP) spreadsheets to determine runoff values for both pre-development and post-development site.

CUHP is an evolution of the Snyder unit hydrograph and is calibrated for use along the Colorado Front Range. One hour rainfall amounts are input into the program to produce a storm hyetograph that is then used to calculate a storm hydrograph for each basin depending on the subbasins properties including flow slope, longest flow path length, centroidal flow path length, impervious area, pervious depression storage area, and various infiltration rates. Tabular hydrographs are then computed and can be used in EPA SWMM. The CUHP results for proposed and existing conditions are included within Appendix B.

EPA SWMM was used to determine flow routing via the kinematic wave method. Subbasins were routed to their respective design points for both the developed and predeveloped condition to determine peak runoff amounts for the 5-year and 100-year storm events. Models were developed with the assumption of conveyance of 100-year storm event; therefore, conveyance paths and geometry (culvert and channel sizes and slopes) were estimated based on site data (terrain surface, site photos, and aerial imagery).

Information from these models along with information and calculations performed in the Mile High Flood District BMP spreadsheets was used to determine pond sizing calculations and release rates.

## **b. Major Basins and Subbasins**

### **1. MAJOR BASIN DESCRIPTION**

Per FEMA FIRM 08041C0785G and 08041C0805G (eff. 12/7/2018), Flying Horse East has the Unnamed Tributary 107 to Black Squirrel Creek run through the site. Currently, FEMA shows a Zone A floodplain for this stream. Per the El Paso County Land Development Code Chapter 8 Section 8.4.2.B.1.e.i, the base flood elevations for Zone A will be determined once the platted lots are solidified and are confirmed within 300-ft of the current floodplain designation. Certification of the flood elevations will be via the FEMA CLOMR/LOMR process or Floodplain Certification Letter. The FIRM panels described above are shown in Appendix A.

The site has been divided into three major drainage basins based on El Paso county's major basin delineations. These basins were then divided into subbasins based on the locations in which flow was anticipated to enter or leave the site. The existing and proposed subbasin delineations are shown in Appendix F.

### **2. EXISTING SUBBASIN DESCRIPTION**

Within the Livestock Company Basin, flow is generally carried east and southeast throughout the site. On the other side, the Upper East Chico and Drennan Basins flow directly south. Subbasin IDs are labeled as LC (Livestock Company), UEC (Upper East Chico), and Dr (Drennan), followed by a letter. Most of the offsite basins labeled OS are part of the Livestock Company Basin, except for OS9 which contributes to the Upper East Chico. Additionally, OS4, OS5, and OS6 all drain north into OS3; the contributing flows from OS4, OS5, and OS6 were considered in the SWMM modeling. Below in Table 4, details the location, drainage pattern, characteristics, and the 5- and 100-year peak flows of each existing basin.

Table 4 – Existing Drainage Subbasins' Locations and Characteristics

Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS1	An offsite basin located in the northeast corner, just north of Subbasin LC-B. Mainly undeveloped land with some homes and roadways.	Drains southwest towards Subbasin LC-B	423.70	7.68	9.22	230.99
OS2	An offsite basin directly west of Subbasin OS1, just north of the site. Mainly undeveloped land with some homes and roadways.	Drains south towards Subbasin LC-B	100.46	17.40	6.00	55.02
OS3	The major offsite basin northwest of the site, just north of Subbasin LC-A10. Mainly undeveloped land with some homes and roadways.	Drains southwest towards Subbasin LC-B through the natural drainageway	3535.15	8.72	82.90	1831.23
OS4	An offsite basin located west of the site, just east of N Curtis Rd and south of Hwy 94. This subbasin is directly west of Subbasin OS5. Currently an undeveloped area.	Drains north towards a culvert and discharges onto Subbasin OS3. Which eventually drains into the natural drainageway	76.90	5.06	1.62	59.67

Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS5	An offsite basin between Subbasins OS4 and OS6, directly west of the site and south of Hwy 94. Mainly undeveloped land with some homes and roadways.	Drains north towards a low point just south of Hwy 94. No culvert identified but flow anticipated to overtop Hwy 94. This would discharge into Subbasin OS3 and eventually drains into the natural drainageway.	7.78	6.87	0.15	4.20
OS6	An offsite basin between Subbasins OS5 and OS7, directly west of the site and south of Hwy 94. Mainly undeveloped land with some homes and roadways.	Drains north towards a culvert and discharges onto Subbasin OS3. Which eventually drains into the natural drainageway	71.77	3.13	0.43	26.86
OS7	An offsite basin directly west of Subbasin LC-A, just west of Enoch Road. Currently an undeveloped area.	Drains west towards Subbasin LC-A	31.27	12.31	1.88	25.47
OS8	An offsite basin directly west of Subbasin LC-A, just west of Enoch Road, and south of Subbasin OS4. Currently an undeveloped area.	Drains west towards Subbasin LC-A	53.43	11.13	3.86	58.70



Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS9	An offsite basin directly northwest of Subbasin UEC-A, just west of Enoch Road, and south of OS5. Currently an undeveloped area.	Drains west towards Subbasin UEC-A	215.89	5.44	4.20	136.42
LC-A10	In the northwest corner of the site, directly north of Subbasin UEC-A. Mainly undeveloped land with some roadways.	Drains north towards Subbasin OS3 and eventually drains into the natural drainageway	135.30	4.31	1.42	62.55
LC-A20	In the northwest corner of the site, directly east of Subbasin LC-A10. Mainly undeveloped land with one major roadway.	Drains north towards Subbasin OS3 and eventually drains into the natural drainageway	23.35	4.43	0.26	11.42
LC-B	Largest onsite basin in the center of the site. Mainly undeveloped land with a few homes.	Drains southeast into the natural drainageway until draining offsite	1135.72	2.44	9.42	698.54



Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-C	In the northeast corner of the site, between Subbasins OS1 and LC-D. Mainly undeveloped land with one major roadway.	Drains southeast towards the property line	25.36	2.44	0.39	26.19
LC-D	In the northeast corner just south of Subbasin LC-C. Currently an undeveloped area.	Drains southeast towards the property line	20.81	2.00	1.21	25.11
LC-E	On the eastern side of the site directly south of Subbasin LC-D. Currently an undeveloped area.	Drains east towards the property line	26.67	2.00	1.45	31.60
LC-F	On the eastern side of the site directly north of Subbasin LC-G. Currently an undeveloped area.	Drains east towards the property line	94.23	2.00	1.44	111.12



Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-G	In the southeast corner of the site, between Subbasins LC-F and LC-H. Currently an undeveloped area.	Drains east towards the property line	28.37	2.00	0.28	21.94
LC-H	In the southeast corner of the site, directly south of Subbasins LC-G. Currently an undeveloped area.	Drains east towards the property line	14.25	2.00	0.26	18.92
LC-I	In the southeast corner of the site, directly east of Subbasin LC-H. Currently an undeveloped area.	Drains southeast towards Subbasin LC-H and the property line	90.13	2.00	0.77	61.26
UEC-A	In the southeast corner of the site, directly south of Subbasin LC-A. Mainly undeveloped land with one major roadway.	Drains southeast towards Subbasin UEC-B	71.28	3.48	1.04	49.42



Subbasin ID	Location /Characteristics	Drainage Pattern	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
UEC-B	In the southeast corner of the site, between Subbasins UEC-A and UEC-C. Currently an undeveloped area.	Drains south towards the property line	121.88	2.00	0.96	87.55
UEC-C	On the southern edge of the property line, between Subbasins UEC-B and UEC-D. Currently an undeveloped area.	Drains southwest towards the property line	23.23	2.00	0.13	12.30
UEC-D	On the southern edge of the property line, between Subbasins UEC-C and Dr-A. Currently an undeveloped area.	Drains southwest towards the property line	12.69	2.00	0.73	15.19
Dr-A	On the southern edge of the property line, between Subbasins UEC-D and Dr-B. Currently an undeveloped area.	Drains southeast towards the property line	50.27	2.00	0.44	37.13
Dr-B	On the southern edge of the property line, between Subbasins LC-I and Dr-A. Currently an undeveloped area.	Drains southeast towards the property line	18.15	2.00	0.22	17.72



### 3. PROPOSED SUBBASIN DESCRIPTION

The proposed basins reside within the same three major basins: Livestock Company, Upper East Chico, and Drennan. The proposed basins were delineated based on the site plan shown in Figure 1. Four major factors contributed to the delineation of proposed basins. One was the boundary of the existing major basins, second was the location of proposed roadways and greenways, third was the location of the site boundary, and finally was based on the land type. The proposed basins additionally added three more offsite basins. OS10 was added to the northwest corner of the site, which was required to separate the onsite property flow from the flow contributed by the roadway. OS-B1 and OS-B2 were both initially part of the large onsite basin LC-B, however, the site property did not extend into these areas and therefore could not be considered onsite. Additionally, OS1, OS2, and OS3 were slightly adjusted to account for the drainage of Hwy 94 that was initially part of the existing Subbasin LC-B.

Some assumptions were made during the evaluation of CUHP parameters for the proposed basins. The proposed slope and longest flow length were assumed to follow the existing grade and contours. However, in some cases it was assumed that swales would convey the flow to the expected design point which was assumed to be 2% based on El Paso Engineering Criteria for ditch slope (Section 3.3.4). Assumptions made for the proposed SWMM routing are noted within the model descriptions.

Below in Table 5, details the location, drainage pattern, characteristics, and the 5- and 100-year peak flows of each proposed basin. Basin names followed a similar pattern to the existing basins; major drainage basins first and then followed by the existing basin design point plus numerical values to separate each basin. Proposed detention ponds are detailed within the drainage patterns (*Note: proposed detention ponds and culverts will be sized after the approval of the hydrology*).



Table 5 - Proposed Drainage Subbasins' Locations and Characteristics

Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS1	An offsite basin located in the northeast corner, just north of Subbasin LC-B. Mainly undeveloped land with some homes and roadways.	Drains southwest towards Subbasin LC-B50. The proposed flow path will be channelized until discharging into Pond <b>B1</b> .	423.70	7.65	9.17	230.59
OS2	An offsite basin directly west of Subbasin OS1, just north of the site. Mainly undeveloped land with some homes and roadways.	Drains south towards Subbasin LC-B70. The proposed flow path will be channelized until discharging into the natural drainageway.	100.46	17.90	6.27	55.71
OS3	The major offsite basin northwest of the site, just north of Subbasin LC-A10. Mainly undeveloped land with some homes and roadways.	Drains southwest towards Subbasin LC-B100 through the natural drainageway.	3535.15	8.75	83.24	1832.34
OS4	An offsite basin located west of the site, just east of N Curtis Rd and south of Hwy 94. This subbasin is directly west of Subbasin OS5. Currently an undeveloped area.	Drains north towards a culvert and discharges onto Subbasin OS3. Which eventually drains into the natural drainageway.	76.90	5.06	1.62	59.67



Subbasin ID	Location	Drainage Path	Acreeage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS5	An offsite basin between Subbasins OS4 and OS6, directly west of the site and south of Hwy 94. Mainly undeveloped land with some homes and roadways.	Drains north towards a low point just south of Hwy 94. No culvert identified but flow anticipated to overtop Hwy 94. This would discharge into Subbasin OS3 and eventually drains into the natural drainageway.	7.78	6.87	0.15	4.20
OS6	An offsite basin between Subbasins OS5 and OS7, directly west of the site and south of Hwy 94. Mainly undeveloped land with some homes and roadways.	Drains north towards a culvert and discharges onto Subbasin OS3. Which eventually drains into the natural drainageway.	71.77	3.13	0.43	26.86
OS7	An offsite basin directly west of Subbasin LC-A10, just west of Enoch Road. Currently an undeveloped area.	Drains west towards Subbasin LC-A10. Proposed flow path will be channelized until discharging to culvert under Hwy 94.	31.27	12.09	1.84	25.38
OS8	An offsite basin directly west of Subbasin LC-A30, just west of Enoch Road, and south of Subbasin OS4. Currently an undeveloped area.	Drains west towards Subbasin LC-A30. The proposed flow path will be channelized until discharging into Pond <b>A3</b> .	53.43	11.56	4.08	59.07



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
OS9	An offsite basin directly northwest of Subbasin UEC-A10, just west of Enoch Road, and south of OS5. Currently an undeveloped area.	Drains west towards Subbasin UEC-A10. The proposed flow path will be channelized until discharging into Pond <b>UEC</b> .	215.89	4.95	3.80	135.58
OS10	An offsite basin directly northwest of Subbasin LC-A10. Subbasin initially connected to existing Subbasin LC-A10 but was separated at the property line. The area is mainly roadways.	Drains east towards the culvert at the end of Subbasin LC-A10. Flow would discharge into the channelized flow from Subbasin OS7.	1.42	75.57	0.95	2.67
OS-B1	An offsite basin that was initially part of the existing Subbasin LC-B. Basin in northern part of site, just east of Subbasin LC-B130. The area is currently undeveloped.	Drains southeast towards Subbasin LC-B100. Flow will discharge into the natural drainageway.	8.80	2	0.08	7.25
OS-B2	An offsite basin that was initially part of the existing Subbasin LC-B. Basin in northern part of site, just south of Subbasin OS2 and OS1. The area is farmland with one residence.	Drains southeast towards Subbasin LC-B70. Flow will be either channelized or pipe directly to the natural drainageway.	38.55	3.26	0.59	32.70



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-A10	In the northwest corner of the site, directly north of LC-A20. Current planning documents anticipate the area to be commercial.	Drains north towards Pond <b>A1</b> . Will be discharged north towards a culvert under Hwy 94 to Subbasin OS3.	22.91	67.15	31.12	89.75
LC-A20	In the northwest corner of the site, directly between Subbasin LC-A10 and LC-A30. Current planning documents anticipate the area to be high density residential.	Drains north towards Subbasin LC-A10. Flow will be channelized towards Pond <b>A1</b> .	33.65	56.35	22.05	70.78
LC-A25	In the northwest corner of the site, directly east of Subbasin LC-A10. Current planning documents anticipate the area to be mainly high density residential with some commercial.	Drains north towards proposed Pond <b>A2</b> . Flow will be discharged towards Subbasin OS3 and eventually drains into the natural drainageway.	23.35	59.09	16.06	48.69
LC-A30	On the western side of the site, directly south of Subbasin LC-A20. Current planning documents anticipate the area to be mainly medium high density residential.	Drains naturally towards the center of the subbasin which will have proposed Pond <b>A3</b> . The pond outlet will be piped north toward LC-A10.	76.91	40.55	50.19	202.69
LC-B10	On the eastern side of the site directly south of LC-B20. Subbasin resides within the natural drainageway.	Drains southeast into the natural drainageway until draining offsite at the property boundary.	71.02	3.59	1.17	50.36



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-B20	On the northeastern portion of the site directly north of LC-B10. Current planning documents anticipate the area to low density residential.	Drains southeast towards Subbasin LC-B10 and Pond <b>B1</b> . Flow will be discharged from the pond into the natural drainageway.	75.80	19.38	8.45	71.02
LC-B30	Located east of Subbasin LC-F20. Current planning documents anticipate the area to be low density residential.	Drains northeast towards Subbasin LC-B10. The flow will be direct towards Pond <b>F1</b> with Subbasin LC-F20. Flow will be discharged from the pond into the natural drainageway.	47.55	25.52	20.33	99.79
LC-B40	Located southeast of Subbasin LC-B30. Current planning documents anticipate the area to be a business park.	Drains northeast towards Subbasin LC-B30. Flow will be channelized through Subbasin LC-B30 and will discharge into Pond <b>F1</b> .	79.78	58.97	66.69	210.35
LC-B50	On the northeast side of the site, directly south of Subbasin OS1. Current planning documents anticipate the area to be a school.	Drains southeast towards Subbasin LC-B20. Flow will be conveyed through LC-B20 and discharged into Pond <b>B1</b> .	60.13	49.55	40.74	150.29
LC-B60	Located directly northwest of Subbasin LC-B10. Subbasin resides within the natural drainageway.	Drains southeast towards Subbasin LC-B10 within the natural drainageway.	50.06	4.44	2.14	44.51



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-B70	Located directly south of Subbasin OS-B2. Current planning documents anticipate the area to be mostly medium density residential with a small section of commercial.	Drains southeast towards Subbasin LC-B60 and Pond <b>B2</b> . The pond will be discharged into the natural drainageway.	115.66	37.31	34.93	154.75
LC-B80	Located directly south of Subbasin LC-B60. Current planning documents anticipate the area to be medium density residential.	Drains northeast towards Subbasin LC-B60 and Pond <b>B3</b> . The pond will be discharged into the natural drainageway.	87.58	35.96	24.60	120.82
LC-B90	Located directly south of Subbasin LC-B60. Current planning documents anticipate the area to be medium density residential.	Drains northeast towards Subbasin LC-B60 and Pond <b>B4</b> . The pond will be discharged into the natural drainageway.	116.91	36.01	29.93	137.94
LC-B100	Located directly northwest of Subbasin LC-B60. Subbasin resides within the natural drainageway.	Drains southeast towards Subbasin LC-B60 within the natural drainageway.	16.04	3.77	0.25	10.11
LC-B110	On the north side of the site, north of LC-B100. Current planning documents anticipate the area to be medium high density residential.	Drains southeast towards Subbasin LC-B100 and Pond <b>B5</b> . The pond will discharge into the natural drainageway.	40.34	35.71	14.08	65.28



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-B120	Located directly south of Subbasin OS-B1. Current planning documents anticipate the area to be medium density residential.	Drains northeast towards Subbasin LC-B100 and Pond <b>B6</b> . The pond will be discharged into the natural drainageway.	89.59	29.01	19.04	103.80
LC-B130	In the northeast corner of the site, between Subbasins LC-A25 and LC-B120. Current planning documents anticipate the area to be high density.	Drains east towards Subbasin LC-B120. Flow will be channelized through LC-B120 until discharging in Pond <b>B6</b> .	32.88	53.33	12.69	42.94
LC-B140	Located directly south of Subbasin LC-B130. Current planning documents anticipate the area to be medium high density residential.	Drains northeast towards Subbasin LC-B120. Flow will be channelized to Subbasin LC-B150 and discharged into Pond <b>B6</b> .	21.40	43.88	11.79	46.69
LC-B150	Located directly south of Subbasin LC-B120. Current planning documents anticipate the area to be medium density residential.	Drains north towards Subbasin LC-B120. Flow will be channelized through Subbasin LC-B120 and discharged into Pond <b>B6</b> .	32.77	37	13.18	59.16
LC-B160	Located directly south of Subbasin LC-B120. Current planning documents anticipate the area to be medium density residential.	Drains north towards Subbasin LC-B120. Flow will be channelized through Subbasin LC-B120 and discharged into Pond <b>B6</b> .	56.00	37.35	30.50	131.96





Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-B170	Located directly south of Subbasin LC-B140. Current planning documents anticipate the area to be medium high density residential.	Drains north towards Subbasin LC-B140. Flow will be channelized through LC-B140. Flow will be conveyed to Pond <b>B6</b> .	7.32	32.2	1.71	8.74
LC-B180	Located directly south of Subbasin LC-B160. Current planning documents anticipate the area to be medium density residential.	Drains north towards Subbasin LC-B160. Flow will be channelized through Subbasin LC-B160. Flow will be conveyed to Pond <b>B6</b> .	56.49	36.53	31.29	143.01
LC-B190	Located directly south of LC-B90. Current planning documents anticipate the area to be a business park.	Drains north towards Subbasin LC-B90. Flow will be channelized through Subbasin LC-B90 and discharged into Pond <b>B4</b> .	42.56	52.26	41.78	142.63
LC-C10	In the northeast corner of the site, north of Subbasin LC-D10. Current planning documents anticipate the area to be a school.	Drains southeast towards the property line. Flow will be conveyed towards Pond <b>D</b> .	35.83	45.6	20.27	79.80
LC-D10	In the northeast corner just south of Subbasin LC-C10. Current planning documents anticipate the area to be low density residential.	Drains southeast towards the property line and to Pond <b>D</b> .	34.73	22.57	11.34	58.99



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-F10	On the eastern side of the site directly north of Subbasin LC-G10. Current planning documents anticipate the area to be a business park.	Drains east towards the property line and Pond <b>F1</b> .	53.87	59.69	48.28	153.24
LC-F20	Located directly south of Subbasin LC-B10. Current planning documents anticipate the area to be a pond and low density residential.	Drains east towards the property line. The flow will be directed towards Pond <b>F2</b> and discharged into the natural drainageway.	28.47	13.00	1.65	21.43
LC-G10	In the southeast corner of the site, between Subbasins LC-F10 and LC-H10. Current planning documents anticipate the area to be a business park.	Drains east towards the property line and towards Pond <b>G</b> .	27.23	63.28	18.87	58.97
LC-H10	In the southeast corner of the site, directly south of Subbasins LC-G10. Current planning documents anticipate the area to be a business park.	Drains east towards the property line. Flow will be conveyed towards Pond <b>G</b> .	12.49	35.96	5.22	25.24
LC-I10	In the southeast corner of the site, directly east of Subbasin LC-G10. Current planning documents anticipate the area to be a business park.	Drains southeast towards Subbasin LC-H10 and the property line. Flow will be directed towards Pond <b>I</b> .	36.06	50.23	25.93	87.28



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
LC-I20	On the south edge of the property, just east of Subbasin LC-I10. Current planning documents anticipate the area to be a business park.	Drains southeast towards Subbasin LC-I10 and the property line. Flow will be channelized towards Pond I.	53.43	55.82	35.85	121.23
UEC-A10	In the southeast corner of the site, directly south of Subbasin UEC-A20. Current planning documents anticipate the area to be a business park.	Drains southeast towards Subbasin UEC-B10. Flow will be channelized towards Pond <b>UEC</b> .	55.99	52.34	32.34	114.80
UEC-A20	Located directly north of Subbasin UEC-A10. Current planning documents anticipate the area to be medium high density residential.	Drains south towards Subbasin UEC-A10. Flow will be channelized through Subbasin UEC-A10 towards Pond <b>UEC</b> .	20.21	41.41	8.92	34.76
UEC-B10	In the southeast corner of the site, between Subbasins UEC-A10 and UEC-B20. Current planning documents anticipate the area to be a business park.	Drains south towards the property line and towards Pond <b>UEC</b> .	44.52	47.84	24.45	91.59



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
UEC-B20	In the southeast corner of the site, between Subbasins UEC-B10 and UEC-C10. Current planning documents anticipate the area to be a business park.	Drains south towards the property line and towards Pond <b>UEC</b> .	43.60	54.84	30.59	100.29
UEC-B30	Located directly north of Subbasin UEC-B10. Current planning documents anticipate the area to be mixed use.	Drains southeast towards Subbasin UEC-B10. Flow will be channelized towards Pond <b>UEC</b> .	22.90	56.84	20.75	66.13
UEC-B40	Located directly north of Subbasin UEC-B20. Current planning documents anticipate the area to be medium density residential.	Drains southwest towards Subbasin UEC-B20. Flow will be channelized towards Pond <b>UEC</b> .	11.23	33.96	4.99	23.06
UEC-C10	On the southern edge of the property line, between Subbasins UEC-B20 and UEC-D10. Current planning documents anticipate the area to be a business park.	Drains southwest towards the property line. Flow will be channelized towards Pond <b>UEC</b> .	23.57	52.16	12.08	42.23
UEC-D10	On the southern edge of the property line, between Subbasins UEC-C10 and Dr-A10. Current planning documents anticipate the area to be a business park.	Drains southwest towards the property line. Flow will be channelized towards Pond <b>UEC</b> .	12.41	49.51	9.12	30.73



Subbasin ID	Location	Drainage Path	Acreage	Impervious (%)	5-Year Flowrate (cfs)	100-Year Flowrate (cfs)
Dr-A10	On the southern edge of the property line, between Subbasins UEC-D10 and Dr-B10. Current planning documents anticipate the area to be a business park.	Drains southeast towards the property line and to Pond <b>Dr.</b>	51.02	55.85	31.27	106.35
Dr-B10	On the southern edge of the property line, between Subbasins LC-I20 and Dr-A10. Current planning documents anticipate the area to be a business park.	Drains southeast towards the property line. Flow will be conveyed towards Pond <b>Dr.</b>	17.74	47.82	11.07	41.35

The above-mentioned basins are large planning area basins and as drainage reports are developed for the individual developed parcels additional drainage reports and calculations will be required. It is expected that storm drainage infrastructure consisting of inlets, storm sewer and open drainage channels will be constructed as the property develops.

- Mentioned above, offsite basins include basins OS1 through OS10 as well as OS-B1 and OS-B2. Flow contributing to the site from these basins will be routed to the natural drainageway. In some cases, the offsite flow will be routed through the proposed detention ponds. These specific basins, receiving proposed pond, and flow rates are shown in the table below.

Table 6 – Offsite Subbasin Receiving Detention Pond Parameters

Offsite Flow Summary				
Basin Description	Basin Area (ac)	Receiving Detention Pond	5 Year Peak Runoff (cfs)	100 Year Peak Runoff (cfs)
OS1	423.70	Pond B1	9.17	230.59
OS8	53.43	Pond A3	4.08	59.07
OS9	215.89	Pond UEC	3.80	135.58

### c. Basin Hydrology

A summary of the flows for both the predeveloped and developed cases for each basin, subbasin, and proposed ponds are found above in Tables 4 and 5. Below in Table 6 depicts the anticipated subbasins draining to each pond with the expected 5- and 100-year volume for each pond. Full computation found in Appendix B. (*Note: Pond volumes will be determined after the initial review and approval of the hydrology*)

Table 7 – Proposed Detention Pond Volumes with Associated Subbasin Drainage Parameters

Proposed SWMM Basin and Pond Summary						
Basin Description	Basin Area (ac)	% Impervious	5 Year Peak Runoff (cfs)	100 Year Peak Runoff (cfs)	5 Year Pond Volume (ac-ft)	100 Year Pond Volume (ac-ft)
LC-A10	22.91	67.15	31.12	89.75		
LC-A20	33.65	56.35	22.05	70.78		
			<b>Pond A1</b>			
LC-A25	23.35	59.09	16.06	48.69		
			<b>Pond A2</b>			
LC-A30	76.91	40.55	50.19	202.69		
OS8	53.43	11.56	4.08	59.07		
			<b>Pond A3</b>			
OS1	423.70	7.65	9.17	230.59		
LC-B20	75.80	19.38	8.45	71.02		
LC-B50	60.13	49.55	40.74	150.29		
			<b>Pond B1</b>			
LC-B70	115.66	37.31	34.93	154.75		
			<b>Pond B2</b>			



Proposed SWMM Basin and Pond Summary						
Basin Description	Basin Area (ac)	% Impervious	5 Year Peak Runoff (cfs)	100 Year Peak Runoff (cfs)	5 Year Pond Volume (ac-ft)	100 Year Pond Volume (ac-ft)
LC-B80	87.58	35.96	24.60	120.82		
			<b>Pond B3</b>			
LC-B90	116.91	36.01	29.93	137.94		
LC-B190	42.56	52.26	41.78	142.63		
			<b>Pond B4</b>			
LC-B110	40.34	35.71	14.08	65.28		
			<b>Pond B5</b>			
LC-B120	89.59	29.01	19.04	103.80		
LC-B130	32.88	53.33	12.69	42.94		
LC-B140	21.40	43.88	11.79	46.69		
LC-B150	32.77	37	13.18	59.16		
LC-B160	56.00	37.35	30.50	131.96		
LC-B170	7.32	32.2	1.71	8.74		
LC-B180	56.49	36.53	31.29	143.01		
			<b>Pond B6</b>			
LC-C10	35.83	45.6	20.27	79.80		
LC-D10	34.73	22.57	11.34	58.99		
			<b>Pond D</b>			
LC-F10	53.87	59.69	48.28	153.24		
			<b>Pond F1</b>			
LC-B30	47.55	25.52	20.33	99.79		
LC-B40	79.78	58.97	66.69	210.35		
LC-F20	28.47	13.00	1.65	21.43		
			<b>Pond F2</b>			
LC-G10	27.23	63.28	18.87	58.97		
LC-H10	12.49	35.96	5.22	25.24		
			<b>Pond G</b>			
LC-I10	36.06	50.23	25.93	87.28		
LC-I20	53.43	55.82	35.85	121.23		
			<b>Pond I</b>			
OS9	215.89	4.95	3.80	135.58		
UEC-A10	55.99	52.34	32.34	114.80		
UEC-A20	20.21	41.41	8.92	34.76		
UEC-B10	44.52	47.84	24.45	91.59		
UEC-B20	43.60	54.84	30.59	100.29		
UEC-B30	22.90	56.84	20.75	66.13		
UEC-B40	11.23	33.96	4.99	23.06		
UEC-C10	23.57	52.16	12.08	42.23		
UEC-D10	12.41	49.51	9.12	30.73		
			<b>Pond UEC</b>			

Proposed SWMM Basin and Pond Summary						
Basin Description	Basin Area (ac)	% Impervious	5 Year Peak Runoff (cfs)	100 Year Peak Runoff (cfs)	5 Year Pond Volume (ac-ft)	100 Year Pond Volume (ac-ft)
Dr-A10	51.02	55.85	31.27	106.35		
Dr-B10	17.74	47.82	11.07	41.35		
			Pond Dr			
OS2	100.46	17.90	6.27	55.71		
OS3	3535.15	8.75	83.24	1832.34		
OS-B1	8.80	2	0.08	7.25		
OS-B2	38.55	3.26	0.59	32.70		
LC-B10	75.80	19.38	8.45	71.02		
LC-B60	50.06	4.44	2.14	44.51		
LC-B100	16.04	3.77	0.25	10.11		
			Natural Drainage Way			

please provide preliminary analysis and discussion regarding the existing drainageway/floodplain that traverses the site. Provide the existing conditions and identify anticipated infrastructure needed at the road crossings and any improvements that are anticipated to be needed.

## IV. Hydraulic Analysis

### a. Major Drainageways

There is one major drainageways that exists within the development Squirrel Creek. Additionally, two small tertiary tributaries are within the site currently and function to convey flows to unnamed tributaries of the Chico Creek and Black Squirrel Creek.

## V. Environmental Evaluations

### a. Significant Existing or Potential Wetland and Riparian Areas Impacts

As part of this work, the developer has engaged Bristlecone Ecology, LLC to perform environmental studies of the site that will be submitted with the planning documents. Major information in the report concerning wetlands concludes that there is a moderate presence of a wetland in the floodplain of the Unnamed Tributary 107 to Black Squirrel Creek. Additionally, there is a natural lake/pond on the west side of the property that corresponds to a wetland, however this pond is considered non-jurisdictional.

At this time, there are no improvements proposed to the Unnamed Tributary 107 of Black Squirrel Creek. The minimal impact to the stream will keep the natural habitat intact and the natural function of the Creek as it is to maintain the wetland habitat. No major improvements are proposed to the existing wetland pond. Additional runoff will be treated and conveyed north.

### b. Stormwater Quality Considerations and Proposed Practices

As part of the development, full spectrum detention facilities will be installed to provide water quality for the development. The facilities will be designed using El Paso County criteria and provide stormwater quality by slowing the release of stormwater captured by the ponds and allowing solids to settle out. Additionally, when possible, the existing natural drainage ways will be used to convey stormwater to more closely mimic the natural hydrologic and hydraulic cycle. Some of the drainage ways will be used to



convey water to the ponds and others will receive water from the ponds and in both scenarios will provide additional water quality benefits.

On site practices for the homes, schools, churches, and other buildings should use means such that impervious areas drain across pervious area to allow for infiltration during the minor events. This would include discharge of the gutters onto landscape areas vs. directly connecting to storm sewer and as discussed above as well using natural ditches and swales where it is logical and makes sense to convey stormwater in lieu of storm sewer piping.

### **c. Permitting Requirements**

When work infringes upon the wetlands or floodplain a 404 Permit will be required. If the work within the waterways is minimal, it will likely be covered under a nationwide 404 permit; it is however possible that an individual permit will be required.

The Colorado Department of Public Health and Environment will require permits for any disturbance that exceeds 1 acre of land. Should groundwater be encountered, a dewatering permit will also be required.

El Paso County will require an Erosion and Stormwater Quality Control Permit, and any other construction permits required to complete the construction of the site.

Should development occur which affects the floodplain, FEMA will require a permit for work within the floodplain prior to the commencement of any construction or development within any special flood hazard area (SFHA). If the infrastructure is to be installed within the channel the designer shall route the design through the proper FEMA channels whether that be with a no rise certification or via the CLOMR/LOMR process should a more major improvement within the floodplain be proposed. At this time the project does not propose any direct development within the floodplain, however storm infrastructure will discharge into the existing FEMA channel.

### **d. 4-Step Process**

In accordance with the Engineering Criteria Manual I.7.2.A and DCM V2, this site has implemented the four-step process to minimize adverse impacts of urbanization. The four-step process includes reducing runoff volumes, stabilizing drainageways, treating the water quality capture volume, and considering the need for Industrial Commercial BMPs.

**Step 1 – Reducing Runoff Volumes:** The development of the project site includes a variety of land uses including open and vegetated areas interspersed to help disconnect impervious areas and reduce runoff volumes.

**Step 2 – Stabilize Drainageways:** Altered drainage ways will be designed in a manner that provides water quality benefits through infiltration and the removal of pollutants via phytoremediation. Vegetation will also be selected to stabilize the drainage ways by reducing the velocity of flows and decreasing any scour. Should the final drainage ways require, grade control structures may be implemented to further reduce flow velocities and protect against erosion. These improvements will help stabilize drainageways.

**Step 3 – Provide WQCV:** Runoff from this development is treated through capture and slow release of the WQCV via detention ponds that are designed per current El Paso County DCM V2.

**Step 4 – Consider the need for Industrial and Commercial BMP's:** A site-specific storm water quality and erosion control plan and narrative will be prepared with subsequent land use approvals prepared in conjunction with the report prior to any construction. Site specific temporary source control BMPs as well



Please include a discussion drainage problems anticipated within the development and their solutions

as permanent BMPs are detailed in this plan and narrative. Guidelines detailed in the El Paso DCM V2 4.2 pertaining to the covering and storage handline and spill containment and control shall be followed as necessary.

clarify that they will be full-spectrum and include water quality

## VI. Alternatives Evaluation

A DPBS was not developed for any major drainage basins within the project site, therefore, two alternatives were created.

The first alternative is the proposed plan presented above which includes 16 large scale detention ponds. Each pond was properly sized to store runoff and discharge into the natural drainageway at or near the existing conditions before leaving the site.

The second alternative would require smaller scaled detention ponds for each proposed subbasin. In some cases, the subbasins drain to similar areas that would still share a pond, such as Subbasins UEC-B10 and UEC-B20. This alternative could reduce potential issues with routing between subbasins and reduce the size of channels throughout the development. However, adding approximately 20 detention ponds would increase the amount of maintenance required by the county and significantly reduce the amount of developable land. This alternative would not be recommended unless limits to the first alternative are discovered during the preliminary and final drainage reports.

## VII. Selected Plan

### a. Plan Hydrology

The County would not be responsible for maintenance. Likely a Metro District or HOA. Please revise.

This MDDP schematically addressed on-site and off-site drainage patterns using the existing topography and proposed land use plan for the overall drainage design. Individual preliminary and final drainage reports will better define the planning areas as the site is developed.

The overall site is divided into several separate major basins. Proposed onsite basin sizes range from 7.3 acres to 116.9 acres in size. Basins LC-A10 through LC-I20 drain and eventually discharge into an unnamed tributary Black Squirrel Creek and eventually discharge into the Arkansas River. Basins Dr-A10 and Dr-B10 follow a similar path and eventually drain into the Arkansas River. Basins UEC-A10 through UEC-D10 drain towards Chico Creek which also discharges into the Arkansas River.

The subbasins are described in additional detail above.

### b. System Improvements

*This section of the report will be completed after the review and acceptance of the hydrology.*

## VIII. Drawings

Please refer to the appendices for vicinity maps and drainage basin maps.

## IX. Summary

*This section of the report will be completed in future reports.*

please complete the conclusion/summary section.

## X. References

El Paso County – Drainage Criteria Manual, 2014

City of Colorado Springs – Drainage Criteria Manual, May 2014

Urban Storm Drainage Criteria Manual, Urban Drainage Flood Control District, January 2018




# Appendix A

## Maps and Site Photos

Douglas County

Elbert County



### Drainage Basins

#### El Paso County Colorado Legend

- Drainage Basins (source: Muler Engineering Company 1986)
- US Interstate Highways
- US Highways
- Colorado State Highways
- Major Roadways
- Local Streets & Roads
- Creeks**
- Perennial
- Intermittent
- Lakes & Reservoirs
- Summits
- Unincorporated Urban Areas
- Incorporated Cities
- Military
- Forest
- County Lines



Copyright 2007 by the Board of County Commissioners, El Paso County, Colorado. All rights reserved. No part of this document or data contained herein may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the Board of County Commissioners, El Paso County, Colorado. This document was prepared from the best data available at the time of printing. El Paso County, Colorado, makes no claim as to the completeness or accuracy of the data contained herein.

**NOTES TO USERS**

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where **Base Flood Elevations (BFEs)** and/or **floodways** have been determined, users are encouraged to consult the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

**Coastal Base Flood Elevations** shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to section 2.4 "Flood Protection Measures" of the Flood Insurance Study report for information on flood control structures for this jurisdiction.

The **projection** used in the preparation of this map was Universal Transverse Mercator (UTM) zone 13. The **horizontal datum** was NAD83, GRS80 spheroid. Differences in datum, spheroid, projection or UTM zones zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the **North American Vertical Datum of 1988 (NAVD88)**. These flood elevations must be compared to structure and ground elevations referenced to the same **vertical datum**. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at <http://www.ngs.noaa.gov/> or contact the National Geodetic Survey at the following address:

NGS Information Services  
NOAA, NIMS12  
National Geodetic Survey  
SSMC-3, #9202  
1315 East-West Highway  
Silver Spring, MD 20910-3282

To obtain current elevation, description, and/or location information for **bench marks** shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242 or visit its website at <http://www.ngs.noaa.gov/>.

**Base Map** information shown on this FIRM was provided in digital format by El Paso County, Colorado Springs Utilities, and Anderson Consulting Engineers, Inc. These data are current as of 2008.

This map reflects more detailed and up-to-date **stream channel configurations and floodplain delineations** than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables in the Flood Insurance Study Report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map. The profile baselines depicted on this map represent the hydraulic modeling baselines that match the flood profiles and Floodway Data Tables if applicable, in the FIS report. As a result, the profile baselines may deviate significantly from the new base map channel representation and may appear outside of the floodplain.

**Corporate limits** shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels, community map repository addresses, and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.

Contact **FEMA Map Service Center (MSC)** via the FEMA Map Information eXchange (FIMX) 1-877-336-2627 for information on available products associated with this FIRM. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. The MSC may also be reached by Fax at 1-800-358-9620 and its website at <http://www.msc.fema.gov/>.


If you have **questions about this map** or questions concerning the National Flood Insurance Program in general, please call **1-877-FEMA MAP (1-877-336-2627)** or visit the FEMA website at <http://www.fema.gov/business/nfp>.

**El Paso County Vertical Datum Offset Table**


Flooding Source	Vertical Datum Offset (ft)

REFER TO SECTION 3.3 OF THE EL PASO COUNTY FLOOD INSURANCE STUDY FOR STREAM BY STREAM VERTICAL DATUM CONVERSION INFORMATION


**Panel Location Map**



This Digital Flood Insurance Rate Map (DFIRM) was produced through a Cooperating Technical Partner (CTP) agreement between the State of Colorado Water Conservation Board (CWCB) and the Federal Emergency Management Agency (FEMA).



Additional Flood Hazard information and resources are available from local communities and the Colorado Water Conservation Board.



NOTE: MAP AREA SHOWN ON THIS PANEL IS LOCATED WITHIN TOWNSHIP 13 SOUTH, RANGE 64 WEST, AND TOWNSHIP 14 SOUTH, RANGE 64 WEST.

**LEGEND**

**SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD**

The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equalled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.

- ZONE A** No Base Flood Elevations determined.
- ZONE AE** Base Flood Elevations determined.
- ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.
- ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.
- ZONE AR** Special Flood Hazard Area Formerly protected from the 1% annual chance flood by a flood control system that was subsequently decertified. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.
- ZONE A99** Area to be protected from 1% annual chance flood by a Federal flood protection system under construction; no Base Flood Elevations determined.
- ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.
- ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.

**FLOODWAY AREAS IN ZONE AE**

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

**OTHER FLOOD AREAS**

**ZONE X** Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

**OTHER AREAS**

**ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.

**ZONE D** Areas in which flood hazards are undetermined, but possible.

**COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS**

**OTHERWISE PROTECTED AREAS (OPAs)**

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.

- Floodplain boundary
- Floodway boundary
- Zone D Boundary
- CBRS and OPA boundary

Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities.

513 Base Flood Elevation line and value; elevation in feet\* (EL 987)  
Base Flood Elevation value where uniform within zone; elevation in feet\*

\* Referenced to the North American Vertical Datum of 1988 (NAVD 88)

A—A Cross section line

23-23 Transsect line

97° 07' 30.00" Geographic coordinates referenced to the North American Datum of 1983 (NAD 83)

42° 50' 00" N 1000-meter Universal Transverse Mercator grid ticks, zone 13

6000000 FT 5000-foot grid ticks: Colorado State Plane coordinate system, central zone (FIPSZONE 0502), Lambert Conformal Conic Projection

DX5510 Bench mark (see explanation in Notes to Users section of this FIRM panel)

M1.5 River Mile

MAP REPOSITORIES Refer to Map Repositories list on Map Index

EFFECTIVE DATE OF COUNTYWIDE FLOOD INSURANCE RATE MAP MARCH 17, 1997

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL DECEMBER 7, 2018 - to update corporate limits, to change Base Flood Elevations and Special Flood Hazard Areas, to update map format, to add roads and road names, and to incorporate previously issued Letters of Map Revision

For community map revision history prior to countywide mapping, refer to the Community Map History Table located in the Flood Insurance Study report for this jurisdiction.

To determine if flood insurance is available in this community, contact your insurance agent or call the National Flood Insurance Program at 1-800-638-6620.

MAP SCALE 1" = 1000'

500 0 1000 2000 FEET

300 0 300 600 METERS

**NFIP**

**PANEL 0785G**

---

**FIRM**

**FLOOD INSURANCE RATE MAP**

**EL PASO COUNTY, COLORADO AND INCORPORATED AREAS**

**PANEL 785 OF 1300**

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

COMMUNITY	NUMBER	PANEL	SUFFIX
EL PASO COUNTY	080059	0785	G

Notice to User: The Map Number shown below should be used when placing map orders. The Community Number shown above should be used on insurance applications for the subject community.

**MAP NUMBER**  
**08041C0785G**

**MAP REVISED**  
**DECEMBER 7, 2018**

Federal Emergency Management Agency

**NOTES TO USERS**

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where **Base Flood Elevations (BFEs)** and/or **floodways** have been determined, users are encouraged to consult the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

**Coastal Base Flood Elevations** shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to section 2.4 "Flood Protection Measures" of the Flood Insurance Study report for information on flood control structures for this jurisdiction.

The projection used in the preparation of this map was Universal Transverse Mercator (UTM) zone 13. The horizontal datum was NAD83, GRS80 spheroid. Differences in datum, spheroid, projection or UTM zones zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the **North American Vertical Datum of 1988 (NAVD88)**. These flood elevations must be compared to structure and ground elevations referenced to the same **vertical datum**. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at <http://www.ngs.noaa.gov/> or contact the National Geodetic Survey at the following address:

NGS Information Services  
NOAA, NIMS12  
National Geodetic Survey  
SSMC-3, #9202  
1315 East-West Highway  
Silver Spring, MD 20910-3282

To obtain current elevation, description, and/or location information for **bench marks** shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242 or visit its website at <http://www.ngs.noaa.gov/>.

**Base Map** information shown on this FIRM was provided in digital format by El Paso County, Colorado Springs Utilities, and Anderson Consulting Engineers, Inc. These data are current as of 2008.

This map reflects more detailed and up-to-date **stream channel configurations and floodplain delineations** than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables in the Flood Insurance Study Report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map. The profile baselines depicted on this map represent the hydraulic modeling baselines that match the flood profiles and Floodway Data Tables if applicable, in the FIS report. As a result, the profile baselines may deviate significantly from the new base map channel representation and may appear outside of the floodplain.

**Corporate limits** shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.


Contact **FEMA Map Service Center (MSC)** via the FEMA Map Information eXchange (FIMX) 1-877-336-2627 for information on available products associated with this FIRM. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. The MSC may also be reached by Fax at 1-800-358-9620 and its website at <http://www.msc.fema.gov/>.

If you have **questions about this map** or questions concerning the National Flood Insurance Program in general, please call 1-877-FEMA MAP (1-877-336-2627) or visit the FEMA website at <http://www.fema.gov/business/nfp>.

El Paso County Vertical Datum Offset Table	
Flooding Source	Vertical Datum Offset (ft)

REFER TO SECTION 3.3 OF THE EL PASO COUNTY FLOOD INSURANCE STUDY FOR STREAM BY STREAM VERTICAL DATUM CONVERSION INFORMATION


**Panel Location Map**



This Digital Flood Insurance Rate Map (DFIRM) was produced through a Cooperating Technical Partner (CTP) agreement between the State of Colorado Water Conservation Board (CWCB) and the Federal Emergency Management Agency (FEMA).



Additional Flood Hazard information and resources are available from local communities and the Colorado Water Conservation Board.



**LEGEND**

**SPECIAL FLOOD HAZARD AREAS (SFHAS) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD**

The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equalled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AV, A99, V, and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.

**ZONE A** No Base Flood Elevations determined.  
**ZONE AE** Base Flood Elevations determined.  
**ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.  
**ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.  
**ZONE AR** Special Flood Hazard Area Formerly protected from the 1% annual chance flood by a flood control system that was subsequently dewatered. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.  
**ZONE A99** Area to be protected from 1% annual chance flood by a Federal flood protection system under construction; no Base Flood Elevations determined.  
**ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.  
**ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.

**FLOODWAY AREAS IN ZONE AE**

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

**OTHER FLOOD AREAS**

**ZONE X** Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

**OTHER AREAS**

**ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.  
**ZONE D** Areas in which flood hazards are undetermined, but possible.

**COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS**

**OTHERWISE PROTECTED AREAS (OPAs)**

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.

— Floodplain boundary  
 --- Floodway boundary  
 --- Zone D boundary  
 - - - - - CBRS and OPA boundary  
 - - - - - Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities.  
 (EL 987) Base Flood Elevation value where uniform within zone; elevation in feet\*  
 ~~~~~ 513 Base Flood Elevation value where uniform within zone; elevation in feet\*

\* Referenced to the North American Vertical Datum of 1988 (NAVD 88)

— A — A Cross section line  
 (23) — (23) Transsect line  
 97° 07' 30.00" 32° 22' 30.00" Geographic coordinates referenced to the North American Datum of 1983 (NAD 83)  
 4750000N 1000-meter Universal Transverse Mercator grid ticks, zone 13  
 6000000 FT 5000-foot grid ticks: Colorado State Plane coordinate system, central zone (FIPSZONE 0502), Lambert Conformal Conic Projection  
 DX5510 Bench mark (see explanation in Notes to Users section of this FIRM panel)  
 ● M1.5 River Mile

**MAP REPOSITORIES**  
 Refer to Map Repositories list on Map Index  
**EFFECTIVE DATE OF COUNTYWIDE FLOOD INSURANCE RATE MAP**  
**MARCH 17, 1997**  
**EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL**  
**DECEMBER 7, 2018** - to update corporate limits, to change Base Flood Elevations and Special Flood Hazard Areas, to update map format, to add roads and road names, and to incorporate previously issued Letters of Map Revision

For community map revision history prior to countywide mapping, refer to the Community Map History Table located in the Flood Insurance Study report for this jurisdiction.  
 To determine if flood insurance is available in this community, contact your insurance agent or call the National Flood Insurance Program at 1-800-638-6620.

**MAP SCALE 1" = 1000'**

500 0 1000 2000 FEET  
 300 0 300 600 METERS

**NFIP** **PANEL 0805G**


**FIRM**  
**FLOOD INSURANCE RATE MAP**  
**EL PASO COUNTY, COLORADO AND INCORPORATED AREAS**  
**PANEL 805 OF 1300**  
 (SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:  
 COMMUNITY NUMBER PANEL SUFFIX  
 EL PASO COUNTY 08059 0805 0

Notice to User: The Map Number shown below should be used when placing map orders. The Community Number shown above should be used on insurance applications for the subject community.

**MAP NUMBER 08041C0805G**  
**MAP REVISED DECEMBER 7, 2018**  
 Federal Emergency Management Agency

Hydrologic Soil Group—El Paso County Area, Colorado  
(Flying Horse East Soils\_On and Offsite data)



Map Scale: 1:47,800 if printed on A landscape (11" x 8.5") sheet.




Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 13N WGS84



Hydrologic Soil Group—El Paso County Area, Colorado  
(Flying Horse East Soils\_On and Offsite data)

### MAP LEGEND

**Area of Interest (AOI)**









 Area of Interest (AOI)

**Soils**

**Soil Rating Polygons**





-  A
-  A/D
-  B
-  B/D
-  C
-  C/D
-  D
-  Not rated or not available

**Soil Rating Lines**

-  A
-  A/D
-  B
-  B/D
-  C
-  C/D
-  D
-  Not rated or not available

**Soil Rating Points**






-  A
-  A/D
-  B
-  B/D

-  C
-  C/D
-  D
-  Not rated or not available


**Water Features**

 Streams and Canals

**Transportation**

-  Rails
-  Interstate Highways
-  US Routes
-  Major Roads
-  Local Roads

**Background**

 Aerial Photography

### MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service  
Web Soil Survey URL:  
Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: El Paso County Area, Colorado  
Survey Area Data: Version 22, Sep 3, 2024

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Sep 11, 2018—Oct 20, 2018

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

## Hydrologic Soil Group

| Map unit symbol                    | Map unit name                                      | Rating | Acres in AOI   | Percent of AOI |
|------------------------------------|----------------------------------------------------|--------|----------------|----------------|
| 2                                  | Ascalon sandy loam, 1 to 3 percent slopes          | B      | 81.9           | 1.3%           |
| 3                                  | Ascalon sandy loam, 3 to 9 percent slopes          | B      | 45.2           | 0.7%           |
| 8                                  | Blakeland loamy sand, 1 to 9 percent slopes        | A      | 490.9          | 8.1%           |
| 10                                 | Blendon sandy loam, 0 to 3 percent slopes          | B      | 230.1          | 3.8%           |
| 11                                 | Bresser sandy loam, cool, 0 to 3 percent slopes    | B      | 328.4          | 5.4%           |
| 12                                 | Bresser sandy loam, cool, 3 to 5 percent slopes    | B      | 367.2          | 6.1%           |
| 13                                 | Bresser sandy loam, cool, 5 to 9 percent slopes    | B      | 118.0          | 1.9%           |
| 28                                 | Ellicott loamy coarse sand, 0 to 5 percent slopes  | A      | 99.1           | 1.6%           |
| 86                                 | Stoneham sandy loam, 3 to 8 percent slopes         | B      | 99.3           | 1.6%           |
| 89                                 | Tassel fine sandy loam, 3 to 18 percent slopes     | D      | 94.1           | 1.6%           |
| 95                                 | Truckton loamy sand, 1 to 9 percent slopes         | A      | 123.5          | 2.0%           |
| 96                                 | Truckton sandy loam, 0 to 3 percent slopes         | A      | 825.4          | 13.6%          |
| 97                                 | Truckton sandy loam, 3 to 9 percent slopes         | A      | 2,921.9        | 48.2%          |
| 98                                 | Truckton-Blakeland complex, 9 to 20 percent slopes | A      | 61.0           | 1.0%           |
| 100                                | Truckton-Bresser complex, eroded                   | A      | 82.0           | 1.4%           |
| 101                                | Ustic Torrifluvents, loamy                         | B      | 44.8           | 0.7%           |
| 105                                | Vona sandy loam, warm, 3 to 6 percent slopes       | A      | 47.1           | 0.8%           |
| 116                                | Udic Haplusterts                                   | D      | 6.9            | 0.1%           |
| <b>Totals for Area of Interest</b> |                                                    |        | <b>6,066.9</b> | <b>100.0%</b>  |

## Description

Hydrologic soil groups are based on estimates of runoff potential. Soils are assigned to one of four groups according to the rate of water infiltration when the soils are not protected by vegetation, are thoroughly wet, and receive precipitation from long-duration storms.

The soils in the United States are assigned to four groups (A, B, C, and D) and three dual classes (A/D, B/D, and C/D). The groups are defined as follows:

Group A. Soils having a high infiltration rate (low runoff potential) when thoroughly wet. These consist mainly of deep, well drained to excessively drained sands or gravelly sands. These soils have a high rate of water transmission.

Group B. Soils having a moderate infiltration rate when thoroughly wet. These consist chiefly of moderately deep or deep, moderately well drained or well drained soils that have moderately fine texture to moderately coarse texture. These soils have a moderate rate of water transmission.

Group C. Soils having a slow infiltration rate when thoroughly wet. These consist chiefly of soils having a layer that impedes the downward movement of water or soils of moderately fine texture or fine texture. These soils have a slow rate of water transmission.

Group D. Soils having a very slow infiltration rate (high runoff potential) when thoroughly wet. These consist chiefly of clays that have a high shrink-swell potential, soils that have a high water table, soils that have a claypan or clay layer at or near the surface, and soils that are shallow over nearly impervious material. These soils have a very slow rate of water transmission.

If a soil is assigned to a dual hydrologic group (A/D, B/D, or C/D), the first letter is for drained areas and the second is for undrained areas. Only the soils that in their natural condition are in group D are assigned to dual classes.

## Rating Options

*Aggregation Method:* Dominant Condition

*Component Percent Cutoff:* None Specified

*Tie-break Rule:* Higher



**NOAA Atlas 14, Volume 8, Version 2**  
**Location name: Colorado Springs, Colorado, USA\***  
**Latitude: 38.8324°, Longitude: -104.5303°**  
**Elevation: 6396 ft\*\***



\* source: ESRI Maps  
 \*\* source: USGS

**POINT PRECIPITATION FREQUENCY ESTIMATES**

Sanja Perica, Deborah Martin, Sandra Pavlovic, Ishani Roy, Michael St. Laurent, Carl Trypaluk, Dale Unruh, Michael Yekta, Geoffery Bonnin

NOAA, National Weather Service, Silver Spring, Maryland

[PF tabular](#) | [PF graphical](#) | [Maps & aerals](#)

**PF tabular**

| <b>PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)<sup>1</sup></b> |                                            |                               |                               |                               |                               |                               |                              |                              |                             |                             |
|----------------------------------------------------------------------------------------------------------------|--------------------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|------------------------------|------------------------------|-----------------------------|-----------------------------|
| <b>Duration</b>                                                                                                | <b>Average recurrence interval (years)</b> |                               |                               |                               |                               |                               |                              |                              |                             |                             |
|                                                                                                                | <b>1</b>                                   | <b>2</b>                      | <b>5</b>                      | <b>10</b>                     | <b>25</b>                     | <b>50</b>                     | <b>100</b>                   | <b>200</b>                   | <b>500</b>                  | <b>1000</b>                 |
| <b>5-min</b>                                                                                                   | <b>0.242</b><br>(0.197-0.301)              | <b>0.295</b><br>(0.239-0.367) | <b>0.386</b><br>(0.313-0.482) | <b>0.468</b><br>(0.377-0.586) | <b>0.588</b><br>(0.460-0.771) | <b>0.688</b><br>(0.524-0.910) | <b>0.792</b><br>(0.582-1.07) | <b>0.905</b><br>(0.636-1.26) | <b>1.06</b><br>(0.717-1.51) | <b>1.19</b><br>(0.778-1.71) |
| <b>10-min</b>                                                                                                  | <b>0.354</b><br>(0.288-0.441)              | <b>0.431</b><br>(0.351-0.537) | <b>0.566</b><br>(0.458-0.706) | <b>0.685</b><br>(0.552-0.858) | <b>0.861</b><br>(0.674-1.13)  | <b>1.01</b><br>(0.767-1.33)   | <b>1.16</b><br>(0.853-1.57)  | <b>1.32</b><br>(0.932-1.84)  | <b>1.55</b><br>(1.05-2.22)  | <b>1.74</b><br>(1.14-2.50)  |
| <b>15-min</b>                                                                                                  | <b>0.432</b><br>(0.352-0.538)              | <b>0.526</b><br>(0.428-0.655) | <b>0.690</b><br>(0.559-0.861) | <b>0.835</b><br>(0.673-1.05)  | <b>1.05</b><br>(0.822-1.38)   | <b>1.23</b><br>(0.935-1.62)   | <b>1.42</b><br>(1.04-1.92)   | <b>1.62</b><br>(1.14-2.24)   | <b>1.90</b><br>(1.28-2.70)  | <b>2.12</b><br>(1.39-3.05)  |
| <b>30-min</b>                                                                                                  | <b>0.628</b><br>(0.511-0.781)              | <b>0.763</b><br>(0.620-0.950) | <b>0.999</b><br>(0.809-1.25)  | <b>1.21</b><br>(0.974-1.52)   | <b>1.52</b><br>(1.19-1.99)    | <b>1.78</b><br>(1.35-2.35)    | <b>2.05</b><br>(1.50-2.77)   | <b>2.34</b><br>(1.64-3.24)   | <b>2.74</b><br>(1.85-3.91)  | <b>3.06</b><br>(2.01-4.41)  |
| <b>60-min</b>                                                                                                  | <b>0.812</b><br>(0.661-1.01)               | <b>0.973</b><br>(0.791-1.21)  | <b>1.26</b><br>(1.02-1.58)    | <b>1.53</b><br>(1.23-1.92)    | <b>1.94</b><br>(1.53-2.56)    | <b>2.28</b><br>(1.75-3.04)    | <b>2.66</b><br>(1.96-3.61)   | <b>3.06</b><br>(2.16-4.27)   | <b>3.64</b><br>(2.46-5.20)  | <b>4.10</b><br>(2.69-5.91)  |
| <b>2-hr</b>                                                                                                    | <b>0.996</b><br>(0.816-1.23)               | <b>1.18</b><br>(0.969-1.46)   | <b>1.53</b><br>(1.25-1.90)    | <b>1.86</b><br>(1.50-2.31)    | <b>2.36</b><br>(1.88-3.10)    | <b>2.80</b><br>(2.16-3.70)    | <b>3.27</b><br>(2.43-4.43)   | <b>3.79</b><br>(2.69-5.26)   | <b>4.54</b><br>(3.10-6.45)  | <b>5.15</b><br>(3.40-7.36)  |
| <b>3-hr</b>                                                                                                    | <b>1.09</b><br>(0.898-1.34)                | <b>1.28</b><br>(1.06-1.58)    | <b>1.65</b><br>(1.35-2.04)    | <b>2.00</b><br>(1.63-2.48)    | <b>2.56</b><br>(2.05-3.37)    | <b>3.05</b><br>(2.37-4.04)    | <b>3.59</b><br>(2.68-4.86)   | <b>4.19</b><br>(3.00-5.80)   | <b>5.06</b><br>(3.47-7.18)  | <b>5.77</b><br>(3.83-8.22)  |
| <b>6-hr</b>                                                                                                    | <b>1.25</b><br>(1.03-1.52)                 | <b>1.45</b><br>(1.20-1.78)    | <b>1.86</b><br>(1.53-2.28)    | <b>2.25</b><br>(1.85-2.77)    | <b>2.89</b><br>(2.33-3.78)    | <b>3.45</b><br>(2.70-4.55)    | <b>4.08</b><br>(3.08-5.49)   | <b>4.78</b><br>(3.45-6.59)   | <b>5.80</b><br>(4.02-8.20)  | <b>6.65</b><br>(4.45-9.41)  |
| <b>12-hr</b>                                                                                                   | <b>1.40</b><br>(1.17-1.70)                 | <b>1.64</b><br>(1.36-1.98)    | <b>2.09</b><br>(1.73-2.54)    | <b>2.52</b><br>(2.08-3.08)    | <b>3.21</b><br>(2.61-4.16)    | <b>3.82</b><br>(3.01-4.98)    | <b>4.49</b><br>(3.40-5.99)   | <b>5.23</b><br>(3.80-7.15)   | <b>6.30</b><br>(4.40-8.84)  | <b>7.20</b><br>(4.85-10.1)  |
| <b>24-hr</b>                                                                                                   | <b>1.58</b><br>(1.32-1.90)                 | <b>1.85</b><br>(1.55-2.22)    | <b>2.34</b><br>(1.96-2.83)    | <b>2.82</b><br>(2.34-3.42)    | <b>3.54</b><br>(2.89-4.54)    | <b>4.17</b><br>(3.30-5.39)    | <b>4.86</b><br>(3.71-6.42)   | <b>5.61</b><br>(4.10-7.60)   | <b>6.69</b><br>(4.70-9.30)  | <b>7.58</b><br>(5.15-10.6)  |
| <b>2-day</b>                                                                                                   | <b>1.80</b><br>(1.53-2.16)                 | <b>2.11</b><br>(1.78-2.52)    | <b>2.66</b><br>(2.24-3.19)    | <b>3.16</b><br>(2.65-3.81)    | <b>3.94</b><br>(3.22-4.98)    | <b>4.59</b><br>(3.66-5.87)    | <b>5.30</b><br>(4.07-6.94)   | <b>6.07</b><br>(4.47-8.15)   | <b>7.17</b><br>(5.07-9.89)  | <b>8.07</b><br>(5.53-11.2)  |
| <b>3-day</b>                                                                                                   | <b>1.96</b><br>(1.67-2.34)                 | <b>2.30</b><br>(1.95-2.74)    | <b>2.90</b><br>(2.46-3.47)    | <b>3.45</b><br>(2.90-4.14)    | <b>4.27</b><br>(3.50-5.37)    | <b>4.96</b><br>(3.96-6.30)    | <b>5.70</b><br>(4.39-7.41)   | <b>6.49</b><br>(4.80-8.67)   | <b>7.62</b><br>(5.41-10.4)  | <b>8.53</b><br>(5.87-11.8)  |
| <b>4-day</b>                                                                                                   | <b>2.11</b><br>(1.80-2.50)                 | <b>2.47</b><br>(2.10-2.93)    | <b>3.10</b><br>(2.64-3.70)    | <b>3.68</b><br>(3.10-4.40)    | <b>4.54</b><br>(3.73-5.68)    | <b>5.25</b><br>(4.20-6.64)    | <b>6.01</b><br>(4.65-7.79)   | <b>6.83</b><br>(5.06-9.09)   | <b>7.99</b><br>(5.68-10.9)  | <b>8.92</b><br>(6.16-12.3)  |
| <b>7-day</b>                                                                                                   | <b>2.50</b><br>(2.14-2.95)                 | <b>2.89</b><br>(2.48-3.41)    | <b>3.58</b><br>(3.06-4.24)    | <b>4.20</b><br>(3.56-4.99)    | <b>5.12</b><br>(4.23-6.36)    | <b>5.88</b><br>(4.74-7.39)    | <b>6.70</b><br>(5.21-8.62)   | <b>7.57</b><br>(5.64-10.0)   | <b>8.80</b><br>(6.30-11.9)  | <b>9.78</b><br>(6.80-13.4)  |
| <b>10-day</b>                                                                                                  | <b>2.84</b><br>(2.44-3.33)                 | <b>3.26</b><br>(2.81-3.84)    | <b>4.01</b><br>(3.44-4.73)    | <b>4.68</b><br>(3.98-5.54)    | <b>5.66</b><br>(4.69-6.99)    | <b>6.47</b><br>(5.23-8.08)    | <b>7.32</b><br>(5.71-9.38)   | <b>8.24</b><br>(6.16-10.8)   | <b>9.52</b><br>(6.84-12.9)  | <b>10.5</b><br>(7.36-14.4)  |
| <b>20-day</b>                                                                                                  | <b>3.74</b><br>(3.24-4.36)                 | <b>4.33</b><br>(3.75-5.06)    | <b>5.32</b><br>(4.59-6.23)    | <b>6.16</b><br>(5.29-7.25)    | <b>7.36</b><br>(6.12-8.96)    | <b>8.31</b><br>(6.74-10.3)    | <b>9.28</b><br>(7.28-11.7)   | <b>10.3</b><br>(7.74-13.4)   | <b>11.7</b><br>(8.43-15.6)  | <b>12.7</b><br>(8.96-17.3)  |
| <b>30-day</b>                                                                                                  | <b>4.49</b><br>(3.91-5.22)                 | <b>5.22</b><br>(4.54-6.06)    | <b>6.40</b><br>(5.55-7.46)    | <b>7.38</b><br>(6.36-8.64)    | <b>8.74</b><br>(7.27-10.5)    | <b>9.78</b><br>(7.96-12.0)    | <b>10.8</b><br>(8.51-13.6)   | <b>11.9</b><br>(8.97-15.3)   | <b>13.3</b><br>(9.65-17.7)  | <b>14.4</b><br>(10.2-19.4)  |
| <b>45-day</b>                                                                                                  | <b>5.47</b><br>(4.78-6.33)                 | <b>6.34</b><br>(5.53-7.33)    | <b>7.72</b><br>(6.72-8.97)    | <b>8.85</b><br>(7.66-10.3)    | <b>10.4</b><br>(8.64-12.4)    | <b>11.5</b><br>(9.39-14.0)    | <b>12.6</b><br>(9.95-15.7)   | <b>13.7</b><br>(10.4-17.6)   | <b>15.1</b><br>(11.0-20.0)  | <b>16.2</b><br>(11.5-21.8)  |
| <b>60-day</b>                                                                                                  | <b>6.33</b><br>(5.55-7.30)                 | <b>7.29</b><br>(6.39-8.42)    | <b>8.82</b><br>(7.70-10.2)    | <b>10.0</b><br>(8.72-11.7)    | <b>11.7</b><br>(9.74-13.9)    | <b>12.9</b><br>(10.5-15.6)    | <b>14.0</b><br>(11.1-17.4)   | <b>15.1</b><br>(11.5-19.3)   | <b>16.6</b><br>(12.1-21.7)  | <b>17.6</b><br>(12.5-23.6)  |





<sup>1</sup> Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.

[Back to Top](#)

**PF graphical**

### PDS-based depth-duration-frequency (DDF) curves


Latitude: 38.8324°, Longitude: -104.5303°



[Back to Top](#)

## Maps & aerials

Small scale terrain




Large scale terrain



Large scale map



Large scale aerial




[Back to Top](#)

---

[US Department of Commerce](#)  
[National Oceanic and Atmospheric Administration](#)  
[National Weather Service](#)  
[National Water Center](#)  
1325 East West Highway  
Silver Spring, MD 20910  
Questions?: [HDSC.Questions@noaa.gov](mailto:HDSC.Questions@noaa.gov)

[Disclaimer](#)




Mosaic: Esri, TomTom, GeoRip, GeoBridle, GeoTechnologies, Inc, INDEP, NASA, USGS, EPA, NPS, U.S. Census Bureau, USDA, USFWS, 6 S 8 5 6

1/HJHQG

- ([LVWLQJ %DVLQV
- ▨ 6LVH \$UHD
- 1/&' ,PSHUYLRXV
- 6XUIDFHV
- 1RQ URDG LPSHUYLRXV KRPHV
- 3ULPDU\ URDG
- 6HFRQQDU\ URDG
- 7HUWLDU\ URDG
- 7KLQQHG URDG
- 8QGHHORSHG



)O\LQJ +RUVH (DVW  
([LVWLQJ 1/&' /DQG 8VH



6KHHW



Flying Horse East  
Site Photos



Flying Horse East  
Site Photos



Flying Horse East  
Site Photos





## Appendix B

# Hydrology Calculations

*CUHP Input Parameters for the Existing Subbasins Flying Horse East*

**Summary of CUHP Input Parameters (Version 2.0.1)**

| Catchment Name/ID | SWMM Node/ID | Area (sq.mi.) | Dist. to Centroid (miles) | Length (miles) | Slope (ft./ft.) | Percent Imperv. | Depression Storage |                  | Horton's Infiltration Parameters |                      |                       | DCIA Level and Fractions |                              |                        |                      |
|-------------------|--------------|---------------|---------------------------|----------------|-----------------|-----------------|--------------------|------------------|----------------------------------|----------------------|-----------------------|--------------------------|------------------------------|------------------------|----------------------|
|                   |              |               |                           |                |                 |                 | Pervious (inches)  | Imperv. (inches) | Initial Rate (in./hr.)           | Final Rate (in./hr.) | Decay Coeff. (1/sec.) | DCIA Level               | Dir. Con'ct Imperv. Fraction | Receiv. Perv. Fraction | Percent Eff. Imperv. |
| OS1               | OS1          | 0.662         | 0.642                     | 1.439          | 0.017           | 7.7             | 0.40               | 0.10             | 4.97                             | 0.98                 | 0.0008                | 0.00                     | 0.15                         | 0.08                   | 5.04                 |
| OS2               | OS2          | 0.157         | 0.596                     | 0.860          | 0.019           | 17.4            | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.35                         | 0.12                   | 13.12                |
| OS3               | OS3          | 5.524         | 1.660                     | 3.442          | 0.014           | 8.7             | 0.40               | 0.10             | 4.87                             | 0.93                 | 0.0009                | 0.00                     | 0.17                         | 0.09                   | 5.78                 |
| OS4               | OS4          | 0.120         | 0.258                     | 0.410          | 0.029           | 5.1             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.10                         | 0.05                   | 3.23                 |
| OS5               | OS5          | 0.012         | 0.123                     | 0.232          | 0.024           | 6.9             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.14                         | 0.07                   | 4.47                 |
| OS6               | OS6          | 0.112         | 0.237                     | 0.654          | 0.003           | 3.1             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.06                         | 0.03                   | 1.96                 |
| OS7               | OS7          | 0.049         | 0.333                     | 0.487          | 0.019           | 12.3            | 0.40               | 0.10             | 4.71                             | 0.77                 | 0.0013                | 0.00                     | 0.25                         | 0.11                   | 9.35                 |
| OS8               | OS8          | 0.083         | 0.176                     | 0.359          | 0.024           | 11.1            | 0.40               | 0.10             | 4.90                             | 0.92                 | 0.0009                | 0.00                     | 0.22                         | 0.10                   | 7.65                 |
| OS9               | OS9          | 0.337         | 0.623                     | 1.214          | 0.008           | 5.4             | 0.40               | 0.10             | 4.77                             | 0.82                 | 0.0012                | 0.00                     | 0.11                         | 0.05                   | 3.74                 |
| LC-A10            | LC_A10       | 0.211         | 0.492                     | 1.057          | 0.005           | 4.3             | 0.40               | 0.10             | 4.82                             | 0.91                 | 0.0009                | 0.00                     | 0.09                         | 0.04                   | 2.73                 |
| LC-A20            | LC_A20       | 0.036         | 0.242                     | 0.407          | 0.029           | 4.4             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.09                         | 0.04                   | 2.81                 |
| LC-B              | LC_B         | 1.775         | 0.984                     | 2.448          | 0.012           | 2.4             | 0.40               | 0.10             | 4.80                             | 0.84                 | 0.0011                | 0.00                     | 0.05                         | 0.02                   | 1.60                 |
| LC-C              | LC_C         | 0.040         | 0.132                     | 0.262          | 0.021           | 2.4             | 0.40               | 0.10             | 4.84                             | 0.87                 | 0.0011                | 0.00                     | 0.05                         | 0.02                   | 1.56                 |
| LC-D              | LC_D         | 0.033         | 0.171                     | 0.263          | 0.019           | 2.0             | 0.40               | 0.10             | 4.50                             | 0.60                 | 0.0018                | 0.00                     | 0.04                         | 0.02                   | 1.51                 |
| LC-E              | LC_E         | 0.042         | 0.143                     | 0.279          | 0.008           | 2.0             | 0.40               | 0.10             | 4.50                             | 0.60                 | 0.0018                | 0.00                     | 0.04                         | 0.02                   | 1.51                 |
| LC-F              | LC_F         | 0.147         | 0.277                     | 0.492          | 0.029           | 2.0             | 0.40               | 0.10             | 4.76                             | 0.81                 | 0.0012                | 0.00                     | 0.04                         | 0.02                   | 1.34                 |
| LC-G              | LC_G         | 0.044         | 0.283                     | 0.493          | 0.017           | 2.0             | 0.40               | 0.10             | 4.65                             | 0.72                 | 0.0015                | 0.00                     | 0.04                         | 0.02                   | 1.42                 |
| LC-H              | LC_H         | 0.022         | 0.058                     | 0.328          | 0.024           | 2.0             | 0.40               | 0.10             | 4.66                             | 0.73                 | 0.0014                | 0.00                     | 0.04                         | 0.02                   | 1.42                 |
| LC-I              | LC_I         | 0.141         | 0.678                     | 0.935          | 0.018           | 2.0             | 0.40               | 0.10             | 4.65                             | 0.72                 | 0.0015                | 0.00                     | 0.04                         | 0.02                   | 1.42                 |
| UEC-A             | UEC_A        | 0.111         | 0.538                     | 0.770          | 0.019           | 3.5             | 0.40               | 0.10             | 4.72                             | 0.78                 | 0.0013                | 0.00                     | 0.07                         | 0.03                   | 2.42                 |
| UEC-B             | UEC_B        | 0.190         | 0.350                     | 0.707          | 0.030           | 2.0             | 0.40               | 0.10             | 4.95                             | 0.96                 | 0.0008                | 0.00                     | 0.04                         | 0.02                   | 1.24                 |
| UEC-C             | UEC_C        | 0.036         | 0.243                     | 0.462          | 0.026           | 2.0             | 0.40               | 0.10             | 4.93                             | 0.95                 | 0.0008                | 0.00                     | 0.04                         | 0.02                   | 1.24                 |
| UEC-D             | UEC_D        | 0.020         | 0.106                     | 0.238          | 0.015           | 2.0             | 0.40               | 0.10             | 4.50                             | 0.60                 | 0.0018                | 0.00                     | 0.04                         | 0.02                   | 1.51                 |
| Dr-A              | Dr_A         | 0.079         | 0.321                     | 0.587          | 0.017           | 2.0             | 0.40               | 0.10             | 4.78                             | 0.82                 | 0.0012                | 0.00                     | 0.04                         | 0.02                   | 1.33                 |
| Dr-B              | Dr_B         | 0.028         | 0.142                     | 0.270          | 0.027           | 2.0             | 0.40               | 0.10             | 4.80                             | 0.84                 | 0.0011                | 0.00                     | 0.04                         | 0.02                   | 1.31                 |

CUHP Existing Subbasins Flying Horse East Results - 5 Year

**Summary of Unit Hydrograph Parameters Used By Program and Calculated Results (Version 2.0.1)**

| Catchment Name/ID | User Comment for Catchment | Unit Hydrograph Parameters and Results |       |            |                 |            |                 |                     |            |               | Excess Precip.  |               | Storm Hydrograph    |                 |                     |                                 |
|-------------------|----------------------------|----------------------------------------|-------|------------|-----------------|------------|-----------------|---------------------|------------|---------------|-----------------|---------------|---------------------|-----------------|---------------------|---------------------------------|
|                   |                            | CT                                     | Cp    | W50 (min.) | W50 Before Peak | W75 (min.) | W75 Before Peak | Time to Peak (min.) | Peak (cfs) | Volume (c.f.) | Excess (Inches) | Excess (c.f.) | Time to Peak (min.) | Peak Flow (cfs) | Total Volume (c.f.) | Runoff per Unit Area (cfs/acre) |
| OS1               |                            | 0.144                                  | 0.295 | 59.0       | 13.67           | 30.7       | 9.66            | 22.8                | 337        | 1,538,031     | 0.03            | 50,834        | 51.0                | 9               | 50,834              | 0.02                            |
| OS2               |                            | 0.121                                  | 0.164 | 65.2       | 8.49            | 33.9       | 6.00            | 14.2                | 72         | 364,670       | 0.11            | 41,126        | 48.0                | 6               | 41,125              | 0.06                            |
| OS3               |                            | 0.142                                  | 0.548 | 78.2       | 27.37           | 40.7       | 18.30           | 55.4                | 2,119      | 12,832,595    | 0.04            | 573,175       | 82.0                | 83              | 573,174             | 0.02                            |
| OS4               |                            | 0.151                                  | 0.174 | 32.3       | 4.62            | 16.8       | 3.27            | 7.7                 | 112        | 279,147       | 0.02            | 4,959         | 36.0                | 2               | 4,959               | 0.02                            |
| OS5               |                            | 0.146                                  | 0.060 | 50.5       | 2.65            | 26.2       | 1.87            | 4.4                 | 7          | 28,241        | 0.03            | 737           | 36.0                | 0               | 737                 | 0.02                            |
| OS6               |                            | 0.156                                  | 0.174 | 70.0       | 9.66            | 36.4       | 6.83            | 16.1                | 48         | 260,525       | 0.01            | 2,584         | 45.0                | 0               | 2,584               | 0.01                            |
| OS7               |                            | 0.128                                  | 0.101 | 64.7       | 5.31            | 33.6       | 3.75            | 8.8                 | 23         | 113,510       | 0.11            | 11,927        | 45.0                | 2               | 11,927              | 0.06                            |
| OS8               |                            | 0.135                                  | 0.134 | 30.9       | 3.47            | 16.0       | 2.45            | 5.8                 | 81         | 193,951       | 0.06            | 12,405        | 34.0                | 4               | 12,404              | 0.07                            |
| OS9               |                            | 0.149                                  | 0.248 | 77.3       | 15.04           | 40.2       | 10.63           | 25.1                | 131        | 783,681       | 0.04            | 27,637        | 56.0                | 4               | 27,637              | 0.02                            |
| LC-A10            |                            | 0.153                                  | 0.221 | 84.3       | 14.61           | 43.8       | 10.32           | 24.3                | 75         | 491,139       | 0.02            | 10,083        | 54.0                | 1               | 10,083              | 0.01                            |
| LC-A20            |                            | 0.153                                  | 0.103 | 53.5       | 4.53            | 27.8       | 3.20            | 7.6                 | 20         | 84,776        | 0.02            | 1,272         | 37.0                | 0               | 1,272               | 0.01                            |
| LC-B              |                            | 0.157                                  | 0.429 | 74.9       | 25.01           | 39.0       | 17.67           | 41.7                | 710        | 4,122,649     | 0.01            | 57,152        | 68.0                | 9               | 57,152              | 0.01                            |
| LC-C              |                            | 0.157                                  | 0.110 | 33.6       | 3.14            | 17.5       | 2.22            | 5.2                 | 35         | 92,057        | 0.01            | 1,152         | 35.0                | 0               | 1,152               | 0.02                            |
| LC-D              |                            | 0.157                                  | 0.101 | 42.8       | 3.61            | 22.3       | 2.55            | 6.0                 | 23         | 75,540        | 0.06            | 4,459         | 40.0                | 1               | 4,459               | 0.06                            |
| LC-E              |                            | 0.157                                  | 0.113 | 43.9       | 4.10            | 22.8       | 2.90            | 6.8                 | 28         | 96,812        | 0.06            | 5,489         | 40.0                | 1               | 5,489               | 0.05                            |
| LC-F              |                            | 0.158                                  | 0.200 | 33.3       | 5.40            | 17.3       | 3.82            | 9.0                 | 133        | 342,055       | 0.01            | 4,283         | 38.0                | 1               | 4,283               | 0.02                            |
| LC-G              |                            | 0.158                                  | 0.116 | 66.0       | 6.19            | 34.3       | 4.37            | 10.3                | 20         | 102,983       | 0.02            | 1,690         | 47.0                | 0               | 1,690               | 0.01                            |
| LC-H              |                            | 0.158                                  | 0.085 | 31.7       | 2.37            | 16.5       | 1.68            | 4.0                 | 21         | 51,728        | 0.02            | 835           | 36.0                | 0               | 835                 | 0.02                            |
| LC-I              |                            | 0.158                                  | 0.195 | 79.7       | 12.25           | 41.4       | 8.66            | 20.4                | 53         | 327,172       | 0.02            | 5,370         | 57.0                | 1               | 5,370               | 0.01                            |
| UEC-A             |                            | 0.154                                  | 0.172 | 71.4       | 9.71            | 37.1       | 6.86            | 16.2                | 47         | 258,746       | 0.03            | 6,479         | 51.0                | 1               | 6,479               | 0.01                            |
| UEC-B             |                            | 0.158                                  | 0.222 | 39.9       | 7.08            | 20.7       | 5.01            | 11.8                | 143        | 442,424       | 0.01            | 3,207         | 39.0                | 1               | 3,207               | 0.01                            |
| UEC-C             |                            | 0.158                                  | 0.107 | 58.8       | 5.11            | 30.6       | 3.61            | 8.5                 | 19         | 84,325        | 0.01            | 644           | 37.0                | 0               | 644                 | 0.01                            |
| UEC-D             |                            | 0.157                                  | 0.081 | 43.0       | 2.97            | 22.4       | 2.10            | 4.9                 | 14         | 46,065        | 0.06            | 2,719         | 39.0                | 1               | 2,719               | 0.06                            |
| Dr-A              |                            | 0.158                                  | 0.150 | 59.0       | 7.12            | 30.7       | 5.03            | 11.9                | 40         | 182,480       | 0.01            | 2,215         | 44.0                | 0               | 2,215               | 0.01                            |
| Dr-B              |                            | 0.158                                  | 0.095 | 38.6       | 3.12            | 20.1       | 2.20            | 5.2                 | 22         | 65,885        | 0.01            | 734           | 36.0                | 0               | 734                 | 0.01                            |

CUHP Existing Subbasins Flying Horse East Results - 100 Year

**Summary of Unit Hydrograph Parameters Used By Program and Calculated Results (Version 2.0.1)**

| Catchment Name/ID | User Comment for Catchment | Unit Hydrograph Parameters and Results |       |               |                       |               |                       |                           |            |                  | Excess Precip.     |                  | Storm Hydrograph          |                    |                           |                                       |
|-------------------|----------------------------|----------------------------------------|-------|---------------|-----------------------|---------------|-----------------------|---------------------------|------------|------------------|--------------------|------------------|---------------------------|--------------------|---------------------------|---------------------------------------|
|                   |                            | CT                                     | Cp    | W50<br>(min.) | W50<br>Before<br>Peak | W75<br>(min.) | W75<br>Before<br>Peak | Time to<br>Peak<br>(min.) | Peak (cfs) | Volume<br>(c.f.) | Excess<br>(Inches) | Excess<br>(c.f.) | Time to<br>Peak<br>(min.) | Peak Flow<br>(cfs) | Total<br>Volume<br>(c.f.) | Runoff per<br>Unit Area<br>(cfs/acre) |
| OS1               |                            | 0.140                                  | 0.288 | 58.8          | 13.29                 | 30.6          | 9.39                  | 22.1                      | 338        | 1,538,031        | 0.75               | 1,149,730        | 58.0                      | 231                | 1,149,729                 | 0.55                                  |
| OS2               |                            | 0.118                                  | 0.162 | 64.4          | 8.31                  | 33.5          | 5.88                  | 13.9                      | 73         | 364,670          | 0.87               | 317,087          | 54.0                      | 55                 | 317,081                   | 0.55                                  |
| OS3               |                            | 0.136                                  | 0.531 | 77.8          | 27.24                 | 40.5          | 18.21                 | 53.4                      | 2,129      | 12,832,595       | 0.91               | 11,722,956       | 87.0                      | 1,831              | 11,722,899                | 0.52                                  |
| OS4               |                            | 0.148                                  | 0.172 | 32.2          | 4.55                  | 16.8          | 3.21                  | 7.6                       | 112        | 279,147          | 0.62               | 174,315          | 44.0                      | 60                 | 174,311                   | 0.78                                  |
| OS5               |                            | 0.143                                  | 0.059 | 50.4          | 2.59                  | 26.2          | 1.83                  | 4.3                       | 7          | 28,241           | 0.65               | 18,492           | 46.0                      | 4                  | 18,493                    | 0.54                                  |
| OS6               |                            | 0.154                                  | 0.172 | 70.0          | 9.56                  | 36.4          | 6.75                  | 15.9                      | 48         | 260,525          | 0.59               | 152,552          | 54.0                      | 27                 | 152,552                   | 0.37                                  |
| OS7               |                            | 0.125                                  | 0.099 | 64.2          | 5.16                  | 33.4          | 3.65                  | 8.6                       | 23         | 113,510          | 1.35               | 152,780          | 55.0                      | 25                 | 152,777                   | 0.81                                  |
| OS8               |                            | 0.129                                  | 0.129 | 30.6          | 3.33                  | 15.9          | 2.35                  | 5.5                       | 82         | 193,951          | 0.97               | 188,640          | 43.0                      | 59                 | 188,633                   | 1.10                                  |
| OS9               |                            | 0.146                                  | 0.244 | 77.1          | 14.74                 | 40.1          | 10.42                 | 24.6                      | 131        | 783,681          | 1.15               | 898,547          | 68.0                      | 136                | 898,541                   | 0.63                                  |
| LC-A10            |                            | 0.150                                  | 0.217 | 84.2          | 14.34                 | 43.8          | 10.13                 | 23.9                      | 75         | 491,139          | 0.90               | 440,383          | 68.0                      | 63                 | 440,381                   | 0.46                                  |
| LC-A20            |                            | 0.150                                  | 0.102 | 53.4          | 4.47                  | 27.8          | 3.16                  | 7.4                       | 20         | 84,776           | 0.61               | 51,654           | 47.0                      | 11                 | 51,654                    | 0.49                                  |
| LC-B              |                            | 0.156                                  | 0.425 | 74.9          | 24.77                 | 38.9          | 17.50                 | 41.3                      | 711        | 4,122,649        | 1.05               | 4,335,372        | 77.0                      | 699                | 4,335,367                 | 0.62                                  |
| LC-C              |                            | 0.156                                  | 0.109 | 33.6          | 3.11                  | 17.5          | 2.20                  | 5.2                       | 35         | 92,057           | 0.98               | 90,142           | 44.0                      | 26                 | 90,138                    | 1.03                                  |
| LC-D              |                            | 0.157                                  | 0.100 | 42.8          | 3.60                  | 22.3          | 2.54                  | 6.0                       | 23         | 75,540           | 1.46               | 110,658          | 48.0                      | 25                 | 110,658                   | 1.21                                  |
| LC-E              |                            | 0.157                                  | 0.112 | 43.9          | 4.08                  | 22.8          | 2.88                  | 6.8                       | 28         | 96,812           | 1.46               | 141,376          | 49.0                      | 32                 | 141,369                   | 1.18                                  |
| LC-F              |                            | 0.157                                  | 0.198 | 33.3          | 5.36                  | 17.3          | 3.79                  | 8.9                       | 133        | 342,055          | 1.11               | 379,656          | 46.0                      | 111                | 379,650                   | 1.18                                  |
| LC-G              |                            | 0.157                                  | 0.115 | 66.0          | 6.15                  | 34.3          | 4.34                  | 10.2                      | 20         | 102,983          | 1.28               | 131,799          | 57.0                      | 22                 | 131,797                   | 0.77                                  |
| LC-H              |                            | 0.157                                  | 0.085 | 31.7          | 2.36                  | 16.5          | 1.67                  | 3.9                       | 21         | 51,728           | 1.27               | 65,644           | 43.0                      | 19                 | 65,643                    | 1.33                                  |
| LC-I              |                            | 0.157                                  | 0.194 | 79.7          | 12.17                 | 41.4          | 8.60                  | 20.3                      | 53         | 327,172          | 1.28               | 418,784          | 68.0                      | 61                 | 418,781                   | 0.68                                  |
| UEC-A             |                            | 0.152                                  | 0.170 | 71.3          | 9.60                  | 37.1          | 6.78                  | 16.0                      | 47         | 258,746          | 1.20               | 310,988          | 62.0                      | 49                 | 310,987                   | 0.69                                  |
| UEC-B             |                            | 0.157                                  | 0.220 | 39.8          | 7.03                  | 20.7          | 4.97                  | 11.7                      | 143        | 442,424          | 0.70               | 309,985          | 49.0                      | 88                 | 309,980                   | 0.72                                  |
| UEC-C             |                            | 0.157                                  | 0.106 | 58.8          | 5.07                  | 30.6          | 3.58                  | 8.5                       | 19         | 84,325           | 0.74               | 62,738           | 51.0                      | 12                 | 62,737                    | 0.53                                  |
| UEC-D             |                            | 0.157                                  | 0.080 | 43.0          | 2.95                  | 22.4          | 2.08                  | 4.9                       | 14         | 46,065           | 1.46               | 67,479           | 48.0                      | 15                 | 67,475                    | 1.20                                  |
| Dr-A              |                            | 0.157                                  | 0.149 | 59.0          | 7.07                  | 30.7          | 4.99                  | 11.8                      | 40         | 182,480          | 1.09               | 199,207          | 55.0                      | 37                 | 199,205                   | 0.74                                  |
| Dr-B              |                            | 0.157                                  | 0.094 | 38.6          | 3.10                  | 20.0          | 2.19                  | 5.2                       | 22         | 65,885           | 1.04               | 68,431           | 46.0                      | 18                 | 68,425                    | 0.98                                  |

*CUHP Input Parameters for the Proposed Subbasins Flying Horse East*

**Summary of CUHP Input Parameters (Version 2.0.1)**

| Catchment Name/ID | SWMM Node/ID | Area (sq.mi.) | Dist. to Centroid (miles) | Length (miles) | Slope (ft./ft.) | Percent Imperv. | Depression Storage |                  | Horton's Infiltration Parameters |                      |                       | DCIA Level and Fractions |                              |                        |                      |
|-------------------|--------------|---------------|---------------------------|----------------|-----------------|-----------------|--------------------|------------------|----------------------------------|----------------------|-----------------------|--------------------------|------------------------------|------------------------|----------------------|
|                   |              |               |                           |                |                 |                 | Pervious (inches)  | Imperv. (inches) | Initial Rate (in./hr.)           | Final Rate (in./hr.) | Decay Coeff. (1/sec.) | DCIA Level               | Dir. Con'ct Imperv. Fraction | Receiv. Perv. Fraction | Percent Eff. Imperv. |
| OS1               | OS1          | 0.662         | 0.642                     | 1.439          | 0.017           | 7.7             | 0.40               | 0.10             | 4.97                             | 0.98                 | 0.0008                | 0.00                     | 0.15                         | 0.08                   | 5.02                 |
| OS2               | OS2          | 0.157         | 0.596                     | 0.860          | 0.019           | 17.9            | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.36                         | 0.12                   | 13.57                |
| OS3               | OS3          | 5.524         | 1.660                     | 3.442          | 0.014           | 8.8             | 0.40               | 0.10             | 4.87                             | 0.93                 | 0.0009                | 0.00                     | 0.18                         | 0.09                   | 5.80                 |
| OS4               | OS4          | 0.120         | 0.258                     | 0.410          | 0.029           | 5.1             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.10                         | 0.05                   | 3.23                 |
| OS5               | OS5          | 0.012         | 0.123                     | 0.232          | 0.024           | 6.9             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.14                         | 0.07                   | 4.47                 |
| OS6               | OS6          | 0.112         | 0.237                     | 0.654          | 0.003           | 3.1             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.06                         | 0.03                   | 1.96                 |
| OS7               | OS7          | 0.049         | 0.333                     | 0.487          | 0.019           | 12.1            | 0.40               | 0.10             | 4.71                             | 0.77                 | 0.0013                | 0.00                     | 0.24                         | 0.11                   | 9.15                 |
| OS8               | OS8          | 0.083         | 0.176                     | 0.359          | 0.024           | 11.6            | 0.40               | 0.10             | 4.90                             | 0.92                 | 0.0009                | 0.00                     | 0.23                         | 0.10                   | 8.01                 |
| OS9               | OS9          | 0.337         | 0.623                     | 1.214          | 0.008           | 5.0             | 0.40               | 0.10             | 4.77                             | 0.82                 | 0.0012                | 0.00                     | 0.10                         | 0.05                   | 3.39                 |
| OS10              | OS10         | 0.002         | 0.148                     | 0.181          | 0.032           | 75.6            | 0.40               | 0.10             | 4.53                             | 0.62                 | 0.0017                | 0.00                     | 0.93                         | 0.32                   | 74.05                |
| OS-B1             | OS_B1        | 0.014         | 0.089                     | 0.168          | 0.045           | 2.0             | 0.40               | 0.10             | 4.97                             | 0.98                 | 0.0008                | 0.00                     | 0.04                         | 0.02                   | 1.24                 |
| OS-B2             | OS_B2        | 0.060         | 0.134                     | 0.249          | 0.022           | 3.3             | 0.40               | 0.10             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.07                         | 0.03                   | 2.04                 |
| LC-A10            | LC_A10       | 0.036         | 0.091                     | 0.252          | 0.033           | 67.2            | 0.35               | 0.10             | 4.70                             | 0.76                 | 0.0014                | 0.00                     | 0.91                         | 0.29                   | 65.03                |
| LC-A20            | LC_A20       | 0.053         | 0.116                     | 0.509          | 0.005           | 56.4            | 0.35               | 0.05             | 4.89                             | 0.91                 | 0.0009                | 0.00                     | 0.88                         | 0.26                   | 53.25                |
| LC-A25            | LC_A25       | 0.036         | 0.242                     | 0.407          | 0.029           | 59.1            | 0.35               | 0.05             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.90                         | 0.27                   | 56.17                |
| LC-A30            | LC_A30       | 0.120         | 0.082                     | 0.395          | 0.012           | 40.6            | 0.35               | 0.05             | 4.82                             | 0.96                 | 0.0008                | 0.00                     | 0.80                         | 0.20                   | 36.94                |
| LC-B10            | LC_B10       | 0.111         | 0.430                     | 0.778          | 0.007           | 3.6             | 0.40               | 0.10             | 4.58                             | 0.67                 | 0.0016                | 0.00                     | 0.07                         | 0.04                   | 2.66                 |
| LC-B20            | LC_B20       | 0.118         | 0.375                     | 0.740          | 0.013           | 19.4            | 0.35               | 0.05             | 4.75                             | 0.80                 | 0.0013                | 0.00                     | 0.39                         | 0.13                   | 15.60                |
| LC-B30            | LC_B30       | 0.074         | 0.124                     | 0.394          | 0.030           | 25.5            | 0.35               | 0.05             | 4.52                             | 0.62                 | 0.0018                | 0.00                     | 0.51                         | 0.15                   | 22.38                |
| LC-B40            | LC_B40       | 0.125         | 0.362                     | 0.619          | 0.023           | 59.0            | 0.35               | 0.10             | 4.58                             | 0.66                 | 0.0016                | 0.00                     | 0.89                         | 0.27                   | 56.97                |
| LC-B50            | LC_B50       | 0.094         | 0.201                     | 0.446          | 0.012           | 49.6            | 0.35               | 0.10             | 4.67                             | 0.73                 | 0.0014                | 0.00                     | 0.85                         | 0.23                   | 46.95                |
| LC-B60            | LC_B60       | 0.078         | 0.267                     | 0.601          | 0.008           | 4.4             | 0.40               | 0.10             | 4.52                             | 0.62                 | 0.0017                | 0.00                     | 0.09                         | 0.04                   | 3.37                 |
| LC-B70            | LC_B70       | 0.181         | 0.415                     | 0.786          | 0.014           | 37.3            | 0.35               | 0.05             | 4.96                             | 0.97                 | 0.0008                | 0.00                     | 0.75                         | 0.19                   | 33.26                |
| LC-B80            | LC_B80       | 0.137         | 0.474                     | 0.867          | 0.019           | 36.0            | 0.35               | 0.05             | 4.72                             | 0.78                 | 0.0013                | 0.00                     | 0.72                         | 0.19                   | 32.49                |
| LC-B90            | LC_B90       | 0.183         | 0.578                     | 0.889          | 0.022           | 36.0            | 0.35               | 0.05             | 4.96                             | 0.97                 | 0.0008                | 0.00                     | 0.72                         | 0.19                   | 31.79                |
| LC-B100           | LC_B100      | 0.025         | 0.251                     | 0.461          | 0.007           | 3.8             | 0.40               | 0.10             | 4.57                             | 0.66                 | 0.0016                | 0.00                     | 0.08                         | 0.04                   | 2.80                 |
| LC-B110           | LC_B110      | 0.063         | 0.172                     | 0.407          | 0.016           | 35.7            | 0.35               | 0.05             | 4.91                             | 0.93                 | 0.0009                | 0.00                     | 0.71                         | 0.19                   | 31.45                |
| LC-B120           | LC_B120      | 0.140         | 0.324                     | 0.564          | 0.023           | 29.0            | 0.35               | 0.05             | 5.00                             | 1.00                 | 0.0007                | 0.00                     | 0.58                         | 0.17                   | 24.27                |
| LC-B130           | LC_B130      | 0.051         | 0.536                     | 0.743          | 0.023           | 53.3            | 0.35               | 0.05             | 4.95                             | 0.96                 | 0.0008                | 0.00                     | 0.87                         | 0.24                   | 50.06                |
| LC-B140           | LC_B140      | 0.033         | 0.143                     | 0.286          | 0.015           | 43.9            | 0.35               | 0.05             | 4.69                             | 0.75                 | 0.0014                | 0.00                     | 0.82                         | 0.21                   | 41.09                |
| LC-B150           | LC_B150      | 0.051         | 0.156                     | 0.393          | 0.025           | 37.0            | 0.35               | 0.05             | 4.88                             | 0.91                 | 0.0010                | 0.00                     | 0.74                         | 0.19                   | 32.90                |
| LC-B160           | LC_B160      | 0.088         | 0.094                     | 0.469          | 0.031           | 37.4            | 0.35               | 0.05             | 4.94                             | 0.95                 | 0.0008                | 0.00                     | 0.75                         | 0.19                   | 33.30                |
| LC-B170           | LC_B170      | 0.011         | 0.087                     | 0.295          | 0.026           | 32.2            | 0.35               | 0.05             | 4.96                             | 0.97                 | 0.0008                | 0.00                     | 0.64                         | 0.18                   | 27.61                |
| LC-B180           | LC_B180      | 0.088         | 0.141                     | 0.327          | 0.023           | 36.5            | 0.35               | 0.05             | 4.74                             | 0.79                 | 0.0013                | 0.00                     | 0.73                         | 0.19                   | 33.07                |
| LC-B190           | LC_B190      | 0.066         | 0.067                     | 0.346          | 0.022           | 52.3            | 0.35               | 0.10             | 4.91                             | 0.93                 | 0.0009                | 0.00                     | 0.86                         | 0.24                   | 48.94                |
| LC-C10            | LC_C10       | 0.056         | 0.168                     | 0.380          | 0.015           | 45.6            | 0.35               | 0.10             | 4.74                             | 0.79                 | 0.0013                | 0.00                     | 0.83                         | 0.22                   | 42.67                |
| LC-D10            | LC_D10       | 0.054         | 0.107                     | 0.244          | 0.005           | 22.6            | 0.35               | 0.05             | 4.50                             | 0.60                 | 0.0018                | 0.00                     | 0.45                         | 0.14                   | 19.56                |
| LC-F10            | LC_F10       | 0.084         | 0.240                     | 0.492          | 0.029           | 59.7            | 0.35               | 0.10             | 4.75                             | 0.80                 | 0.0013                | 0.00                     | 0.90                         | 0.27                   | 57.28                |
| LC-F20            | LC_F20       | 0.044         | 0.247                     | 0.446          | 0.011           | 13.0            | 0.40               | 0.05             | 4.80                             | 0.84                 | 0.0011                | 0.00                     | 0.26                         | 0.11                   | 9.57                 |
| LC-G10            | LC_G10       | 0.043         | 0.284                     | 0.494          | 0.017           | 63.3            | 0.35               | 0.10             | 4.64                             | 0.71                 | 0.0015                | 0.00                     | 0.91                         | 0.28                   | 61.24                |
| LC-H10            | LC_H10       | 0.020         | 0.088                     | 0.274          | 0.024           | 36.0            | 0.35               | 0.10             | 4.67                             | 0.73                 | 0.0014                | 0.00                     | 0.72                         | 0.19                   | 32.72                |



|         |         |       |       |       |       |      |      |      |      |      |        |      |      |      |       |
|---------|---------|-------|-------|-------|-------|------|------|------|------|------|--------|------|------|------|-------|
| LC-I10  | LC_I10  | 0.056 | 0.211 | 0.357 | 0.013 | 50.2 | 0.35 | 0.10 | 4.50 | 0.60 | 0.0018 | 0.00 | 0.85 | 0.23 | 48.09 |
| LC-I20  | LC_I20  | 0.083 | 0.321 | 0.576 | 0.024 | 55.8 | 0.35 | 0.10 | 4.76 | 0.80 | 0.0012 | 0.00 | 0.88 | 0.25 | 53.17 |
| UEC-A10 | UEC_A10 | 0.087 | 0.327 | 0.635 | 0.015 | 52.3 | 0.35 | 0.10 | 4.61 | 0.69 | 0.0016 | 0.00 | 0.86 | 0.24 | 49.98 |
| UEC-A20 | UEC_A20 | 0.032 | 0.128 | 0.300 | 0.018 | 41.4 | 0.35 | 0.05 | 5.00 | 1.00 | 0.0007 | 0.00 | 0.81 | 0.20 | 37.81 |
| UEC-B10 | UEC_B10 | 0.070 | 0.250 | 0.521 | 0.030 | 47.8 | 0.35 | 0.10 | 4.86 | 0.89 | 0.0010 | 0.00 | 0.84 | 0.22 | 44.40 |
| UEC-B20 | UEC_B20 | 0.068 | 0.213 | 0.455 | 0.025 | 54.8 | 0.35 | 0.10 | 4.99 | 0.99 | 0.0007 | 0.00 | 0.87 | 0.25 | 51.65 |
| UEC-B30 | UEC_B30 | 0.036 | 0.143 | 0.235 | 0.042 | 56.8 | 0.35 | 0.10 | 5.00 | 1.00 | 0.0007 | 0.00 | 0.88 | 0.26 | 53.77 |
| UEC-B40 | UEC_B40 | 0.018 | 0.037 | 0.214 | 0.024 | 34.0 | 0.35 | 0.05 | 5.00 | 1.00 | 0.0007 | 0.00 | 0.68 | 0.18 | 29.52 |
| UEC-C10 | UEC_C10 | 0.037 | 0.243 | 0.462 | 0.026 | 52.2 | 0.35 | 0.10 | 4.93 | 0.95 | 0.0008 | 0.00 | 0.86 | 0.24 | 48.84 |
| UEC-D10 | UEC_D10 | 0.019 | 0.106 | 0.238 | 0.015 | 49.5 | 0.35 | 0.10 | 4.50 | 0.60 | 0.0018 | 0.00 | 0.85 | 0.23 | 47.36 |
| Dr-A10  | Dr_A10  | 0.080 | 0.321 | 0.587 | 0.017 | 55.9 | 0.35 | 0.10 | 4.78 | 0.82 | 0.0012 | 0.00 | 0.88 | 0.25 | 53.13 |
| Dr-B10  | Dr_B10  | 0.028 | 0.142 | 0.270 | 0.027 | 47.8 | 0.35 | 0.10 | 4.81 | 0.85 | 0.0011 | 0.00 | 0.84 | 0.22 | 44.65 |

*CUHP Proposed Subbasins Flying Horse East Results - 5 Year*

**Summary of Unit Hydrograph Parameters Used By Program and Calculated Results (Version 2.0.1)**

| Catchment Name/ID | User Comment for Catchment | Unit Hydrograph Parameters and Results |       |            |                 |            |                 |                     |            |               | Excess Precip.  |               | Storm Hydrograph    |                 |                     |                                 |
|-------------------|----------------------------|----------------------------------------|-------|------------|-----------------|------------|-----------------|---------------------|------------|---------------|-----------------|---------------|---------------------|-----------------|---------------------|---------------------------------|
|                   |                            | CT                                     | Cp    | W50 (min.) | W50 Before Peak | W75 (min.) | W75 Before Peak | Time to Peak (min.) | Peak (cfs) | Volume (c.f.) | Excess (inches) | Excess (c.f.) | Time to Peak (min.) | Peak Flow (cfs) | Total Volume (c.f.) | Runoff per Unit Area (cfs/acre) |
| OS1               |                            | 0.144                                  | 0.295 | 59.0       | 13.68           | 30.7       | 9.66            | 22.8                | 337        | 1,538,031     | 0.03            | 50,524        | 51.0                | 9               | 50,523              | 0.02                            |
| OS2               |                            | 0.120                                  | 0.163 | 65.0       | 8.44            | 33.8       | 5.97            | 14.1                | 72         | 364,670       | 0.12            | 43,044        | 48.0                | 6               | 43,043              | 0.06                            |
| OS3               |                            | 0.141                                  | 0.548 | 78.2       | 27.36           | 40.7       | 18.29           | 55.4                | 2,120      | 12,832,595    | 0.04            | 575,659       | 82.0                | 83              | 575,658             | 0.02                            |
| OS4               |                            | 0.151                                  | 0.174 | 32.3       | 4.62            | 16.8       | 3.27            | 7.7                 | 112        | 279,147       | 0.02            | 4,959         | 36.0                | 2               | 4,959               | 0.02                            |
| OS5               |                            | 0.146                                  | 0.060 | 50.5       | 2.65            | 26.2       | 1.87            | 4.4                 | 7          | 28,241        | 0.03            | 737           | 36.0                | 0               | 737                 | 0.02                            |
| OS6               |                            | 0.156                                  | 0.174 | 70.0       | 9.66            | 36.4       | 6.83            | 16.1                | 48         | 260,525       | 0.01            | 2,584         | 45.0                | 0               | 2,584               | 0.01                            |
| OS7               |                            | 0.129                                  | 0.101 | 64.7       | 5.34            | 33.7       | 3.77            | 8.9                 | 23         | 113,510       | 0.10            | 11,635        | 45.0                | 2               | 11,635              | 0.06                            |
| OS8               |                            | 0.133                                  | 0.133 | 30.8       | 3.44            | 16.0       | 2.43            | 5.7                 | 81         | 193,951       | 0.07            | 13,164        | 34.0                | 4               | 13,163              | 0.08                            |
| OS9               |                            | 0.150                                  | 0.250 | 77.3       | 15.17           | 40.2       | 10.72           | 25.3                | 131        | 783,681       | 0.03            | 24,923        | 56.0                | 4               | 24,923              | 0.02                            |
| OS10              |                            | 0.079                                  | 0.040 | 36.9       | 1.44            | 19.2       | 1.02            | 2.4                 | 2          | 5,143         | 0.96            | 4,941         | 36.0                | 1               | 4,941               | 0.67                            |
| OS-B1             |                            | 0.158                                  | 0.069 | 30.1       | 1.89            | 15.7       | 1.34            | 3.2                 | 14         | 31,939        | 0.01            | 215           | 32.0                | 0               | 215                 | 0.01                            |
| OS-B2             |                            | 0.155                                  | 0.131 | 27.2       | 3.05            | 14.2       | 2.15            | 5.1                 | 66         | 139,924       | 0.01            | 1,455         | 33.0                | 1               | 1,455               | 0.02                            |
| LC-A10            |                            | 0.082                                  | 0.135 | 10.5       | 1.39            | 5.5        | 0.98            | 2.3                 | 102        | 83,170        | 0.83            | 68,926        | 30.0                | 31              | 68,928              | 1.36                            |
| LC-A20            |                            | 0.087                                  | 0.149 | 25.2       | 3.18            | 13.1       | 2.25            | 5.3                 | 63         | 122,144       | 0.69            | 83,746        | 33.0                | 22              | 83,738              | 0.66                            |
| LC-A25            |                            | 0.085                                  | 0.129 | 23.9       | 2.67            | 12.4       | 1.89            | 4.4                 | 46         | 84,776        | 0.71            | 60,344        | 32.0                | 16              | 60,340              | 0.69                            |
| LC-A30            |                            | 0.095                                  | 0.178 | 13.9       | 2.20            | 7.2        | 1.55            | 3.7                 | 260        | 279,201       | 0.46            | 127,326       | 31.0                | 50              | 127,309             | 0.65                            |
| LC-B10            |                            | 0.153                                  | 0.171 | 82.4       | 11.09           | 42.8       | 7.84            | 18.5                | 40         | 257,805       | 0.03            | 8,664         | 58.0                | 1               | 8,664               | 0.02                            |
| LC-B20            |                            | 0.117                                  | 0.142 | 59.2       | 6.76            | 30.8       | 4.78            | 11.3                | 60         | 275,150       | 0.19            | 51,956        | 45.0                | 8               | 51,956              | 0.11                            |
| LC-B30            |                            | 0.107                                  | 0.113 | 24.2       | 2.40            | 12.6       | 1.69            | 4.0                 | 92         | 172,614       | 0.36            | 62,045        | 33.0                | 20              | 62,041              | 0.43                            |
| LC-B40            |                            | 0.085                                  | 0.226 | 21.3       | 3.99            | 11.1       | 2.82            | 6.7                 | 176        | 289,609       | 0.75            | 216,956       | 34.0                | 67              | 216,917             | 0.84                            |
| LC-B50            |                            | 0.090                                  | 0.182 | 20.8       | 3.21            | 10.8       | 2.27            | 5.3                 | 136        | 218,284       | 0.60            | 130,262       | 33.0                | 41              | 130,244             | 0.68                            |
| LC-B60            |                            | 0.150                                  | 0.143 | 64.9       | 7.44            | 33.7       | 5.26            | 12.4                | 36         | 181,718       | 0.07            | 12,411        | 48.0                | 2               | 12,411              | 0.04                            |
| LC-B70            |                            | 0.097                                  | 0.201 | 36.6       | 5.93            | 19.0       | 4.19            | 9.9                 | 148        | 419,855       | 0.40            | 168,156       | 38.0                | 35              | 168,154             | 0.30                            |
| LC-B80            |                            | 0.097                                  | 0.175 | 44.2       | 6.22            | 23.0       | 4.40            | 10.4                | 93         | 317,932       | 0.41            | 131,695       | 41.0                | 25              | 131,689             | 0.28                            |
| LC-B90            |                            | 0.098                                  | 0.196 | 42.5       | 6.70            | 22.1       | 4.74            | 11.2                | 129        | 424,366       | 0.38            | 160,633       | 41.0                | 30              | 160,631             | 0.26                            |
| LC-B100           |                            | 0.153                                  | 0.087 | 94.8       | 6.64            | 49.3       | 4.69            | 11.1                | 8          | 58,224        | 0.04            | 2,094         | 57.0                | 0               | 2,094               | 0.02                            |
| LC-B110           |                            | 0.098                                  | 0.121 | 28.7       | 2.96            | 14.9       | 2.09            | 4.9                 | 66         | 146,446       | 0.38            | 55,665        | 33.0                | 14              | 55,660              | 0.35                            |
| LC-B120           |                            | 0.105                                  | 0.150 | 35.8       | 4.42            | 18.6       | 3.13            | 7.4                 | 117        | 325,211       | 0.26            | 86,126        | 36.0                | 19              | 86,124              | 0.21                            |
| LC-B130           |                            | 0.088                                  | 0.143 | 45.7       | 5.33            | 23.7       | 3.76            | 8.9                 | 34         | 119,350       | 0.63            | 75,639        | 41.0                | 13              | 75,637              | 0.39                            |
| LC-B140           |                            | 0.093                                  | 0.107 | 23.9       | 2.26            | 12.4       | 1.60            | 3.8                 | 42         | 77,672        | 0.53            | 41,554        | 32.0                | 12              | 41,552              | 0.55                            |
| LC-B150           |                            | 0.097                                  | 0.113 | 25.7       | 2.53            | 13.3       | 1.79            | 4.2                 | 60         | 118,960       | 0.41            | 48,218        | 32.0                | 13              | 48,220              | 0.40                            |
| LC-B160           |                            | 0.097                                  | 0.145 | 16.2       | 2.10            | 8.4        | 1.49            | 3.5                 | 162        | 203,284       | 0.40            | 82,145        | 31.0                | 31              | 82,132              | 0.54                            |
| LC-B170           |                            | 0.102                                  | 0.052 | 38.2       | 1.82            | 19.8       | 1.29            | 3.0                 | 9          | 26,576        | 0.32            | 8,448         | 35.0                | 2               | 8,448               | 0.23                            |
| LC-B180           |                            | 0.097                                  | 0.145 | 17.8       | 2.28            | 9.3        | 1.61            | 3.8                 | 149        | 205,046       | 0.42            | 86,174        | 31.0                | 31              | 86,172              | 0.55                            |
| LC-B190           |                            | 0.089                                  | 0.159 | 10.7       | 1.61            | 5.6        | 1.14            | 2.7                 | 187        | 154,479       | 0.60            | 93,045        | 30.0                | 42              | 92,981              | 0.98                            |
| LC-C10            |                            | 0.092                                  | 0.137 | 22.9       | 2.71            | 11.9       | 1.92            | 4.5                 | 73         | 130,056       | 0.53            | 69,437        | 33.0                | 20              | 69,436              | 0.57                            |
| LC-D10            |                            | 0.111                                  | 0.098 | 32.5       | 2.76            | 16.9       | 1.95            | 4.6                 | 50         | 126,082       | 0.33            | 42,148        | 36.0                | 11              | 42,147              | 0.33                            |
| LC-F10            |                            | 0.085                                  | 0.190 | 17.6       | 2.86            | 9.1        | 2.02            | 4.8                 | 144        | 195,539       | 0.72            | 141,700       | 32.0                | 48              | 141,669             | 0.90                            |
| LC-F20            |                            | 0.128                                  | 0.096 | 63.0       | 4.95            | 32.7       | 3.50            | 8.3                 | 21         | 103,341       | 0.10            | 10,043        | 42.0                | 2               | 10,042              | 0.06                            |
| LC-G10            |                            | 0.083                                  | 0.143 | 28.3       | 3.42            | 14.7       | 2.41            | 5.7                 | 45         | 98,833        | 0.79            | 77,716        | 35.0                | 19              | 77,711              | 0.69                            |
| LC-H10            |                            | 0.097                                  | 0.073 | 25.5       | 1.73            | 13.2       | 1.22            | 2.9                 | 23         | 45,346        | 0.41            | 18,741        | 32.0                | 5               | 18,737              | 0.42                            |
| LC-I10            |                            | 0.089                                  | 0.147 | 23.2       | 2.91            | 12.1       | 2.06            | 4.8                 | 73         | 130,899       | 0.67            | 87,224        | 33.0                | 26              | 87,207              | 0.72                            |
| LC-I20            |                            | 0.087                                  | 0.183 | 24.2       | 3.70            | 12.6       | 2.62            | 6.2                 | 104        | 193,959       | 0.67            | 129,911       | 34.0                | 36              | 129,907             | 0.67                            |
| UEC-A10           |                            | 0.088                                  | 0.182 | 29.3       | 4.40            | 15.2       | 3.11            | 7.3                 | 90         | 203,233       | 0.65            | 132,014       | 36.0                | 32              | 132,016             | 0.58                            |
| UEC-A20           |                            | 0.094                                  | 0.099 | 24.6       | 2.17            | 12.8       | 1.53            | 3.6                 | 38         | 73,359        | 0.46            | 33,688        | 32.0                | 9               | 33,683              | 0.44                            |
| UEC-B10           |                            | 0.091                                  | 0.155 | 24.1       | 3.16            | 12.5       | 2.23            | 5.3                 | 87         | 161,592       | 0.55            | 88,450        | 33.0                | 24              | 88,444              | 0.55                            |
| UEC-B20           |                            | 0.087                                  | 0.165 | 19.6       | 2.78            | 10.2       | 1.96            | 4.6                 | 105        | 158,286       | 0.63            | 99,285        | 32.0                | 31              | 99,267              | 0.70                            |
| UEC-B30           |                            | 0.086                                  | 0.126 | 13.6       | 1.61            | 7.1        | 1.14            | 2.7                 | 79         | 83,138        | 0.65            | 54,400        | 30.0                | 21              | 54,380              | 0.91                            |

|         |  |       |       |      |      |      |      |     |    |         |      |         |      |    |         |      |
|---------|--|-------|-------|------|------|------|------|-----|----|---------|------|---------|------|----|---------|------|
| UEC-B40 |  | 0.100 | 0.065 | 17.2 | 1.16 | 8.9  | 0.82 | 1.9 | 31 | 40,774  | 0.34 | 13,849  | 30.0 | 5  | 13,845  | 0.44 |
| UEC-C10 |  | 0.089 | 0.122 | 28.8 | 3.00 | 15.0 | 2.12 | 5.0 | 38 | 85,547  | 0.60 | 51,168  | 34.0 | 12 | 51,162  | 0.51 |
| UEC-D10 |  | 0.089 | 0.090 | 21.9 | 1.81 | 11.4 | 1.28 | 3.0 | 27 | 45,057  | 0.66 | 29,626  | 32.0 | 9  | 29,620  | 0.73 |
| Dr-A10  |  | 0.087 | 0.179 | 27.2 | 4.04 | 14.1 | 2.86 | 6.7 | 88 | 185,188 | 0.67 | 123,695 | 35.0 | 31 | 123,676 | 0.61 |
| Dr-B10  |  | 0.091 | 0.103 | 20.6 | 1.92 | 10.7 | 1.36 | 3.2 | 40 | 64,389  | 0.55 | 35,690  | 31.0 | 11 | 35,686  | 0.62 |

CUHP Proposed Subbasins Flying Horse East Results - 100 Year

Summary of Unit Hydrograph Parameters Used By Program and Calculated Results (Version 2.0.1)

| Catchment Name/ID | User Comment for Catchment | Unit Hydrograph Parameters and Results |       |            |                 |            |                 |                     |            |              | Excess Precip.  |               | Storm Hydrograph    |                 |                     |                                 |
|-------------------|----------------------------|----------------------------------------|-------|------------|-----------------|------------|-----------------|---------------------|------------|--------------|-----------------|---------------|---------------------|-----------------|---------------------|---------------------------------|
|                   |                            | CT                                     | Cp    | W50 (min.) | W50 Before Peak | W75 (min.) | W75 Before Peak | Time to Peak (min.) | Peak (cfs) | Volume (c.f) | Excess (inches) | Excess (c.f.) | Time to Peak (min.) | Peak Flow (cfs) | Total Volume (c.f.) | Runoff per Unit Area (cfs/acre) |
| OS1               |                            | 0.140                                  | 0.288 | 58.8       | 13.29           | 30.6       | 9.39            | 22.2                | 338        | 1,538,031    | 0.75            | 1,147,327     | 58.0                | 231             | 1,147,327           | 0.54                            |
| OS2               |                            | 0.117                                  | 0.162 | 64.2       | 8.26            | 33.4       | 5.84            | 13.8                | 73         | 364,670      | 0.88            | 321,029       | 54.0                | 56              | 321,025             | 0.55                            |
| OS3               |                            | 0.136                                  | 0.531 | 77.8       | 27.24           | 40.5       | 18.21           | 53.4                | 2,129      | 12,832,595   | 0.91            | 11,729,682    | 87.0                | 1,832           | 11,729,637          | 0.52                            |
| OS4               |                            | 0.148                                  | 0.172 | 32.2       | 4.55            | 16.8       | 3.21            | 7.6                 | 112        | 279,147      | 0.62            | 174,315       | 44.0                | 60              | 174,311             | 0.78                            |
| OS5               |                            | 0.143                                  | 0.059 | 50.4       | 2.59            | 26.2       | 1.83            | 4.3                 | 7          | 28,241       | 0.65            | 18,492        | 46.0                | 4               | 18,493              | 0.54                            |
| OS6               |                            | 0.154                                  | 0.172 | 70.0       | 9.56            | 36.4       | 6.75            | 15.9                | 48         | 260,525      | 0.59            | 152,552       | 54.0                | 27              | 152,552             | 0.37                            |
| OS7               |                            | 0.125                                  | 0.099 | 64.3       | 5.18            | 33.4       | 3.66            | 8.6                 | 23         | 113,510      | 1.34            | 152,291       | 55.0                | 25              | 152,287             | 0.81                            |
| OS8               |                            | 0.127                                  | 0.127 | 30.6       | 3.29            | 15.9       | 2.33            | 5.5                 | 82         | 193,951      | 0.98            | 190,071       | 43.0                | 59              | 190,061             | 1.11                            |
| OS9               |                            | 0.148                                  | 0.246 | 77.2       | 14.90           | 40.1       | 10.53           | 24.8                | 131        | 783,681      | 1.14            | 892,444       | 68.0                | 136             | 892,444             | 0.63                            |
| OS10              |                            | 0.079                                  | 0.040 | 36.7       | 1.44            | 19.1       | 1.01            | 2.4                 | 2          | 5,143        | 2.46            | 12,670        | 44.0                | 3               | 12,671              | 1.88                            |
| OS-B1             |                            | 0.157                                  | 0.068 | 30.1       | 1.88            | 15.7       | 1.33            | 3.1                 | 14         | 31,939       | 0.64            | 20,539        | 41.0                | 7               | 20,538              | 0.82                            |
| OS-B2             |                            | 0.154                                  | 0.130 | 27.2       | 3.02            | 14.1       | 2.13            | 5.0                 | 66         | 139,924      | 0.59            | 82,263        | 41.0                | 33              | 82,251              | 0.85                            |
| LC-A10            |                            | 0.081                                  | 0.136 | 10.4       | 1.38            | 5.4        | 0.98            | 2.3                 | 103        | 83,170       | 2.28            | 189,532       | 35.0                | 90              | 189,568             | 3.92                            |
| LC-A20            |                            | 0.086                                  | 0.151 | 24.7       | 3.16            | 12.8       | 2.23            | 5.3                 | 64         | 122,144      | 1.96            | 240,003       | 40.0                | 71              | 239,975             | 2.10                            |
| LC-A25            |                            | 0.085                                  | 0.130 | 23.5       | 2.66            | 12.2       | 1.88            | 4.4                 | 47         | 84,776       | 1.90            | 160,729       | 39.0                | 49              | 160,725             | 2.08                            |
| LC-A30            |                            | 0.094                                  | 0.183 | 13.4       | 2.18            | 7.0        | 1.54            | 3.6                 | 269        | 279,201      | 1.55            | 432,312       | 36.0                | 203             | 432,109             | 2.64                            |
| LC-B10            |                            | 0.151                                  | 0.169 | 82.3       | 10.97           | 42.8       | 7.75            | 18.3                | 40         | 257,805      | 1.39            | 357,114       | 68.0                | 50              | 357,114             | 0.71                            |
| LC-B20            |                            | 0.114                                  | 0.141 | 58.4       | 6.61            | 30.3       | 4.67            | 11.0                | 61         | 275,150      | 1.45            | 397,711       | 54.0                | 71              | 397,713             | 0.94                            |
| LC-B30            |                            | 0.106                                  | 0.113 | 23.8       | 2.36            | 12.4       | 1.67            | 3.9                 | 93         | 172,614      | 1.79            | 309,833       | 40.0                | 100             | 309,831             | 2.10                            |
| LC-B40            |                            | 0.085                                  | 0.227 | 21.0       | 3.97            | 10.9       | 2.81            | 6.6                 | 178        | 289,609      | 2.22            | 642,777       | 39.0                | 210             | 642,729             | 2.64                            |
| LC-B50            |                            | 0.089                                  | 0.185 | 20.4       | 3.19            | 10.6       | 2.25            | 5.3                 | 138        | 218,284      | 2.02            | 440,898       | 38.0                | 150             | 440,881             | 2.50                            |
| LC-B60            |                            | 0.149                                  | 0.142 | 64.8       | 7.35            | 33.7       | 5.20            | 12.3                | 36         | 181,718      | 1.46            | 266,162       | 59.0                | 45              | 266,159             | 0.89                            |
| LC-B70            |                            | 0.096                                  | 0.207 | 35.0       | 5.86            | 18.2       | 4.14            | 9.8                 | 155        | 419,855      | 1.45            | 610,476       | 46.0                | 155             | 610,452             | 1.34                            |
| LC-B80            |                            | 0.096                                  | 0.180 | 42.4       | 6.15            | 22.0       | 4.35            | 10.3                | 97         | 317,932      | 1.76            | 558,953       | 49.0                | 121             | 558,934             | 1.38                            |
| LC-B90            |                            | 0.097                                  | 0.203 | 40.5       | 6.61            | 21.1       | 4.67            | 11.0                | 135        | 424,366      | 1.42            | 601,913       | 48.0                | 138             | 601,910             | 1.18                            |
| LC-B100           |                            | 0.151                                  | 0.086 | 94.7       | 6.57            | 49.3       | 4.64            | 10.9                | 8          | 58,224       | 1.40            | 81,586        | 67.0                | 10              | 81,585              | 0.63                            |
| LC-B110           |                            | 0.097                                  | 0.125 | 27.2       | 2.92            | 14.2       | 2.06            | 4.9                 | 69         | 146,446      | 1.50            | 219,019       | 41.0                | 65              | 218,983             | 1.62                            |
| LC-B120           |                            | 0.103                                  | 0.155 | 34.0       | 4.34            | 17.7       | 3.07            | 7.2                 | 123        | 325,211      | 1.18            | 382,433       | 44.0                | 104             | 382,420             | 1.16                            |
| LC-B130           |                            | 0.087                                  | 0.145 | 44.7       | 5.29            | 23.3       | 3.74            | 8.8                 | 34         | 119,350      | 1.82            | 217,528       | 48.0                | 43              | 217,523             | 1.31                            |
| LC-B140           |                            | 0.092                                  | 0.109 | 23.3       | 2.24            | 12.1       | 1.59            | 3.7                 | 43         | 77,672       | 1.93            | 149,705       | 39.0                | 47              | 149,692             | 2.18                            |
| LC-B150           |                            | 0.096                                  | 0.117 | 24.4       | 2.50            | 12.7       | 1.76            | 4.2                 | 63         | 118,960      | 1.57            | 186,950       | 40.0                | 59              | 186,948             | 1.81                            |
| LC-B160           |                            | 0.096                                  | 0.150 | 15.5       | 2.08            | 8.1        | 1.47            | 3.5                 | 169        | 203,284      | 1.49            | 303,225       | 36.0                | 132             | 303,085             | 2.36                            |
| LC-B170           |                            | 0.100                                  | 0.054 | 36.0       | 1.79            | 18.7       | 1.27            | 3.0                 | 10         | 26,576       | 1.33            | 35,273        | 42.0                | 9               | 35,269              | 1.19                            |
| LC-B180           |                            | 0.096                                  | 0.149 | 17.1       | 2.26            | 8.9        | 1.60            | 3.8                 | 155        | 205,046      | 1.75            | 359,609       | 37.0                | 143             | 359,513             | 2.53                            |
| LC-B190           |                            | 0.088                                  | 0.162 | 10.4       | 1.60            | 5.4        | 1.13            | 2.7                 | 191        | 154,479      | 1.83            | 282,945       | 35.0                | 143             | 282,704             | 3.35                            |
| LC-C10            |                            | 0.091                                  | 0.140 | 22.3       | 2.69            | 11.6       | 1.90            | 4.5                 | 75         | 130,056      | 1.90            | 246,832       | 39.0                | 80              | 246,812             | 2.23                            |
| LC-D10            |                            | 0.109                                  | 0.098 | 32.1       | 2.71            | 16.7       | 1.92            | 4.5                 | 51         | 126,082      | 1.77            | 223,676       | 43.0                | 59              | 223,667             | 1.70                            |
| LC-F10            |                            | 0.084                                  | 0.191 | 17.3       | 2.85            | 9.0        | 2.01            | 4.7                 | 146        | 195,539      | 2.13            | 415,968       | 37.0                | 153             | 415,902             | 2.84                            |
| LC-F20            |                            | 0.124                                  | 0.094 | 62.4       | 4.82            | 32.5       | 3.40            | 8.0                 | 21         | 103,341      | 1.21            | 124,968       | 54.0                | 21              | 124,967             | 0.75                            |
| LC-G10            |                            | 0.083                                  | 0.144 | 28.1       | 3.40            | 14.6       | 2.40            | 5.7                 | 45         | 98,833       | 2.25            | 222,594       | 42.0                | 59              | 222,587             | 2.17                            |
| LC-H10            |                            | 0.096                                  | 0.075 | 24.5       | 1.71            | 12.7       | 1.21            | 2.9                 | 24         | 45,346       | 1.80            | 81,730        | 40.0                | 25              | 81,712              | 2.02                            |
| LC-I10            |                            | 0.089                                  | 0.148 | 22.8       | 2.89            | 11.9       | 2.05            | 4.8                 | 74         | 130,899      | 2.14            | 280,227       | 39.0                | 87              | 280,200             | 2.42                            |
| LC-I20            |                            | 0.086                                  | 0.185 | 23.8       | 3.68            | 12.4       | 2.60            | 6.1                 | 105        | 193,959      | 2.06            | 398,613       | 40.0                | 121             | 398,594             | 2.27                            |
| UEC-A10           |                            | 0.088                                  | 0.184 | 28.8       | 4.37            | 15.0       | 3.09            | 7.3                 | 91         | 203,233      | 2.10            | 426,855       | 43.0                | 115             | 426,850             | 2.05                            |
| UEC-A20           |                            | 0.094                                  | 0.101 | 23.9       | 2.15            | 12.4       | 1.52            | 3.6                 | 40         | 73,359       | 1.48            | 108,567       | 39.0                | 35              | 108,556             | 1.72                            |
| UEC-B10           |                            | 0.090                                  | 0.158 | 23.4       | 3.14            | 12.2       | 2.22            | 5.2                 | 89         | 161,592      | 1.80            | 291,066       | 40.0                | 92              | 291,039             | 2.06                            |
| UEC-B20           |                            | 0.087                                  | 0.167 | 19.2       | 2.76            | 10.0       | 1.95            | 4.6                 | 106        | 158,286      | 1.78            | 282,148       | 38.0                | 100             | 282,115             | 2.30                            |

|         |  |       |       |      |      |      |      |     |    |         |      |         |      |     |         |      |
|---------|--|-------|-------|------|------|------|------|-----|----|---------|------|---------|------|-----|---------|------|
| UEC-B30 |  | 0.086 | 0.127 | 13.4 | 1.60 | 6.9  | 1.13 | 2.7 | 80 | 83,138  | 1.82 | 151,156 | 36.0 | 66  | 151,117 | 2.89 |
| UEC-B40 |  | 0.098 | 0.068 | 16.3 | 1.15 | 8.5  | 0.81 | 1.9 | 32 | 40,774  | 1.30 | 52,978  | 36.0 | 23  | 52,963  | 2.05 |
| UEC-C10 |  | 0.088 | 0.124 | 28.1 | 2.97 | 14.6 | 2.10 | 5.0 | 39 | 85,547  | 1.80 | 154,055 | 41.0 | 42  | 154,041 | 1.79 |
| UEC-D10 |  | 0.089 | 0.091 | 21.6 | 1.81 | 11.2 | 1.28 | 3.0 | 27 | 45,057  | 2.13 | 96,021  | 37.0 | 31  | 95,996  | 2.48 |
| Dr-A10  |  | 0.086 | 0.181 | 26.7 | 4.02 | 13.9 | 2.84 | 6.7 | 90 | 185,188 | 2.04 | 377,724 | 42.0 | 106 | 377,700 | 2.08 |
| Dr-B10  |  | 0.090 | 0.104 | 20.0 | 1.91 | 10.4 | 1.35 | 3.2 | 42 | 64,389  | 1.87 | 120,097 | 37.0 | 41  | 120,080 | 2.33 |

## Appendix C

# SWMM Calculations

## SWMM Model Existing – 5 Year

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.4)

---

\*\*\*\*\*

Element Count

\*\*\*\*\*

Number of rain gages ..... 0  
 Number of subcatchments ... 0  
 Number of nodes ..... 70  
 Number of links ..... 64  
 Number of pollutants ..... 0  
 Number of land uses ..... 0

\*\*\*\*\*

Node Summary

\*\*\*\*\*

| External<br>Name | Type | Invert<br>Elev. | Max.<br>Depth | Ponded<br>Area |
|------------------|------|-----------------|---------------|----------------|
|------------------|------|-----------------|---------------|----------------|

---

|          |          |         |       |     |
|----------|----------|---------|-------|-----|
| DP_OS1   | JUNCTION | 6282.45 | 3.00  | 0.0 |
| DP_OS2   | JUNCTION | 6313.76 | 2.50  | 0.0 |
| DP_OS3   | JUNCTION | 6290.51 | 6.00  | 0.0 |
| DP_OS4   | JUNCTION | 6420.09 | 3.50  | 0.0 |
| DP_OS5   | JUNCTION | 6440.72 | 5.00  | 0.0 |
| DP_OS6   | JUNCTION | 6428.06 | 3.00  | 0.0 |
| DP_OS7   | JUNCTION | 6392.28 | 2.00  | 0.0 |
| DP_OS8   | JUNCTION | 6393.20 | 2.50  | 0.0 |
| DP_OS9   | JUNCTION | 6359.19 | 3.00  | 0.0 |
| Dr_A     | JUNCTION | 6347.11 | 0.00  | 0.0 |
| Dr_B     | JUNCTION | 6329.34 | 0.00  | 0.0 |
| J.UEC.1  | JUNCTION | 6281.05 | 5.00  | 0.0 |
| J_LC_A10 | JUNCTION | 6346.58 | 10.00 | 0.0 |
| J_LC_A20 | JUNCTION | 6320.63 | 3.00  | 0.0 |
| J_OS1    | JUNCTION | 6277.94 | 3.00  | 0.0 |
| J_OS2    | JUNCTION | 6310.41 | 5.00  | 0.0 |
| J_OS4    | JUNCTION | 6420.00 | 5.00  | 0.0 |
| J_OS6    | JUNCTION | 6425.61 | 5.00  | 0.0 |
| J_OS7    | JUNCTION | 6388.69 | 3.00  | 0.0 |
| J_OS8    | JUNCTION | 6391.98 | 2.50  | 0.0 |
| J_OS9    | JUNCTION | 6357.73 | 3.00  | 0.0 |
| J1       | JUNCTION | 6355.74 | 5.00  | 0.0 |
| J2       | JUNCTION | 6323.35 | 5.00  | 0.0 |
| J2_OS2   | JUNCTION | 6250.19 | 5.00  | 0.0 |
| J3       | JUNCTION | 6305.72 | 10.00 | 0.0 |
| J4       | JUNCTION | 6298.21 | 5.00  | 0.0 |
| LC_A10   | JUNCTION | 6393.58 | 0.00  | 0.0 |
| LC_A20   | JUNCTION | 6358.75 | 0.00  | 0.0 |
| LC_B     | JUNCTION | 6284.81 | 0.00  | 0.0 |

*SWMM Model Existing – 5 Year*

|            |          |         |      |     |
|------------|----------|---------|------|-----|
| LC_C       | JUNCTION | 6267.21 | 0.00 | 0.0 |
| LC_D       | JUNCTION | 6254.31 | 0.00 | 0.0 |
| LC_E       | JUNCTION | 6248.16 | 0.00 | 0.0 |
| LC_F       | JUNCTION | 6246.12 | 0.00 | 0.0 |
| LC_G       | JUNCTION | 6234.42 | 0.00 | 0.0 |
| LC_H       | JUNCTION | 6237.87 | 0.00 | 0.0 |
| LC_I       | JUNCTION | 6282.51 | 0.00 | 0.0 |
| OS1        | JUNCTION | 6349.15 | 0.00 | 0.0 |
| OS2        | JUNCTION | 6342.30 | 0.00 | 0.0 |
| OS3        | JUNCTION | 6453.31 | 0.00 | 0.0 |
| OS4        | JUNCTION | 6462.88 | 0.00 | 0.0 |
| OS5        | JUNCTION | 6448.20 | 0.00 | 0.0 |
| OS6        | JUNCTION | 6428.17 | 0.00 | 0.0 |
| OS7        | JUNCTION | 6416.17 | 0.00 | 0.0 |
| OS8        | JUNCTION | 6415.01 | 0.00 | 0.0 |
| OS9        | JUNCTION | 6429.66 | 0.00 | 0.0 |
| Out_Dr_A   | JUNCTION | 6327.48 | 4.50 | 0.0 |
| Out_Dr_B   | JUNCTION | 6315.27 | 2.00 | 0.0 |
| Out_LC_A10 | JUNCTION | 6349.20 | 8.00 | 0.0 |
| Out_LC_A20 | JUNCTION | 6322.30 | 3.00 | 0.0 |
| Out_LC_B   | JUNCTION | 6211.12 | 6.00 | 0.0 |
| Out_LC_C   | JUNCTION | 6255.23 | 2.00 | 0.0 |
| Out_LC_D   | JUNCTION | 6244.47 | 2.00 | 0.0 |
| Out_LC_E   | JUNCTION | 6244.40 | 2.00 | 0.0 |
| Out_LC_F   | JUNCTION | 6207.25 | 2.00 | 0.0 |
| Out_LC_G   | JUNCTION | 6211.83 | 2.00 | 0.0 |
| Out_LC_H   | JUNCTION | 6211.23 | 2.00 | 0.0 |
| Out_UEC_A  | JUNCTION | 6318.87 | 2.00 | 0.0 |
| Out_UEC_B  | JUNCTION | 6302.81 | 5.00 | 0.0 |
| Out_UEC_C  | JUNCTION | 6327.09 | 2.00 | 0.0 |
| Out_UEC_D  | JUNCTION | 6344.99 | 2.00 | 0.0 |
| UEC_A      | JUNCTION | 6349.56 | 0.00 | 0.0 |
| UEC_B      | JUNCTION | 6354.84 | 0.00 | 0.0 |
| UEC_C      | JUNCTION | 6357.45 | 0.00 | 0.0 |
| UEC_D      | JUNCTION | 6349.03 | 0.00 | 0.0 |
| Out.Dr     | OUTFALL  | 6301.67 | 4.50 | 0.0 |
| Out_C.D.E  | OUTFALL  | 6244.35 | 2.00 | 0.0 |
| Out_LC.B.F | OUTFALL  | 6201.53 | 2.00 | 0.0 |
| Out_LC.G.H | OUTFALL  | 6202.07 | 2.00 | 0.0 |
| Out_LC_I   | OUTFALL  | 6254.02 | 0.00 | 0.0 |
| UEC_Out    | OUTFALL  | 6278.45 | 5.00 | 0.0 |

\*\*\*\*\*

Link Summary

\*\*\*\*\*

| Name     | From Node | To Node   | Type    |
|----------|-----------|-----------|---------|
| Length   | %Slope    | Roughness |         |
| -----    | -----     | -----     | -----   |
| Ch.Dr_A  | Out_Dr_A  | Out.Dr    | CONDUIT |
| 1135.0   | 2.2744    | 0.0320    |         |
| Ch.UEC_B | Out_UEC_B | J.UEC.1   | CONDUIT |
| 1351.3   | 1.6111    | 0.0320    |         |



SWMM Model Existing – 5 Year

|              |        |            |            |         |
|--------------|--------|------------|------------|---------|
| CH_1         |        | J1         | J2         | CONDUIT |
| 2593.7       | 1.2488 | 0.0320     |            |         |
| Ch_2         |        | J2         | J3         | CONDUIT |
| 1678.2       | 1.0507 | 0.0320     |            |         |
| Ch_3         |        | J3         | J4         | CONDUIT |
| 973.6        | 0.7710 | 0.0320     |            |         |
| Ch_4         |        | J4         | DP_OS3     | CONDUIT |
| 998.0        | 0.7716 | 0.0320     |            |         |
| Ch_5         |        | J2_OS2     | Out_LC_B   | CONDUIT |
| 4798.2       | 0.8143 | 0.0320     |            |         |
| Ch_LC_A10    |        | J_LC_A10   | J3         | CONDUIT |
| 1414.2       | 2.8909 | 0.0320     |            |         |
| Ch_Main      |        | DP_OS3     | Out_LC_B   | CONDUIT |
| 9436.1       | 0.8414 | 0.0320     |            |         |
| Ch_OS6       |        | J_OS6      | J2         | CONDUIT |
| 2634.9       | 3.8840 | 0.0350     |            |         |
| Ch_OS7       |        | J_OS7      | Out_LC_A10 | CONDUIT |
| 1441.9       | 2.7395 | 0.0350     |            |         |
| Ch_UEC       |        | J.UEC.1    | UEC_Out    | CONDUIT |
| 737.2        | 0.3521 | 0.0320     |            |         |
| Culv_LC_A10  |        | Out_LC_A10 | J_LC_A10   | CONDUIT |
| 120.5        | 2.1763 | 0.0130     |            |         |
| Culv_LC_A20  |        | Out_LC_A20 | J_LC_A20   | CONDUIT |
| 61.7         | 2.7100 | 0.0130     |            |         |
| Culv_OS1     |        | DP_OS1     | J_OS1      | CONDUIT |
| 67.5         | 6.6934 | 0.0240     |            |         |
| Culv_OS2     |        | DP_OS2     | J_OS2      | CONDUIT |
| 79.1         | 4.2307 | 0.0240     |            |         |
| Culv_OS4     |        | DP_OS4     | J_OS4      | CONDUIT |
| 87.0         | 0.1068 | 0.0130     |            |         |
| Culv_OS6     |        | DP_OS6     | J_OS6      | CONDUIT |
| 82.4         | 2.9775 | 0.0130     |            |         |
| Culv_OS7     |        | DP_OS7     | J_OS7      | CONDUIT |
| 99.0         | 3.6291 | 0.0240     |            |         |
| Culv_OS8     |        | DP_OS8     | J_OS8      | CONDUIT |
| 114.8        | 1.0631 | 0.0240     |            |         |
| Culv_OS9     |        | DP_OS9     | J_OS9      | CONDUIT |
| 93.8         | 1.5617 | 0.0210     |            |         |
| Dummy_Dr_A   |        | Dr_A       | Out_Dr_A   | CONDUIT |
| 1154.7       | 1.7000 | 0.0100     |            |         |
| Dummy_Dr_B   |        | Dr_B       | Out_Dr_B   | CONDUIT |
| 662.0        | 2.1265 | 0.0100     |            |         |
| Dummy_LC_A10 |        | LC_A10     | Out_LC_A10 | CONDUIT |
| 2079.4       | 2.1348 | 0.0100     |            |         |
| dummy_LC_A20 |        | LC_A20     | Out_LC_A20 | CONDUIT |
| 613.0        | 5.9554 | 0.0100     |            |         |
| Dummy_LC_B   |        | LC_B       | Out_LC_B   | CONDUIT |
| 5629.3       | 1.3093 | 0.0100     |            |         |
| Dummy_LC_C   |        | LC_C       | Out_LC_C   | CONDUIT |
| 708.8        | 1.6912 | 0.0100     |            |         |
| Dummy_LC_D   |        | LC_D       | Out_LC_D   | CONDUIT |
| 691.2        | 1.4232 | 0.0100     |            |         |
| Dummy_LC_E   |        | LC_E       | Out_LC_E   | CONDUIT |
| 646.2        | 0.5819 | 0.0100     |            |         |

*SWMM Model Existing – 5 Year*

|             |           |            |         |
|-------------|-----------|------------|---------|
| Dummy_LC_F  | LC_F      | Out_LC_F   | CONDUIT |
| 1332.0      | 2.9192    | 0.0100     |         |
| Dummy_LC_G  | LC_G      | Out_LC_G   | CONDUIT |
| 842.5       | 2.6821    | 0.0100     |         |
| Dummy_LC_H  | LC_H      | Out_LC_H   | CONDUIT |
| 579.9       | 4.5972    | 0.0100     |         |
| Dummy_LC_I  | LC_I      | Out_LC_I   | CONDUIT |
| 1517.8      | 1.8774    | 0.0100     |         |
| Dummy_OS1   | OS1       | DP_OS1     | CONDUIT |
| 3482.0      | 1.9161    | 0.0100     |         |
| Dummy_OS2   | OS2       | DP_OS2     | CONDUIT |
| 1242.8      | 2.2974    | 0.0100     |         |
| Dummy_OS3   | OS3       | DP_OS3     | CONDUIT |
| 9018.4      | 1.8056    | 0.0100     |         |
| Dummy_OS4   | OS4       | DP_OS4     | CONDUIT |
| 811.6       | 5.2783    | 0.0100     |         |
| Dummy_OS5   | OS5       | DP_OS5     | CONDUIT |
| 395.2       | 1.8938    | 0.0100     |         |
| Dummy_OS6   | OS6       | DP_OS6     | CONDUIT |
| 1040.0      | 0.0101    | 0.0100     |         |
| Dummy_OS7   | OS7       | DP_OS7     | CONDUIT |
| 657.7       | 3.6352    | 0.0100     |         |
| Dummy_OS8   | OS8       | DP_OS8     | CONDUIT |
| 393.2       | 5.5555    | 0.0100     |         |
| Dummy_OS9   | OS9       | DP_OS9     | CONDUIT |
| 2515.8      | 2.8023    | 0.0100     |         |
| Dummy_UEC_A | UEC_A     | Out_UEC_A  | CONDUIT |
| 1521.5      | 2.0172    | 0.0100     |         |
| Dummy_UEC_B | UEC_B     | Out_UEC_B  | CONDUIT |
| 1679.8      | 3.0990    | 0.0100     |         |
| Dummy_UEC_C | UEC_C     | Out_UEC_C  | CONDUIT |
| 695.7       | 4.3682    | 0.0100     |         |
| Dummy_UEC_D | UEC_D     | Out_UEC_D  | CONDUIT |
| 352.4       | 1.1481    | 0.0100     |         |
| Over.Dr_B   | Out_Dr_B  | Out .Dr    | CONDUIT |
| 359.0       | 3.7902    | 0.0350     |         |
| Over.LC_B   | Out_LC_B  | Out_LC.B.F | CONDUIT |
| 944.5       | 1.0146    | 0.0350     |         |
| Over.LC_C   | Out_LC_C  | Out_C.D.E  | CONDUIT |
| 1183.0      | 0.9194    | 0.0350     |         |
| Over.LC_D   | Out_LC_D  | Out_C.D.E  | CONDUIT |
| 93.9        | 0.1289    | 0.0350     |         |
| Over.LC_E   | Out_LC_E  | Out_C.D.E  | CONDUIT |
| 86.0        | 0.0605    | 0.0350     |         |
| Over.LC_F   | Out_LC_F  | Out_LC.B.F | CONDUIT |
| 531.3       | 1.0764    | 0.0350     |         |
| Over.LC_G   | Out_LC_G  | Out_LC.G.H | CONDUIT |
| 447.1       | 2.1828    | 0.0350     |         |
| Over.LC_H   | Out_LC_H  | Out_LC.G.H | CONDUIT |
| 442.2       | 2.0720    | 0.0350     |         |
| Over.UEC_A  | Out_UEC_A | J.UEC.1    | CONDUIT |
| 1781.8      | 2.1235    | 0.0350     |         |
| Over.UEC_C  | Out_UEC_C | UEC_Out    | CONDUIT |
| 1664.0      | 2.9246    | 0.0350     |         |

**SWMM Model Existing – 5 Year**

|                  |           |            |         |
|------------------|-----------|------------|---------|
| Over_UEC_D       | Out_UEC_D | UEC_Out    | CONDUIT |
| 1915.6    3.4756 | 0.0350    |            |         |
| Over_LC_A20      | J_LC_A20  | J4         | CONDUIT |
| 707.8    3.1696  | 0.0350    |            |         |
| Over_OS1         | J_OS1     | Out_LC_B   | CONDUIT |
| 5800.5    1.1521 | 0.0350    |            |         |
| Over_OS2         | J_OS2     | J2_OS2     | CONDUIT |
| 2743.3    2.1958 | 0.0350    |            |         |
| Over_OS4         | J_OS4     | J1         | CONDUIT |
| 3674.0    1.7494 | 0.0350    |            |         |
| Over_OS5         | DP_OS5    | J1         | CONDUIT |
| 3464.9    2.4535 | 0.0300    |            |         |
| Over_OS8         | J_OS8     | Out_LC_A10 | CONDUIT |
| 3170.1    1.3495 | 0.0350    |            |         |
| Over_OS9         | J_OS9     | Out_UEC_A  | CONDUIT |
| 2802.5    1.3865 | 0.0350    |            |         |

\*\*\*\*\*  
 Cross Section Summary  
 \*\*\*\*\*

| No. of  | Full                   |             | Full  | Full   | Hyd. | Max.   |
|---------|------------------------|-------------|-------|--------|------|--------|
| Conduit | Flow                   | Shape       | Depth | Area   | Rad. | Width  |
| Barrels |                        |             |       |        |      |        |
| -----   |                        |             |       |        |      |        |
| 1       | Ch.Dr_A<br>1475.06     | TRIANGULAR  | 4.50  | 123.75 | 2.22 | 55.00  |
| 1       | Ch.UEC_B<br>5055.78    | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
| 1       | CH_1<br>4666.46        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_2<br>4280.31        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_3<br>3666.59        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_4<br>3668.12        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_5<br>952.35         | TRIANGULAR  | 5.00  | 125.00 | 2.45 | 50.00  |
| 1       | Ch_LC_A10<br>24339.02  | TRAPEZOIDAL | 10.00 | 900.00 | 6.34 | 140.00 |
| 1       | Ch_Main<br>2645.44     | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
| 1       | Ch_OS6<br>7700.00      | TRIANGULAR  | 5.00  | 500.00 | 2.50 | 200.00 |
| 1       | Ch_OS7<br>711.46       | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
| 1       | Ch_UEC<br>2363.59      | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
| 1       | Culv_LC_A10<br>1159.39 | RECT_CLOSED | 8.00  | 48.00  | 1.71 | 6.00   |

*SWMM Model Existing – 5 Year*

|   |              |             |      |      |      |      |
|---|--------------|-------------|------|------|------|------|
| 1 | Culv_LC_A20  | RECT_CLOSED | 3.00 | 9.00 | 0.75 | 3.00 |
| 1 | 139.80       |             |      |      |      |      |
| 3 | Culv_OS1     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 3 | 93.47        |             |      |      |      |      |
| 2 | Culv_OS2     | CIRCULAR    | 2.50 | 4.91 | 0.62 | 2.50 |
| 2 | 45.70        |             |      |      |      |      |
| 2 | Culv_OS4     | CIRCULAR    | 3.50 | 9.62 | 0.88 | 3.50 |
| 2 | 32.88        |             |      |      |      |      |
| 2 | Culv_OS6     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 2 | 115.09       |             |      |      |      |      |
| 3 | Culv_OS7     | CIRCULAR    | 2.00 | 3.14 | 0.50 | 2.00 |
| 3 | 23.34        |             |      |      |      |      |
| 3 | Culv_OS8     | CIRCULAR    | 2.50 | 4.91 | 0.62 | 2.50 |
| 3 | 22.91        |             |      |      |      |      |
| 3 | Culv_OS9     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 3 | 51.60        |             |      |      |      |      |
| 1 | Dummy_Dr_A   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_Dr_B   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_A10 | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | dummy_LC_A20 | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_B   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_C   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_D   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_E   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_F   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_G   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_H   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_I   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS1    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS2    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS3    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS4    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS5    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS6    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS7    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |

*SWMM Model Existing – 5 Year*

|   |                       |             |      |         |      |        |
|---|-----------------------|-------------|------|---------|------|--------|
| 1 | Dummy_Os8<br>0.00     | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Dummy_OS9<br>0.00     | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Dummy_UEC_A<br>0.00   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Dummy_UEC_B<br>0.00   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Dummy_UEC_C<br>0.00   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Dummy_UEC_D<br>0.00   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
| 1 | Over.Dr_B<br>2556.48  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_B<br>3765.95  | RECT_OPEN   | 1.50 | 675.00  | 1.49 | 450.00 |
| 1 | Over.LC_C<br>1259.11  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_D<br>471.43   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_E<br>322.88   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_F<br>1362.36  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_G<br>1940.07  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.LC_H<br>1890.20  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.UEC_A<br>1913.55 | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.UEC_C<br>2245.67 | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over.UEC_D<br>2448.08 | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
| 1 | Over_LC_A20<br>37.49  | TRIANGULAR  | 0.50 | 12.50   | 0.25 | 50.00  |
| 1 | Over_OS1<br>2855.66   | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |
| 1 | Over_OS2<br>17807.57  | RECT_OPEN   | 5.00 | 1000.00 | 4.76 | 200.00 |
| 1 | Over_OS4<br>8838.21   | TRAPEZOIDAL | 5.00 | 600.00  | 4.25 | 140.00 |
| 1 | Over_OS5<br>10645.06  | RECT_OPEN   | 5.00 | 500.00  | 4.55 | 100.00 |
| 1 | Over_OS8<br>3090.62   | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |
| 1 | Over_OS9<br>3132.77   | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |

\*\*\*\*\*

Analysis Options

\*\*\*\*\*

Flow Units ..... CFS

## SWMM Model Existing – 5 Year

Process Models:

```

Rainfall/Runoff ..... NO
RDII ..... NO
Snowmelt ..... NO
Groundwater ..... NO
Flow Routing ..... YES
Ponding Allowed ..... NO
Water Quality ..... NO
Flow Routing Method ..... KINWAVE
Starting Date ..... 01/01/2024 00:00:00
Ending Date ..... 01/02/2024 00:00:00
Antecedent Dry Days ..... 0.0
Report Time Step ..... 00:01:00
Routing Time Step ..... 5.00 sec
    
```

| *****                      | Volume    | Volume   |
|----------------------------|-----------|----------|
| Flow Routing Continuity    | acre-feet | 10^6 gal |
| *****                      | -----     | -----    |
| Dry Weather Inflow .....   | 0.000     | 0.000    |
| Wet Weather Inflow .....   | 0.000     | 0.000    |
| Groundwater Inflow .....   | 0.000     | 0.000    |
| RDII Inflow .....          | 0.000     | 0.000    |
| External Inflow .....      | 19.126    | 6.233    |
| External Outflow .....     | 20.848    | 6.794    |
| Flooding Loss .....        | 0.000     | 0.000    |
| Evaporation Loss .....     | 0.000     | 0.000    |
| Exfiltration Loss .....    | 0.000     | 0.000    |
| Initial Stored Volume .... | 0.000     | 0.000    |
| Final Stored Volume .....  | 0.069     | 0.023    |
| Continuity Error (%) ..... | -9.366    |          |

```

*****
Highest Flow Instability Indexes
*****
All links are stable.
    
```

```

*****
Routing Time Step Summary
*****
Minimum Time Step      :      5.00 sec
Average Time Step      :      5.00 sec
Maximum Time Step      :      5.00 sec
% of Time in Steady State :      0.00
Average Iterations per Step :      1.00
% of Steps Not Converging :      0.00
    
```

```

*****
Node Depth Summary
*****
    
```

*SWMM Model Existing – 5 Year*

| Reported<br>Max Depth<br>Node<br>Feet | Type     | Average<br>Depth<br>Feet | Maximum<br>Depth<br>Feet | Maximum<br>HGL<br>Feet | Time of Max<br>Occurrence<br>days hr:min |
|---------------------------------------|----------|--------------------------|--------------------------|------------------------|------------------------------------------|
| DP_OS1<br>0.37                        | JUNCTION | 0.04                     | 0.37                     | 6282.82                | 0 00:51                                  |
| DP_OS2<br>0.43                        | JUNCTION | 0.05                     | 0.43                     | 6314.19                | 0 00:48                                  |
| DP_OS3<br>1.65                        | JUNCTION | 0.33                     | 1.65                     | 6292.16                | 0 01:25                                  |
| DP_OS4<br>0.38                        | JUNCTION | 0.02                     | 0.38                     | 6420.47                | 0 00:36                                  |
| DP_OS5<br>0.01                        | JUNCTION | 0.00                     | 0.01                     | 6440.73                | 0 00:36                                  |
| DP_OS6<br>0.10                        | JUNCTION | 0.01                     | 0.10                     | 6428.16                | 0 00:45                                  |
| DP_OS7<br>0.23                        | JUNCTION | 0.03                     | 0.23                     | 6392.51                | 0 00:45                                  |
| DP_OS8<br>0.40                        | JUNCTION | 0.02                     | 0.40                     | 6393.60                | 0 00:34                                  |
| DP_OS9<br>0.34                        | JUNCTION | 0.04                     | 0.34                     | 6359.53                | 0 00:56                                  |
| Dr_A<br>0.00                          | JUNCTION | 0.00                     | 0.00                     | 6347.11                | 0 00:00                                  |
| Dr_B<br>0.00                          | JUNCTION | 0.00                     | 0.00                     | 6329.34                | 0 00:00                                  |
| J.UEC.1<br>0.11                       | JUNCTION | 0.02                     | 0.11                     | 6281.16                | 0 02:18                                  |
| J_LC_A10<br>0.16                      | JUNCTION | 0.03                     | 0.16                     | 6346.74                | 0 01:17                                  |
| J_LC_A20<br>0.08                      | JUNCTION | 0.01                     | 0.08                     | 6320.71                | 0 00:37                                  |
| J_OS1<br>0.37                         | JUNCTION | 0.04                     | 0.37                     | 6278.31                | 0 00:51                                  |
| J_OS2<br>0.43                         | JUNCTION | 0.05                     | 0.43                     | 6310.85                | 0 00:48                                  |
| J_OS4<br>0.38                         | JUNCTION | 0.02                     | 0.38                     | 6420.38                | 0 00:36                                  |
| J_OS6<br>0.13                         | JUNCTION | 0.02                     | 0.13                     | 6425.74                | 0 00:45                                  |
| J_OS7<br>0.23                         | JUNCTION | 0.03                     | 0.23                     | 6388.91                | 0 00:46                                  |
| J_OS8<br>0.40                         | JUNCTION | 0.02                     | 0.40                     | 6392.38                | 0 00:34                                  |
| J_OS9<br>0.34                         | JUNCTION | 0.04                     | 0.34                     | 6358.07                | 0 00:56                                  |
| J1<br>0.03                            | JUNCTION | 0.01                     | 0.03                     | 6355.77                | 0 01:34                                  |

*SWMM Model Existing – 5 Year*

|                    |          |      |      |         |   |       |
|--------------------|----------|------|------|---------|---|-------|
| J2<br>0.12         | JUNCTION | 0.02 | 0.12 | 6323.47 | 0 | 01:16 |
| J2_OS2<br>0.67     | JUNCTION | 0.15 | 0.67 | 6250.86 | 0 | 01:46 |
| J3<br>0.10         | JUNCTION | 0.02 | 0.10 | 6305.82 | 0 | 01:31 |
| J4<br>0.10         | JUNCTION | 0.02 | 0.10 | 6298.31 | 0 | 01:41 |
| LC_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6393.58 | 0 | 00:00 |
| LC_A20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6358.75 | 0 | 00:00 |
| LC_B<br>0.00       | JUNCTION | 0.00 | 0.00 | 6284.81 | 0 | 00:00 |
| LC_C<br>0.00       | JUNCTION | 0.00 | 0.00 | 6267.21 | 0 | 00:00 |
| LC_D<br>0.00       | JUNCTION | 0.00 | 0.00 | 6254.31 | 0 | 00:00 |
| LC_E<br>0.00       | JUNCTION | 0.00 | 0.00 | 6248.16 | 0 | 00:00 |
| LC_F<br>0.00       | JUNCTION | 0.00 | 0.00 | 6246.12 | 0 | 00:00 |
| LC_G<br>0.00       | JUNCTION | 0.00 | 0.00 | 6234.42 | 0 | 00:00 |
| LC_H<br>0.00       | JUNCTION | 0.00 | 0.00 | 6237.87 | 0 | 00:00 |
| LC_I<br>0.00       | JUNCTION | 0.00 | 0.00 | 6282.51 | 0 | 00:00 |
| OS1<br>0.00        | JUNCTION | 0.00 | 0.00 | 6349.15 | 0 | 00:00 |
| OS2<br>0.00        | JUNCTION | 0.00 | 0.00 | 6342.30 | 0 | 00:00 |
| OS3<br>0.00        | JUNCTION | 0.00 | 0.00 | 6453.31 | 0 | 00:00 |
| OS4<br>0.00        | JUNCTION | 0.00 | 0.00 | 6462.88 | 0 | 00:00 |
| OS5<br>0.00        | JUNCTION | 0.00 | 0.00 | 6448.20 | 0 | 00:00 |
| OS6<br>0.00        | JUNCTION | 0.00 | 0.00 | 6428.17 | 0 | 00:00 |
| OS7<br>0.00        | JUNCTION | 0.00 | 0.00 | 6416.17 | 0 | 00:00 |
| OS8<br>0.00        | JUNCTION | 0.00 | 0.00 | 6415.01 | 0 | 00:00 |
| OS9<br>0.00        | JUNCTION | 0.00 | 0.00 | 6429.66 | 0 | 00:00 |
| Out_Dr_A<br>0.22   | JUNCTION | 0.02 | 0.22 | 6327.69 | 0 | 00:44 |
| Out_Dr_B<br>0.01   | JUNCTION | 0.00 | 0.01 | 6315.28 | 0 | 00:36 |
| Out_LC_A10<br>0.16 | JUNCTION | 0.03 | 0.16 | 6349.36 | 0 | 01:17 |
| Out_LC_A20<br>0.04 | JUNCTION | 0.00 | 0.04 | 6322.34 | 0 | 00:37 |



*SWMM Model Existing – 5 Year*

|                    |          |      |      |         |   |       |
|--------------------|----------|------|------|---------|---|-------|
| Out_LC_B<br>1.55   | JUNCTION | 0.37 | 1.55 | 6212.67 | 0 | 01:58 |
| Out_LC_C<br>0.02   | JUNCTION | 0.00 | 0.02 | 6255.24 | 0 | 00:35 |
| Out_LC_D<br>0.05   | JUNCTION | 0.00 | 0.05 | 6244.53 | 0 | 00:40 |
| Out_LC_E<br>0.08   | JUNCTION | 0.00 | 0.08 | 6244.48 | 0 | 00:40 |
| Out_LC_F<br>0.03   | JUNCTION | 0.00 | 0.03 | 6207.28 | 0 | 00:38 |
| Out_LC_G<br>0.01   | JUNCTION | 0.00 | 0.01 | 6211.84 | 0 | 00:47 |
| Out_LC_H<br>0.01   | JUNCTION | 0.00 | 0.01 | 6211.24 | 0 | 00:36 |
| Out_UEC_A<br>0.04  | JUNCTION | 0.01 | 0.04 | 6318.92 | 0 | 01:53 |
| Out_UEC_B<br>0.03  | JUNCTION | 0.00 | 0.03 | 6302.85 | 0 | 00:39 |
| Out_UEC_C<br>0.01  | JUNCTION | 0.00 | 0.01 | 6327.10 | 0 | 00:37 |
| Out_UEC_D<br>0.02  | JUNCTION | 0.00 | 0.02 | 6345.00 | 0 | 00:39 |
| UEC_A<br>0.00      | JUNCTION | 0.00 | 0.00 | 6349.56 | 0 | 00:00 |
| UEC_B<br>0.00      | JUNCTION | 0.00 | 0.00 | 6354.84 | 0 | 00:00 |
| UEC_C<br>0.00      | JUNCTION | 0.00 | 0.00 | 6357.45 | 0 | 00:00 |
| UEC_D<br>0.00      | JUNCTION | 0.00 | 0.00 | 6349.03 | 0 | 00:00 |
| Out.Dr<br>0.21     | OUTFALL  | 0.02 | 0.21 | 6301.88 | 0 | 00:56 |
| Out_C.D.E<br>0.08  | OUTFALL  | 0.01 | 0.08 | 6244.43 | 0 | 00:47 |
| Out_LC.B.F<br>0.15 | OUTFALL  | 0.03 | 0.15 | 6201.69 | 0 | 02:07 |
| Out_LC.G.H<br>0.01 | OUTFALL  | 0.00 | 0.01 | 6202.08 | 0 | 01:08 |
| Out_LC_I<br>0.00   | OUTFALL  | 0.00 | 0.00 | 6254.02 | 0 | 00:00 |
| UEC_Out<br>0.11    | OUTFALL  | 0.03 | 0.11 | 6278.56 | 0 | 02:30 |

\*\*\*\*\*  
Node Inflow Summary  
\*\*\*\*\*

---

| Lateral<br>Inflow | Total<br>Inflow | Flow<br>Balance | Maximum<br>Lateral | Maximum<br>Total | Maximum<br>Time of Max |
|-------------------|-----------------|-----------------|--------------------|------------------|------------------------|
|-------------------|-----------------|-----------------|--------------------|------------------|------------------------|

SWMM Model Existing – 5 Year

| Volume Node<br>gal | Volume<br>10 <sup>6</sup> gal | Error Type<br>Percent | Inflow<br>CFS | Inflow<br>CFS | Occurrence<br>days hr:min | 10 <sup>6</sup> |
|--------------------|-------------------------------|-----------------------|---------------|---------------|---------------------------|-----------------|
| DP_OS1             |                               | JUNCTION              | 0.00          | 9.22          | 0 00:51                   |                 |
| 0                  | 0.38                          | 0.000                 |               |               |                           |                 |
| DP_OS2             |                               | JUNCTION              | 0.00          | 6.00          | 0 00:48                   |                 |
| 0                  | 0.308                         | 0.000                 |               |               |                           |                 |
| DP_OS3             |                               | JUNCTION              | 0.00          | 84.62         | 0 01:25                   |                 |
| 0                  | 4.72                          | 0.000                 |               |               |                           |                 |
| DP_OS4             |                               | JUNCTION              | 0.00          | 1.62          | 0 00:36                   |                 |
| 0                  | 0.0371                        | 0.000                 |               |               |                           |                 |
| DP_OS5             |                               | JUNCTION              | 0.00          | 0.15          | 0 00:36                   |                 |
| 0                  | 0.00551                       | 0.000                 |               |               |                           |                 |
| DP_OS6             |                               | JUNCTION              | 0.00          | 0.43          | 0 00:45                   |                 |
| 0                  | 0.0193                        | 0.000                 |               |               |                           |                 |
| DP_OS7             |                               | JUNCTION              | 0.00          | 1.88          | 0 00:45                   |                 |
| 0                  | 0.0892                        | 0.000                 |               |               |                           |                 |
| DP_OS8             |                               | JUNCTION              | 0.00          | 3.86          | 0 00:34                   |                 |
| 0                  | 0.0928                        | 0.000                 |               |               |                           |                 |
| DP_OS9             |                               | JUNCTION              | 0.00          | 4.20          | 0 00:56                   |                 |
| 0                  | 0.207                         | 0.000                 |               |               |                           |                 |
| Dr_A               |                               | JUNCTION              | 0.44          | 0.44          | 0 00:44                   |                 |
| 0.0166             | 0.0166                        | 0.000                 |               |               |                           |                 |
| Dr_B               |                               | JUNCTION              | 0.22          | 0.22          | 0 00:36                   |                 |
| 0.00549            | 0.00549                       | 0.000                 |               |               |                           |                 |
| J.UEC.1            |                               | JUNCTION              | 0.00          | 3.49          | 0 02:18                   |                 |
| 0                  | 0.33                          | 0.000                 |               |               |                           |                 |
| J_LC_A10           |                               | JUNCTION              | 0.00          | 4.60          | 0 01:17                   |                 |
| 0                  | 0.314                         | 0.000                 |               |               |                           |                 |
| J_LC_A20           |                               | JUNCTION              | 0.00          | 0.26          | 0 00:37                   |                 |
| 0                  | 0.00951                       | 0.000                 |               |               |                           |                 |
| J_OS1              |                               | JUNCTION              | 0.00          | 9.22          | 0 00:51                   |                 |
| 0                  | 0.38                          | 0.000                 |               |               |                           |                 |
| J_OS2              |                               | JUNCTION              | 0.00          | 6.00          | 0 00:48                   |                 |
| 0                  | 0.308                         | 0.000                 |               |               |                           |                 |
| J_OS4              |                               | JUNCTION              | 0.00          | 1.62          | 0 00:36                   |                 |
| 0                  | 0.0371                        | 0.000                 |               |               |                           |                 |
| J_OS6              |                               | JUNCTION              | 0.00          | 0.43          | 0 00:45                   |                 |
| 0                  | 0.0193                        | 0.000                 |               |               |                           |                 |
| J_OS7              |                               | JUNCTION              | 0.00          | 1.88          | 0 00:46                   |                 |
| 0                  | 0.0892                        | 0.000                 |               |               |                           |                 |
| J_OS8              |                               | JUNCTION              | 0.00          | 3.86          | 0 00:34                   |                 |
| 0                  | 0.0927                        | 0.000                 |               |               |                           |                 |
| J_OS9              |                               | JUNCTION              | 0.00          | 4.20          | 0 00:56                   |                 |
| 0                  | 0.207                         | 0.000                 |               |               |                           |                 |
| J1                 |                               | JUNCTION              | 0.00          | 0.81          | 0 01:34                   |                 |
| 0                  | 0.0723                        | 0.000                 |               |               |                           |                 |
| J2                 |                               | JUNCTION              | 0.00          | 0.90          | 0 02:46                   |                 |
| 0                  | 0.0981                        | 0.000                 |               |               |                           |                 |
| J2_OS2             |                               | JUNCTION              | 0.00          | 4.57          | 0 01:46                   |                 |
| 0                  | 0.348                         | 0.000                 |               |               |                           |                 |

*SWMM Model Existing – 5 Year*

|            |         |          |       |       |   |       |
|------------|---------|----------|-------|-------|---|-------|
| J3         |         | JUNCTION | 0.00  | 4.67  | 0 | 01:31 |
| 0          | 0.415   | 0.000    |       |       |   |       |
| J4         |         | JUNCTION | 0.00  | 4.76  | 0 | 01:41 |
| 0          | 0.429   | 0.000    |       |       |   |       |
| LC_A10     |         | JUNCTION | 1.42  | 1.42  | 0 | 00:54 |
| 0.0754     | 0.0754  | 0.000    |       |       |   |       |
| LC_A20     |         | JUNCTION | 0.26  | 0.26  | 0 | 00:37 |
| 0.00951    | 0.00951 | 0.000    |       |       |   |       |
| LC_B       |         | JUNCTION | 9.42  | 9.42  | 0 | 01:08 |
| 0.427      | 0.427   | 0.000    |       |       |   |       |
| LC_C       |         | JUNCTION | 0.39  | 0.39  | 0 | 00:35 |
| 0.00861    | 0.00861 | 0.000    |       |       |   |       |
| LC_D       |         | JUNCTION | 1.21  | 1.21  | 0 | 00:40 |
| 0.0333     | 0.0333  | 0.000    |       |       |   |       |
| LC_E       |         | JUNCTION | 1.45  | 1.45  | 0 | 00:40 |
| 0.0411     | 0.0411  | 0.000    |       |       |   |       |
| LC_F       |         | JUNCTION | 1.44  | 1.44  | 0 | 00:38 |
| 0.032      | 0.032   | 0.000    |       |       |   |       |
| LC_G       |         | JUNCTION | 0.28  | 0.28  | 0 | 00:47 |
| 0.0126     | 0.0126  | 0.000    |       |       |   |       |
| LC_H       |         | JUNCTION | 0.26  | 0.26  | 0 | 00:36 |
| 0.00625    | 0.00625 | 0.000    |       |       |   |       |
| LC_I       |         | JUNCTION | 0.77  | 0.77  | 0 | 00:57 |
| 0.0402     | 0.0402  | 0.000    |       |       |   |       |
| OS1        |         | JUNCTION | 9.22  | 9.22  | 0 | 00:51 |
| 0.38       | 0.38    | 0.000    |       |       |   |       |
| OS2        |         | JUNCTION | 6.00  | 6.00  | 0 | 00:48 |
| 0.308      | 0.308   | 0.000    |       |       |   |       |
| OS3        |         | JUNCTION | 82.90 | 82.90 | 0 | 01:22 |
| 4.29       | 4.29    | 0.000    |       |       |   |       |
| OS4        |         | JUNCTION | 1.62  | 1.62  | 0 | 00:36 |
| 0.0371     | 0.0371  | 0.000    |       |       |   |       |
| OS5        |         | JUNCTION | 0.15  | 0.15  | 0 | 00:36 |
| 0.00551    | 0.00551 | 0.000    |       |       |   |       |
| OS6        |         | JUNCTION | 0.43  | 0.43  | 0 | 00:45 |
| 0.0193     | 0.0193  | 0.000    |       |       |   |       |
| OS7        |         | JUNCTION | 1.88  | 1.88  | 0 | 00:45 |
| 0.0892     | 0.0892  | 0.000    |       |       |   |       |
| OS8        |         | JUNCTION | 3.86  | 3.86  | 0 | 00:34 |
| 0.0928     | 0.0928  | 0.000    |       |       |   |       |
| OS9        |         | JUNCTION | 4.20  | 4.20  | 0 | 00:56 |
| 0.207      | 0.207   | 0.000    |       |       |   |       |
| Out_Dr_A   |         | JUNCTION | 0.00  | 0.44  | 0 | 00:44 |
| 0          | 0.0166  | 0.000    |       |       |   |       |
| Out_Dr_B   |         | JUNCTION | 0.00  | 0.22  | 0 | 00:36 |
| 0          | 0.00549 | 0.000    |       |       |   |       |
| Out_LC_A10 |         | JUNCTION | 0.00  | 4.60  | 0 | 01:17 |
| 0          | 0.314   | 0.000    |       |       |   |       |
| Out_LC_A20 |         | JUNCTION | 0.00  | 0.26  | 0 | 00:37 |
| 0          | 0.00951 | 0.000    |       |       |   |       |
| Out_LC_B   |         | JUNCTION | 0.00  | 85.62 | 0 | 01:59 |
| 0          | 6.21    | 0.000    |       |       |   |       |
| Out_LC_C   |         | JUNCTION | 0.00  | 0.39  | 0 | 00:35 |
| 0          | 0.00861 | 0.000    |       |       |   |       |

*SWMM Model Existing – 5 Year*

|            |         |          |      |       |   |       |
|------------|---------|----------|------|-------|---|-------|
| Out_LC_D   |         | JUNCTION | 0.00 | 1.21  | 0 | 00:40 |
| 0          | 0.0333  | 0.000    |      |       |   |       |
| Out_LC_E   |         | JUNCTION | 0.00 | 1.45  | 0 | 00:40 |
| 0          | 0.0411  | 0.000    |      |       |   |       |
| Out_LC_F   |         | JUNCTION | 0.00 | 1.44  | 0 | 00:38 |
| 0          | 0.032   | 0.000    |      |       |   |       |
| Out_LC_G   |         | JUNCTION | 0.00 | 0.28  | 0 | 00:47 |
| 0          | 0.0126  | 0.000    |      |       |   |       |
| Out_LC_H   |         | JUNCTION | 0.00 | 0.26  | 0 | 00:36 |
| 0          | 0.00625 | 0.000    |      |       |   |       |
| Out_UEC_A  |         | JUNCTION | 0.00 | 3.35  | 0 | 01:53 |
| 0          | 0.296   | 0.000    |      |       |   |       |
| Out_UEC_B  |         | JUNCTION | 0.00 | 0.96  | 0 | 00:39 |
| 0          | 0.024   | 0.000    |      |       |   |       |
| Out_UEC_C  |         | JUNCTION | 0.00 | 0.13  | 0 | 00:37 |
| 0          | 0.00482 | 0.000    |      |       |   |       |
| Out_UEC_D  |         | JUNCTION | 0.00 | 0.73  | 0 | 00:39 |
| 0          | 0.0203  | 0.000    |      |       |   |       |
| UEC_A      |         | JUNCTION | 1.04 | 1.04  | 0 | 00:51 |
| 0.0485     | 0.0485  | 0.000    |      |       |   |       |
| UEC_B      |         | JUNCTION | 0.96 | 0.96  | 0 | 00:39 |
| 0.024      | 0.024   | 0.000    |      |       |   |       |
| UEC_C      |         | JUNCTION | 0.13 | 0.13  | 0 | 00:37 |
| 0.00482    | 0.00482 | 0.000    |      |       |   |       |
| UEC_D      |         | JUNCTION | 0.73 | 0.73  | 0 | 00:39 |
| 0.0203     | 0.0203  | 0.000    |      |       |   |       |
| Out.Dr     |         | OUTFALL  | 0.00 | 0.61  | 0 | 00:55 |
| 0          | 0.0226  | 0.000    |      |       |   |       |
| Out_C.D.E  |         | OUTFALL  | 0.00 | 2.65  | 0 | 00:47 |
| 0          | 0.0879  | 0.000    |      |       |   |       |
| Out_LC.B.F |         | OUTFALL  | 0.00 | 85.67 | 0 | 02:07 |
| 0          | 6.26    | 0.000    |      |       |   |       |
| Out_LC.G.H |         | OUTFALL  | 0.00 | 0.45  | 0 | 01:04 |
| 0          | 0.0202  | 0.000    |      |       |   |       |
| Out_LC_I   |         | OUTFALL  | 0.00 | 0.77  | 0 | 00:57 |
| 0          | 0.0402  | 0.000    |      |       |   |       |
| UEC_Out    |         | OUTFALL  | 0.00 | 3.81  | 0 | 02:27 |
| 0          | 0.366   | 0.000    |      |       |   |       |

\*\*\*\*\*  
Node Flooding Summary  
\*\*\*\*\*

No nodes were flooded.

\*\*\*\*\*  
Outfall Loading Summary  
\*\*\*\*\*

-----  
Flow            Avg            Max            Total  
Freq            Flow            Flow            Volume

*SWMM Model Existing – 5 Year*

| Outfall Node | Pcnt  | CFS   | CFS   | 10 <sup>6</sup> gal |
|--------------|-------|-------|-------|---------------------|
| Out.Dr       | 19.06 | 0.18  | 0.61  | 0.023               |
| Out_C.D.E    | 50.65 | 0.27  | 2.65  | 0.088               |
| Out_LC.B.F   | 97.89 | 9.89  | 85.67 | 6.257               |
| Out_LC.G.H   | 26.20 | 0.12  | 0.45  | 0.020               |
| Out_LC_I     | 23.48 | 0.26  | 0.77  | 0.040               |
| UEC_Out      | 97.44 | 0.58  | 3.81  | 0.366               |
| System       | 52.45 | 11.31 | 90.81 | 6.793               |

\*\*\*\*\*  
 Link Flow Summary  
 \*\*\*\*\*

| Max/<br>Full<br>Link<br>Depth | Type    | Maximum<br> Flow <br>CFS | Time of Max<br>Occurrence<br>days hr:min | Maximum<br> Veloc <br>ft/sec | Max/<br>Full<br>Flow |
|-------------------------------|---------|--------------------------|------------------------------------------|------------------------------|----------------------|
| Ch.Dr_A<br>0.05               | CONDUIT | 0.43                     | 0 00:56                                  | 1.61                         | 0.00                 |
| Ch.UEC_B<br>0.00              | CONDUIT | 0.66                     | 0 01:09                                  | 0.55                         | 0.00                 |
| CH_1<br>0.01                  | CONDUIT | 0.74                     | 0 02:56                                  | 0.54                         | 0.00                 |
| Ch_2<br>0.01                  | CONDUIT | 0.86                     | 0 03:21                                  | 0.52                         | 0.00                 |
| Ch_3<br>0.02                  | CONDUIT | 4.62                     | 0 01:42                                  | 0.89                         | 0.00                 |
| Ch_4<br>0.02                  | CONDUIT | 4.68                     | 0 01:55                                  | 0.90                         | 0.00                 |
| Ch_5<br>0.13                  | CONDUIT | 4.35                     | 0 02:28                                  | 2.60                         | 0.00                 |
| Ch_LC_A10<br>0.01             | CONDUIT | 4.58                     | 0 01:29                                  | 1.45                         | 0.00                 |
| Ch_Main<br>0.26               | CONDUIT | 72.06                    | 0 01:58                                  | 3.86                         | 0.03                 |
| Ch_OS6<br>0.02                | CONDUIT | 0.36                     | 0 01:16                                  | 1.36                         | 0.00                 |
| Ch_OS7<br>0.04                | CONDUIT | 1.83                     | 0 00:59                                  | 1.60                         | 0.00                 |
| Ch_UEC<br>0.02                | CONDUIT | 3.47                     | 0 02:30                                  | 0.63                         | 0.00                 |
| Culv_LC_A10<br>0.02           | CONDUIT | 4.60                     | 0 01:17                                  | 4.80                         | 0.00                 |
| Culv_LC_A20<br>0.01           | CONDUIT | 0.26                     | 0 00:37                                  | 2.17                         | 0.00                 |

*SWMM Model Existing – 5 Year*

|      |              |         |       |   |       |      |      |
|------|--------------|---------|-------|---|-------|------|------|
| 0.12 | Culv_OS1     | CONDUIT | 9.22  | 0 | 00:51 | 6.11 | 0.03 |
| 0.17 | Culv_OS2     | CONDUIT | 6.00  | 0 | 00:48 | 5.27 | 0.07 |
| 0.11 | Culv_OS4     | CONDUIT | 1.62  | 0 | 00:36 | 1.44 | 0.02 |
| 0.03 | Culv_OS6     | CONDUIT | 0.43  | 0 | 00:45 | 3.13 | 0.00 |
| 0.11 | Culv_OS7     | CONDUIT | 1.88  | 0 | 00:46 | 3.21 | 0.03 |
| 0.16 | Culv_OS8     | CONDUIT | 3.86  | 0 | 00:34 | 2.52 | 0.06 |
| 0.11 | Culv_OS9     | CONDUIT | 4.20  | 0 | 00:56 | 3.17 | 0.03 |
|      | Dummy_Dr_A   | DUMMY   | 0.44  | 0 | 00:44 |      |      |
|      | Dummy_Dr_B   | DUMMY   | 0.22  | 0 | 00:36 |      |      |
|      | Dummy_LC_A10 | DUMMY   | 1.42  | 0 | 00:54 |      |      |
|      | dummy_LC_A20 | DUMMY   | 0.26  | 0 | 00:37 |      |      |
|      | Dummy_LC_B   | DUMMY   | 9.42  | 0 | 01:08 |      |      |
|      | Dummy_LC_C   | DUMMY   | 0.39  | 0 | 00:35 |      |      |
|      | Dummy_LC_D   | DUMMY   | 1.21  | 0 | 00:40 |      |      |
|      | Dummy_LC_E   | DUMMY   | 1.45  | 0 | 00:40 |      |      |
|      | Dummy_LC_F   | DUMMY   | 1.44  | 0 | 00:38 |      |      |
|      | Dummy_LC_G   | DUMMY   | 0.28  | 0 | 00:47 |      |      |
|      | Dummy_LC_H   | DUMMY   | 0.26  | 0 | 00:36 |      |      |
|      | Dummy_LC_I   | DUMMY   | 0.77  | 0 | 00:57 |      |      |
|      | Dummy_OS1    | DUMMY   | 9.22  | 0 | 00:51 |      |      |
|      | Dummy_OS2    | DUMMY   | 6.00  | 0 | 00:48 |      |      |
|      | Dummy_OS3    | DUMMY   | 82.90 | 0 | 01:22 |      |      |
|      | Dummy_OS4    | DUMMY   | 1.62  | 0 | 00:36 |      |      |
|      | Dummy_OS5    | DUMMY   | 0.15  | 0 | 00:36 |      |      |
|      | Dummy_OS6    | DUMMY   | 0.43  | 0 | 00:45 |      |      |
|      | Dummy_OS7    | DUMMY   | 1.88  | 0 | 00:45 |      |      |
|      | Dummy_Os8    | DUMMY   | 3.86  | 0 | 00:34 |      |      |
|      | Dummy_OS9    | DUMMY   | 4.20  | 0 | 00:56 |      |      |
|      | Dummy_UEC_A  | DUMMY   | 1.04  | 0 | 00:51 |      |      |
|      | Dummy_UEC_B  | DUMMY   | 0.96  | 0 | 00:39 |      |      |
|      | Dummy_UEC_C  | DUMMY   | 0.13  | 0 | 00:37 |      |      |
|      | Dummy_UEC_D  | DUMMY   | 0.73  | 0 | 00:39 |      |      |
| 0.00 | Over.Dr_B    | CONDUIT | 0.18  | 0 | 00:53 | 0.00 | 0.00 |
| 0.10 | Over.LC_B    | CONDUIT | 85.37 | 0 | 02:07 | 1.24 | 0.02 |
| 0.00 | Over.LC_C    | CONDUIT | 0.21  | 0 | 01:29 | 0.00 | 0.00 |
| 0.03 | Over.LC_D    | CONDUIT | 1.17  | 0 | 00:46 | 0.22 | 0.00 |
| 0.04 | Over.LC_E    | CONDUIT | 1.40  | 0 | 00:47 | 0.19 | 0.00 |
| 0.01 | Over.LC_F    | CONDUIT | 1.17  | 0 | 00:55 | 0.44 | 0.00 |
| 0.00 | Over.LC_G    | CONDUIT | 0.26  | 0 | 01:08 | 0.00 | 0.00 |

SWMM Model Existing – 5 Year

|                     |         |      |   |       |      |      |
|---------------------|---------|------|---|-------|------|------|
| Over.LC_H<br>0.00   | CONDUIT | 0.20 | 0 | 00:58 | 0.00 | 0.00 |
| Over.UEC_A<br>0.02  | CONDUIT | 3.22 | 0 | 02:22 | 0.77 | 0.00 |
| Over.UEC_C<br>0.00  | CONDUIT | 0.07 | 0 | 02:14 | 0.00 | 0.00 |
| Over.UEC_D<br>0.01  | CONDUIT | 0.44 | 0 | 01:32 | 0.44 | 0.00 |
| Over_LC_A20<br>0.15 | CONDUIT | 0.24 | 0 | 00:54 | 0.88 | 0.01 |
| Over_OS1<br>0.02    | CONDUIT | 5.29 | 0 | 02:25 | 0.84 | 0.00 |
| Over_OS2<br>0.01    | CONDUIT | 4.57 | 0 | 01:46 | 0.73 | 0.00 |
| Over_OS4<br>0.00    | CONDUIT | 0.77 | 0 | 01:33 | 0.64 | 0.00 |
| Over_OS5<br>0.00    | CONDUIT | 0.08 | 0 | 03:35 | 0.00 | 0.00 |
| Over_OS8<br>0.01    | CONDUIT | 1.93 | 0 | 01:30 | 0.61 | 0.00 |
| Over_OS9<br>0.01    | CONDUIT | 2.81 | 0 | 01:57 | 0.54 | 0.00 |

\*\*\*\*\*  
Conduit Surcharge Summary  
\*\*\*\*\*

No conduits were surcharged.

Analysis begun on: Mon Dec 16 14:42:50 2024  
Analysis ended on: Mon Dec 16 14:42:50 2024  
Total elapsed time: < 1 sec

## SWMM Model Existing – 100 Year

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.4)

---

\*\*\*\*\*

Element Count

\*\*\*\*\*

Number of rain gages ..... 0  
 Number of subcatchments ... 0  
 Number of nodes ..... 70  
 Number of links ..... 64  
 Number of pollutants ..... 0  
 Number of land uses ..... 0

\*\*\*\*\*

Node Summary

\*\*\*\*\*

| External<br>Name | Type | Invert<br>Elev. | Max.<br>Depth | Ponded<br>Area |
|------------------|------|-----------------|---------------|----------------|
|------------------|------|-----------------|---------------|----------------|

---

|          |          |         |       |     |
|----------|----------|---------|-------|-----|
| DP_OS1   | JUNCTION | 6282.45 | 3.00  | 0.0 |
| DP_OS2   | JUNCTION | 6313.76 | 2.50  | 0.0 |
| DP_OS3   | JUNCTION | 6290.51 | 6.00  | 0.0 |
| DP_OS4   | JUNCTION | 6420.09 | 3.50  | 0.0 |
| DP_OS5   | JUNCTION | 6440.72 | 5.00  | 0.0 |
| DP_OS6   | JUNCTION | 6428.06 | 3.00  | 0.0 |
| DP_OS7   | JUNCTION | 6392.28 | 2.00  | 0.0 |
| DP_OS8   | JUNCTION | 6393.20 | 2.50  | 0.0 |
| DP_OS9   | JUNCTION | 6359.19 | 3.00  | 0.0 |
| Dr_A     | JUNCTION | 6347.11 | 0.00  | 0.0 |
| Dr_B     | JUNCTION | 6329.34 | 0.00  | 0.0 |
| J.UEC.1  | JUNCTION | 6281.05 | 5.00  | 0.0 |
| J_LC_A10 | JUNCTION | 6346.58 | 10.00 | 0.0 |
| J_LC_A20 | JUNCTION | 6320.63 | 3.00  | 0.0 |
| J_OS1    | JUNCTION | 6277.94 | 3.00  | 0.0 |
| J_OS2    | JUNCTION | 6310.41 | 5.00  | 0.0 |
| J_OS4    | JUNCTION | 6420.00 | 5.00  | 0.0 |
| J_OS6    | JUNCTION | 6425.61 | 5.00  | 0.0 |
| J_OS7    | JUNCTION | 6388.69 | 3.00  | 0.0 |
| J_OS8    | JUNCTION | 6391.98 | 2.50  | 0.0 |
| J_OS9    | JUNCTION | 6357.73 | 3.00  | 0.0 |
| J1       | JUNCTION | 6355.74 | 5.00  | 0.0 |
| J2       | JUNCTION | 6323.35 | 5.00  | 0.0 |
| J2_OS2   | JUNCTION | 6250.19 | 5.00  | 0.0 |
| J3       | JUNCTION | 6305.72 | 10.00 | 0.0 |
| J4       | JUNCTION | 6298.21 | 5.00  | 0.0 |
| LC_A10   | JUNCTION | 6393.58 | 0.00  | 0.0 |
| LC_A20   | JUNCTION | 6358.75 | 0.00  | 0.0 |
| LC_B     | JUNCTION | 6284.81 | 0.00  | 0.0 |



SWMM Model Existing – 100 Year

|            |          |         |      |     |
|------------|----------|---------|------|-----|
| LC_C       | JUNCTION | 6267.21 | 0.00 | 0.0 |
| LC_D       | JUNCTION | 6254.31 | 0.00 | 0.0 |
| LC_E       | JUNCTION | 6248.16 | 0.00 | 0.0 |
| LC_F       | JUNCTION | 6246.12 | 0.00 | 0.0 |
| LC_G       | JUNCTION | 6234.42 | 0.00 | 0.0 |
| LC_H       | JUNCTION | 6237.87 | 0.00 | 0.0 |
| LC_I       | JUNCTION | 6282.51 | 0.00 | 0.0 |
| OS1        | JUNCTION | 6349.15 | 0.00 | 0.0 |
| OS2        | JUNCTION | 6342.30 | 0.00 | 0.0 |
| OS3        | JUNCTION | 6453.31 | 0.00 | 0.0 |
| OS4        | JUNCTION | 6462.88 | 0.00 | 0.0 |
| OS5        | JUNCTION | 6448.20 | 0.00 | 0.0 |
| OS6        | JUNCTION | 6428.17 | 0.00 | 0.0 |
| OS7        | JUNCTION | 6416.17 | 0.00 | 0.0 |
| OS8        | JUNCTION | 6415.01 | 0.00 | 0.0 |
| OS9        | JUNCTION | 6429.66 | 0.00 | 0.0 |
| Out_Dr_A   | JUNCTION | 6327.48 | 4.50 | 0.0 |
| Out_Dr_B   | JUNCTION | 6315.27 | 2.00 | 0.0 |
| Out_LC_A10 | JUNCTION | 6349.20 | 8.00 | 0.0 |
| Out_LC_A20 | JUNCTION | 6322.30 | 3.00 | 0.0 |
| Out_LC_B   | JUNCTION | 6211.12 | 6.00 | 0.0 |
| Out_LC_C   | JUNCTION | 6255.23 | 2.00 | 0.0 |
| Out_LC_D   | JUNCTION | 6244.47 | 2.00 | 0.0 |
| Out_LC_E   | JUNCTION | 6244.40 | 2.00 | 0.0 |
| Out_LC_F   | JUNCTION | 6207.25 | 2.00 | 0.0 |
| Out_LC_G   | JUNCTION | 6211.83 | 2.00 | 0.0 |
| Out_LC_H   | JUNCTION | 6211.23 | 2.00 | 0.0 |
| Out_UEC_A  | JUNCTION | 6318.87 | 2.00 | 0.0 |
| Out_UEC_B  | JUNCTION | 6302.81 | 5.00 | 0.0 |
| Out_UEC_C  | JUNCTION | 6327.09 | 2.00 | 0.0 |
| Out_UEC_D  | JUNCTION | 6344.99 | 2.00 | 0.0 |
| UEC_A      | JUNCTION | 6349.56 | 0.00 | 0.0 |
| UEC_B      | JUNCTION | 6354.84 | 0.00 | 0.0 |
| UEC_C      | JUNCTION | 6357.45 | 0.00 | 0.0 |
| UEC_D      | JUNCTION | 6349.03 | 0.00 | 0.0 |
| Out.Dr     | OUTFALL  | 6301.67 | 4.50 | 0.0 |
| Out_C.D.E  | OUTFALL  | 6244.35 | 2.00 | 0.0 |
| Out_LC.B.F | OUTFALL  | 6201.53 | 2.00 | 0.0 |
| Out_LC.G.H | OUTFALL  | 6202.07 | 2.00 | 0.0 |
| Out_LC_I   | OUTFALL  | 6254.02 | 0.00 | 0.0 |
| UEC_Out    | OUTFALL  | 6278.45 | 5.00 | 0.0 |

\*\*\*\*\*

Link Summary

\*\*\*\*\*

| Name     | From Node | To Node   | Type    |
|----------|-----------|-----------|---------|
| Length   | %Slope    | Roughness |         |
| Ch.Dr_A  | Out_Dr_A  | Out.Dr    | CONDUIT |
| 1135.0   | 2.2744    | 0.0320    |         |
| Ch.UEC_B | Out_UEC_B | J.UEC.1   | CONDUIT |
| 1351.3   | 1.6111    | 0.0320    |         |

*SWMM Model Existing – 100 Year*

|              |        |            |            |         |
|--------------|--------|------------|------------|---------|
| CH_1         |        | J1         | J2         | CONDUIT |
| 2593.7       | 1.2488 | 0.0320     |            |         |
| Ch_2         |        | J2         | J3         | CONDUIT |
| 1678.2       | 1.0507 | 0.0320     |            |         |
| Ch_3         |        | J3         | J4         | CONDUIT |
| 973.6        | 0.7710 | 0.0320     |            |         |
| Ch_4         |        | J4         | DP_OS3     | CONDUIT |
| 998.0        | 0.7716 | 0.0320     |            |         |
| Ch_5         |        | J2_OS2     | Out_LC_B   | CONDUIT |
| 4798.2       | 0.8143 | 0.0320     |            |         |
| Ch_LC_A10    |        | J_LC_A10   | J3         | CONDUIT |
| 1414.2       | 2.8909 | 0.0320     |            |         |
| Ch_Main      |        | DP_OS3     | Out_LC_B   | CONDUIT |
| 9436.1       | 0.8414 | 0.0320     |            |         |
| Ch_OS6       |        | J_OS6      | J2         | CONDUIT |
| 2634.9       | 3.8840 | 0.0350     |            |         |
| Ch_OS7       |        | J_OS7      | Out_LC_A10 | CONDUIT |
| 1441.9       | 2.7395 | 0.0350     |            |         |
| Ch_UEC       |        | J.UEC.1    | UEC_Out    | CONDUIT |
| 737.2        | 0.3521 | 0.0320     |            |         |
| Culv_LC_A10  |        | Out_LC_A10 | J_LC_A10   | CONDUIT |
| 120.5        | 2.1763 | 0.0130     |            |         |
| Culv_LC_A20  |        | Out_LC_A20 | J_LC_A20   | CONDUIT |
| 61.7         | 2.7100 | 0.0130     |            |         |
| Culv_OS1     |        | DP_OS1     | J_OS1      | CONDUIT |
| 67.5         | 6.6934 | 0.0240     |            |         |
| Culv_OS2     |        | DP_OS2     | J_OS2      | CONDUIT |
| 79.1         | 4.2307 | 0.0240     |            |         |
| Culv_OS4     |        | DP_OS4     | J_OS4      | CONDUIT |
| 87.0         | 0.1068 | 0.0130     |            |         |
| Culv_OS6     |        | DP_OS6     | J_OS6      | CONDUIT |
| 82.4         | 2.9775 | 0.0130     |            |         |
| Culv_OS7     |        | DP_OS7     | J_OS7      | CONDUIT |
| 99.0         | 3.6291 | 0.0240     |            |         |
| Culv_OS8     |        | DP_OS8     | J_OS8      | CONDUIT |
| 114.8        | 1.0631 | 0.0240     |            |         |
| Culv_OS9     |        | DP_OS9     | J_OS9      | CONDUIT |
| 93.8         | 1.5617 | 0.0210     |            |         |
| Dummy_Dr_A   |        | Dr_A       | Out_Dr_A   | CONDUIT |
| 1154.7       | 1.7000 | 0.0100     |            |         |
| Dummy_Dr_B   |        | Dr_B       | Out_Dr_B   | CONDUIT |
| 662.0        | 2.1265 | 0.0100     |            |         |
| Dummy_LC_A10 |        | LC_A10     | Out_LC_A10 | CONDUIT |
| 2079.4       | 2.1348 | 0.0100     |            |         |
| dummy_LC_A20 |        | LC_A20     | Out_LC_A20 | CONDUIT |
| 613.0        | 5.9554 | 0.0100     |            |         |
| Dummy_LC_B   |        | LC_B       | Out_LC_B   | CONDUIT |
| 5629.3       | 1.3093 | 0.0100     |            |         |
| Dummy_LC_C   |        | LC_C       | Out_LC_C   | CONDUIT |
| 708.8        | 1.6912 | 0.0100     |            |         |
| Dummy_LC_D   |        | LC_D       | Out_LC_D   | CONDUIT |
| 691.2        | 1.4232 | 0.0100     |            |         |
| Dummy_LC_E   |        | LC_E       | Out_LC_E   | CONDUIT |
| 646.2        | 0.5819 | 0.0100     |            |         |

*SWMM Model Existing – 100 Year*

|               |           |            |         |
|---------------|-----------|------------|---------|
| Dummy_LC_F    | LC_F      | Out_LC_F   | CONDUIT |
| 1332.0 2.9192 | 0.0100    |            |         |
| Dummy_LC_G    | LC_G      | Out_LC_G   | CONDUIT |
| 842.5 2.6821  | 0.0100    |            |         |
| Dummy_LC_H    | LC_H      | Out_LC_H   | CONDUIT |
| 579.9 4.5972  | 0.0100    |            |         |
| Dummy_LC_I    | LC_I      | Out_LC_I   | CONDUIT |
| 1517.8 1.8774 | 0.0100    |            |         |
| Dummy_OS1     | OS1       | DP_OS1     | CONDUIT |
| 3482.0 1.9161 | 0.0100    |            |         |
| Dummy_OS2     | OS2       | DP_OS2     | CONDUIT |
| 1242.8 2.2974 | 0.0100    |            |         |
| Dummy_OS3     | OS3       | DP_OS3     | CONDUIT |
| 9018.4 1.8056 | 0.0100    |            |         |
| Dummy_OS4     | OS4       | DP_OS4     | CONDUIT |
| 811.6 5.2783  | 0.0100    |            |         |
| Dummy_OS5     | OS5       | DP_OS5     | CONDUIT |
| 395.2 1.8938  | 0.0100    |            |         |
| Dummy_OS6     | OS6       | DP_OS6     | CONDUIT |
| 1040.0 0.0101 | 0.0100    |            |         |
| Dummy_OS7     | OS7       | DP_OS7     | CONDUIT |
| 657.7 3.6352  | 0.0100    |            |         |
| Dummy_OS8     | OS8       | DP_OS8     | CONDUIT |
| 393.2 5.5555  | 0.0100    |            |         |
| Dummy_OS9     | OS9       | DP_OS9     | CONDUIT |
| 2515.8 2.8023 | 0.0100    |            |         |
| Dummy_UEC_A   | UEC_A     | Out_UEC_A  | CONDUIT |
| 1521.5 2.0172 | 0.0100    |            |         |
| Dummy_UEC_B   | UEC_B     | Out_UEC_B  | CONDUIT |
| 1679.8 3.0990 | 0.0100    |            |         |
| Dummy_UEC_C   | UEC_C     | Out_UEC_C  | CONDUIT |
| 695.7 4.3682  | 0.0100    |            |         |
| Dummy_UEC_D   | UEC_D     | Out_UEC_D  | CONDUIT |
| 352.4 1.1481  | 0.0100    |            |         |
| Over.Dr_B     | Out_Dr_B  | Out.Dr     | CONDUIT |
| 359.0 3.7902  | 0.0350    |            |         |
| Over.LC_B     | Out_LC_B  | Out_LC.B.F | CONDUIT |
| 944.5 1.0146  | 0.0350    |            |         |
| Over.LC_C     | Out_LC_C  | Out_C.D.E  | CONDUIT |
| 1183.0 0.9194 | 0.0350    |            |         |
| Over.LC_D     | Out_LC_D  | Out_C.D.E  | CONDUIT |
| 93.9 0.1289   | 0.0350    |            |         |
| Over.LC_E     | Out_LC_E  | Out_C.D.E  | CONDUIT |
| 86.0 0.0605   | 0.0350    |            |         |
| Over.LC_F     | Out_LC_F  | Out_LC.B.F | CONDUIT |
| 531.3 1.0764  | 0.0350    |            |         |
| Over.LC_G     | Out_LC_G  | Out_LC.G.H | CONDUIT |
| 447.1 2.1828  | 0.0350    |            |         |
| Over.LC_H     | Out_LC_H  | Out_LC.G.H | CONDUIT |
| 442.2 2.0720  | 0.0350    |            |         |
| Over.UEC_A    | Out_UEC_A | J.UEC.1    | CONDUIT |
| 1781.8 2.1235 | 0.0350    |            |         |
| Over.UEC_C    | Out_UEC_C | UEC_Out    | CONDUIT |
| 1664.0 2.9246 | 0.0350    |            |         |

*SWMM Model Existing – 100 Year*

|                  |           |            |         |
|------------------|-----------|------------|---------|
| Over_UEC_D       | Out_UEC_D | UEC_Out    | CONDUIT |
| 1915.6    3.4756 | 0.0350    |            |         |
| Over_LC_A20      | J_LC_A20  | J4         | CONDUIT |
| 707.8    3.1696  | 0.0350    |            |         |
| Over_OS1         | J_OS1     | Out_LC_B   | CONDUIT |
| 5800.5    1.1521 | 0.0350    |            |         |
| Over_OS2         | J_OS2     | J2_OS2     | CONDUIT |
| 2743.3    2.1958 | 0.0350    |            |         |
| Over_OS4         | J_OS4     | J1         | CONDUIT |
| 3674.0    1.7494 | 0.0350    |            |         |
| Over_OS5         | DP_OS5    | J1         | CONDUIT |
| 3464.9    2.4535 | 0.0300    |            |         |
| Over_OS8         | J_OS8     | Out_LC_A10 | CONDUIT |
| 3170.1    1.3495 | 0.0350    |            |         |
| Over_OS9         | J_OS9     | Out_UEC_A  | CONDUIT |
| 2802.5    1.3865 | 0.0350    |            |         |

\*\*\*\*\*  
 Cross Section Summary  
 \*\*\*\*\*

| No. of  | Full                   |             | Full  | Full   | Hyd. | Max.   |
|---------|------------------------|-------------|-------|--------|------|--------|
| Conduit | Flow                   | Shape       | Depth | Area   | Rad. | Width  |
| Barrels |                        |             |       |        |      |        |
| -----   |                        |             |       |        |      |        |
| 1       | Ch.Dr_A<br>1475.06     | TRIANGULAR  | 4.50  | 123.75 | 2.22 | 55.00  |
| 1       | Ch.UEC_B<br>5055.78    | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
| 1       | CH_1<br>4666.46        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_2<br>4280.31        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_3<br>3666.59        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_4<br>3668.12        | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1       | Ch_5<br>952.35         | TRIANGULAR  | 5.00  | 125.00 | 2.45 | 50.00  |
| 1       | Ch_LC_A10<br>24339.02  | TRAPEZOIDAL | 10.00 | 900.00 | 6.34 | 140.00 |
| 1       | Ch_Main<br>2645.44     | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
| 1       | Ch_OS6<br>7700.00      | TRIANGULAR  | 5.00  | 500.00 | 2.50 | 200.00 |
| 1       | Ch_OS7<br>711.46       | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
| 1       | Ch_UEC<br>2363.59      | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
| 1       | Culv_LC_A10<br>1159.39 | RECT_CLOSED | 8.00  | 48.00  | 1.71 | 6.00   |

*SWMM Model Existing – 100 Year*

|   |              |             |      |      |      |      |
|---|--------------|-------------|------|------|------|------|
| 1 | Culv_LC_A20  | RECT_CLOSED | 3.00 | 9.00 | 0.75 | 3.00 |
| 1 | 139.80       |             |      |      |      |      |
| 3 | Culv_OS1     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 3 | 93.47        |             |      |      |      |      |
| 2 | Culv_OS2     | CIRCULAR    | 2.50 | 4.91 | 0.62 | 2.50 |
| 2 | 45.70        |             |      |      |      |      |
| 2 | Culv_OS4     | CIRCULAR    | 3.50 | 9.62 | 0.88 | 3.50 |
| 2 | 32.88        |             |      |      |      |      |
| 2 | Culv_OS6     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 2 | 115.09       |             |      |      |      |      |
| 3 | Culv_OS7     | CIRCULAR    | 2.00 | 3.14 | 0.50 | 2.00 |
| 3 | 23.34        |             |      |      |      |      |
| 3 | Culv_OS8     | CIRCULAR    | 2.50 | 4.91 | 0.62 | 2.50 |
| 3 | 22.91        |             |      |      |      |      |
| 3 | Culv_OS9     | CIRCULAR    | 3.00 | 7.07 | 0.75 | 3.00 |
| 3 | 51.60        |             |      |      |      |      |
| 1 | Dummy_Dr_A   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_Dr_B   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_A10 | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | dummy_LC_A20 | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_B   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_C   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_D   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_E   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_F   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_G   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_H   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_LC_I   | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS1    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS2    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS3    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS4    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS5    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS6    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |
| 1 | Dummy_OS7    | DUMMY       | 0.00 | 0.00 | 0.00 | 0.00 |
| 1 | 0.00         |             |      |      |      |      |

*SWMM Model Existing – 100 Year*

|   |             |             |      |         |      |        |
|---|-------------|-------------|------|---------|------|--------|
| 1 | Dummy_Os8   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Dummy_OS9   | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Dummy_UEC_A | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Dummy_UEC_B | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Dummy_UEC_C | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Dummy_UEC_D | DUMMY       | 0.00 | 0.00    | 0.00 | 0.00   |
|   | 0.00        |             |      |         |      |        |
| 1 | Over.Dr_B   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 2556.48     |             |      |         |      |        |
| 1 | Over.LC_B   | RECT_OPEN   | 1.50 | 675.00  | 1.49 | 450.00 |
|   | 3765.95     |             |      |         |      |        |
| 1 | Over.LC_C   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 1259.11     |             |      |         |      |        |
| 1 | Over.LC_D   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 471.43      |             |      |         |      |        |
| 1 | Over.LC_E   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 322.88      |             |      |         |      |        |
| 1 | Over.LC_F   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 1362.36     |             |      |         |      |        |
| 1 | Over.LC_G   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 1940.07     |             |      |         |      |        |
| 1 | Over.LC_H   | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 1890.20     |             |      |         |      |        |
| 1 | Over.UEC_A  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 1913.55     |             |      |         |      |        |
| 1 | Over.UEC_C  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 2245.67     |             |      |         |      |        |
| 1 | Over.UEC_D  | RECT_OPEN   | 2.00 | 200.00  | 1.92 | 100.00 |
|   | 2448.08     |             |      |         |      |        |
| 1 | Over.LC_A20 | TRIANGULAR  | 0.50 | 12.50   | 0.25 | 50.00  |
|   | 37.49       |             |      |         |      |        |
| 1 | Over_OS1    | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |
|   | 2855.66     |             |      |         |      |        |
| 1 | Over_OS2    | RECT_OPEN   | 5.00 | 1000.00 | 4.76 | 200.00 |
|   | 17807.57    |             |      |         |      |        |
| 1 | Over_OS4    | TRAPEZOIDAL | 5.00 | 600.00  | 4.25 | 140.00 |
|   | 8838.21     |             |      |         |      |        |
| 1 | Over_OS5    | RECT_OPEN   | 5.00 | 500.00  | 4.55 | 100.00 |
|   | 10645.06    |             |      |         |      |        |
| 1 | Over_OS8    | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |
|   | 3090.62     |             |      |         |      |        |
| 1 | Over_OS9    | RECT_OPEN   | 2.00 | 400.00  | 1.96 | 200.00 |
|   | 3132.77     |             |      |         |      |        |

\*\*\*\*\*

Analysis Options

\*\*\*\*\*

Flow Units ..... CFS

## SWMM Model Existing – 100 Year

Process Models:

```

Rainfall/Runoff ..... NO
RDII ..... NO
Snowmelt ..... NO
Groundwater ..... NO
Flow Routing ..... YES
Ponding Allowed ..... NO
Water Quality ..... NO
Flow Routing Method ..... KINWAVE
Starting Date ..... 01/01/2024 00:00:00
Ending Date ..... 01/02/2024 00:00:00
Antecedent Dry Days ..... 0.0
Report Time Step ..... 00:01:00
Routing Time Step ..... 5.00 sec
    
```

|                            | Volume<br>acre-feet | Volume<br>10 <sup>6</sup> gal |
|----------------------------|---------------------|-------------------------------|
|                            | -----               | -----                         |
| Flow Routing Continuity    |                     |                               |
| Dry Weather Inflow .....   | 0.000               | 0.000                         |
| Wet Weather Inflow .....   | 0.000               | 0.000                         |
| Groundwater Inflow .....   | 0.000               | 0.000                         |
| RDII Inflow .....          | 0.000               | 0.000                         |
| External Inflow .....      | 504.097             | 164.267                       |
| External Outflow .....     | 512.481             | 167.000                       |
| Flooding Loss .....        | 0.000               | 0.000                         |
| Evaporation Loss .....     | 0.000               | 0.000                         |
| Exfiltration Loss .....    | 0.000               | 0.000                         |
| Initial Stored Volume .... | 0.000               | 0.000                         |
| Final Stored Volume .....  | 0.081               | 0.026                         |
| Continuity Error (%) ..... | -1.679              |                               |

```

*****
Highest Flow Instability Indexes
*****
All links are stable.
    
```

```

*****
Routing Time Step Summary
*****
Minimum Time Step      :      5.00 sec
Average Time Step      :      5.00 sec
Maximum Time Step      :      5.00 sec
% of Time in Steady State :      0.00
Average Iterations per Step :      1.00
% of Steps Not Converging :      0.00
    
```

```

*****
Node Depth Summary
*****
    
```

*SWMM Model Existing – 100 Year*

| Reported<br>Max Depth<br>Node<br>Feet | Type     | Average<br>Depth<br>Feet | Maximum<br>Depth<br>Feet | Maximum<br>HGL<br>Feet | Time of Max<br>Occurrence<br>days hr:min |
|---------------------------------------|----------|--------------------------|--------------------------|------------------------|------------------------------------------|
| 2.08                                  | JUNCTION | 0.17                     | 2.08                     | 6284.52                | 0 00:58                                  |
| 1.40                                  | JUNCTION | 0.14                     | 1.40                     | 6315.15                | 0 00:54                                  |
| 5.43                                  | JUNCTION | 0.83                     | 5.43                     | 6295.94                | 0 01:27                                  |
| 2.62                                  | JUNCTION | 0.12                     | 2.62                     | 6422.71                | 0 00:44                                  |
| 0.04                                  | JUNCTION | 0.00                     | 0.04                     | 6440.77                | 0 00:46                                  |
| 0.69                                  | JUNCTION | 0.07                     | 0.69                     | 6428.75                | 0 00:54                                  |
| 0.83                                  | JUNCTION | 0.08                     | 0.83                     | 6393.11                | 0 00:55                                  |
| 1.78                                  | JUNCTION | 0.09                     | 1.78                     | 6394.98                | 0 00:43                                  |
| 2.19                                  | JUNCTION | 0.23                     | 2.19                     | 6361.38                | 0 01:08                                  |
| 0.00                                  | JUNCTION | 0.00                     | 0.00                     | 6347.11                | 0 00:00                                  |
| 0.00                                  | JUNCTION | 0.00                     | 0.00                     | 6329.34                | 0 00:00                                  |
| 1.32                                  | JUNCTION | 0.16                     | 1.32                     | 6282.36                | 0 01:20                                  |
| 1.36                                  | JUNCTION | 0.13                     | 1.36                     | 6347.94                | 0 01:10                                  |
| 0.42                                  | JUNCTION | 0.03                     | 0.42                     | 6321.06                | 0 00:47                                  |
| 2.07                                  | JUNCTION | 0.17                     | 2.08                     | 6280.01                | 0 00:58                                  |
| 1.40                                  | JUNCTION | 0.14                     | 1.40                     | 6311.81                | 0 00:54                                  |
| 2.62                                  | JUNCTION | 0.12                     | 2.62                     | 6422.62                | 0 00:44                                  |
| 0.69                                  | JUNCTION | 0.07                     | 0.69                     | 6426.30                | 0 00:54                                  |
| 0.83                                  | JUNCTION | 0.08                     | 0.83                     | 6389.52                | 0 00:55                                  |
| 1.78                                  | JUNCTION | 0.09                     | 1.78                     | 6393.75                | 0 00:43                                  |
| 2.19                                  | JUNCTION | 0.23                     | 2.19                     | 6359.92                | 0 01:08                                  |
| 0.36                                  | JUNCTION | 0.03                     | 0.36                     | 6356.09                | 0 01:05                                  |



*SWMM Model Existing – 100 Year*

|                    |          |      |      |         |   |       |
|--------------------|----------|------|------|---------|---|-------|
| J2<br>0.59         | JUNCTION | 0.08 | 0.59 | 6323.94 | 0 | 01:05 |
| J2_OS2<br>1.65     | JUNCTION | 0.27 | 1.65 | 6251.84 | 0 | 01:15 |
| J3<br>0.95         | JUNCTION | 0.10 | 0.95 | 6306.67 | 0 | 01:18 |
| J4<br>0.97         | JUNCTION | 0.11 | 0.97 | 6299.18 | 0 | 01:21 |
| LC_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6393.58 | 0 | 00:00 |
| LC_A20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6358.75 | 0 | 00:00 |
| LC_B<br>0.00       | JUNCTION | 0.00 | 0.00 | 6284.81 | 0 | 00:00 |
| LC_C<br>0.00       | JUNCTION | 0.00 | 0.00 | 6267.21 | 0 | 00:00 |
| LC_D<br>0.00       | JUNCTION | 0.00 | 0.00 | 6254.31 | 0 | 00:00 |
| LC_E<br>0.00       | JUNCTION | 0.00 | 0.00 | 6248.16 | 0 | 00:00 |
| LC_F<br>0.00       | JUNCTION | 0.00 | 0.00 | 6246.12 | 0 | 00:00 |
| LC_G<br>0.00       | JUNCTION | 0.00 | 0.00 | 6234.42 | 0 | 00:00 |
| LC_H<br>0.00       | JUNCTION | 0.00 | 0.00 | 6237.87 | 0 | 00:00 |
| LC_I<br>0.00       | JUNCTION | 0.00 | 0.00 | 6282.51 | 0 | 00:00 |
| OS1<br>0.00        | JUNCTION | 0.00 | 0.00 | 6349.15 | 0 | 00:00 |
| OS2<br>0.00        | JUNCTION | 0.00 | 0.00 | 6342.30 | 0 | 00:00 |
| OS3<br>0.00        | JUNCTION | 0.00 | 0.00 | 6453.31 | 0 | 00:00 |
| OS4<br>0.00        | JUNCTION | 0.00 | 0.00 | 6462.88 | 0 | 00:00 |
| OS5<br>0.00        | JUNCTION | 0.00 | 0.00 | 6448.20 | 0 | 00:00 |
| OS6<br>0.00        | JUNCTION | 0.00 | 0.00 | 6428.17 | 0 | 00:00 |
| OS7<br>0.00        | JUNCTION | 0.00 | 0.00 | 6416.17 | 0 | 00:00 |
| OS8<br>0.00        | JUNCTION | 0.00 | 0.00 | 6415.01 | 0 | 00:00 |
| OS9<br>0.00        | JUNCTION | 0.00 | 0.00 | 6429.66 | 0 | 00:00 |
| Out_Dr_A<br>1.13   | JUNCTION | 0.12 | 1.13 | 6328.61 | 0 | 00:55 |
| Out_Dr_B<br>0.10   | JUNCTION | 0.01 | 0.10 | 6315.37 | 0 | 00:46 |
| Out_LC_A10<br>1.36 | JUNCTION | 0.13 | 1.36 | 6350.56 | 0 | 01:09 |
| Out_LC_A20<br>0.42 | JUNCTION | 0.03 | 0.42 | 6322.73 | 0 | 00:47 |

*SWMM Model Existing – 100 Year*

|            |          |      |      |         |   |       |
|------------|----------|------|------|---------|---|-------|
| Out_LC_B   | JUNCTION | 0.89 | 5.36 | 6216.48 | 0 | 01:42 |
| 5.36       |          |      |      |         |   |       |
| Out_LC_C   | JUNCTION | 0.01 | 0.19 | 6255.42 | 0 | 00:44 |
| 0.19       |          |      |      |         |   |       |
| Out_LC_D   | JUNCTION | 0.02 | 0.34 | 6244.81 | 0 | 00:48 |
| 0.34       |          |      |      |         |   |       |
| Out_LC_E   | JUNCTION | 0.03 | 0.49 | 6244.89 | 0 | 00:49 |
| 0.49       |          |      |      |         |   |       |
| Out_LC_F   | JUNCTION | 0.02 | 0.44 | 6207.69 | 0 | 00:46 |
| 0.44       |          |      |      |         |   |       |
| Out_LC_G   | JUNCTION | 0.01 | 0.13 | 6211.97 | 0 | 00:57 |
| 0.13       |          |      |      |         |   |       |
| Out_LC_H   | JUNCTION | 0.01 | 0.12 | 6211.36 | 0 | 00:43 |
| 0.12       |          |      |      |         |   |       |
| Out_UEC_A  | JUNCTION | 0.06 | 0.47 | 6319.34 | 0 | 01:20 |
| 0.47       |          |      |      |         |   |       |
| Out_UEC_B  | JUNCTION | 0.03 | 0.48 | 6303.29 | 0 | 00:49 |
| 0.48       |          |      |      |         |   |       |
| Out_UEC_C  | JUNCTION | 0.01 | 0.09 | 6327.18 | 0 | 00:51 |
| 0.09       |          |      |      |         |   |       |
| Out_UEC_D  | JUNCTION | 0.01 | 0.09 | 6345.08 | 0 | 00:48 |
| 0.09       |          |      |      |         |   |       |
| UEC_A      | JUNCTION | 0.00 | 0.00 | 6349.56 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_B      | JUNCTION | 0.00 | 0.00 | 6354.84 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_C      | JUNCTION | 0.00 | 0.00 | 6357.45 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_D      | JUNCTION | 0.00 | 0.00 | 6349.03 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| Out.Dr     | OUTFALL  | 0.12 | 1.13 | 6302.80 | 0 | 00:58 |
| 1.13       |          |      |      |         |   |       |
| Out_C.D.E  | OUTFALL  | 0.03 | 0.49 | 6244.84 | 0 | 00:50 |
| 0.49       |          |      |      |         |   |       |
| Out_LC.B.F | OUTFALL  | 0.15 | 1.24 | 6202.77 | 0 | 01:40 |
| 1.24       |          |      |      |         |   |       |
| Out_LC.G.H | OUTFALL  | 0.01 | 0.13 | 6202.21 | 0 | 00:59 |
| 0.13       |          |      |      |         |   |       |
| Out_LC_I   | OUTFALL  | 0.00 | 0.00 | 6254.02 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_Out    | OUTFALL  | 0.16 | 1.32 | 6279.76 | 0 | 01:22 |
| 1.32       |          |      |      |         |   |       |

\*\*\*\*\*  
Node Inflow Summary  
\*\*\*\*\*

-----  
-----

| Lateral | Total  | Flow    | Maximum | Maximum |             |
|---------|--------|---------|---------|---------|-------------|
| Inflow  | Inflow | Balance | Lateral | Total   | Time of Max |

*SWMM Model Existing – 100 Year*

| Volume<br>Node<br>gal | Volume<br>10 <sup>6</sup> gal | Error<br>Type<br>Percent | Inflow<br>CFS | Inflow<br>CFS | Occurrence<br>days hr:min | 10 <sup>6</sup> |
|-----------------------|-------------------------------|--------------------------|---------------|---------------|---------------------------|-----------------|
| DP_OS1                |                               | JUNCTION                 | 0.00          | 230.99        | 0 00:58                   |                 |
| 0                     | 8.6                           | 0.000                    |               |               |                           |                 |
| DP_OS2                |                               | JUNCTION                 | 0.00          | 55.02         | 0 00:54                   |                 |
| 0                     | 2.37                          | 0.000                    |               |               |                           |                 |
| DP_OS3                |                               | JUNCTION                 | 0.00          | 2031.29       | 0 01:27                   |                 |
| 0                     | 97                            | 0.000                    |               |               |                           |                 |
| DP_OS4                |                               | JUNCTION                 | 0.00          | 59.67         | 0 00:44                   |                 |
| 0                     | 1.3                           | 0.000                    |               |               |                           |                 |
| DP_OS5                |                               | JUNCTION                 | 0.00          | 4.20          | 0 00:46                   |                 |
| 0                     | 0.138                         | 0.000                    |               |               |                           |                 |
| DP_OS6                |                               | JUNCTION                 | 0.00          | 26.86         | 0 00:54                   |                 |
| 0                     | 1.14                          | 0.000                    |               |               |                           |                 |
| DP_OS7                |                               | JUNCTION                 | 0.00          | 25.47         | 0 00:55                   |                 |
| 0                     | 1.14                          | 0.000                    |               |               |                           |                 |
| DP_OS8                |                               | JUNCTION                 | 0.00          | 58.70         | 0 00:43                   |                 |
| 0                     | 1.41                          | 0.000                    |               |               |                           |                 |
| DP_OS9                |                               | JUNCTION                 | 0.00          | 136.42        | 0 01:08                   |                 |
| 0                     | 6.72                          | 0.000                    |               |               |                           |                 |
| Dr_A                  |                               | JUNCTION                 | 37.13         | 37.13         | 0 00:55                   |                 |
| 1.49                  | 1.49                          | 0.000                    |               |               |                           |                 |
| Dr_B                  |                               | JUNCTION                 | 17.72         | 17.72         | 0 00:46                   |                 |
| 0.512                 | 0.512                         | 0.000                    |               |               |                           |                 |
| J.UEC.1               |                               | JUNCTION                 | 0.00          | 225.69        | 0 01:20                   |                 |
| 0                     | 11.6                          | 0.000                    |               |               |                           |                 |
| J_LC_A10              |                               | JUNCTION                 | 0.00          | 131.30        | 0 01:10                   |                 |
| 0                     | 6.06                          | 0.000                    |               |               |                           |                 |
| J_LC_A20              |                               | JUNCTION                 | 0.00          | 11.42         | 0 00:47                   |                 |
| 0                     | 0.386                         | 0.000                    |               |               |                           |                 |
| J_OS1                 |                               | JUNCTION                 | 0.00          | 230.99        | 0 00:58                   |                 |
| 0                     | 8.6                           | 0.000                    |               |               |                           |                 |
| J_OS2                 |                               | JUNCTION                 | 0.00          | 55.02         | 0 00:54                   |                 |
| 0                     | 2.37                          | 0.000                    |               |               |                           |                 |
| J_OS4                 |                               | JUNCTION                 | 0.00          | 59.67         | 0 00:44                   |                 |
| 0                     | 1.3                           | 0.000                    |               |               |                           |                 |
| J_OS6                 |                               | JUNCTION                 | 0.00          | 26.86         | 0 00:54                   |                 |
| 0                     | 1.14                          | 0.000                    |               |               |                           |                 |
| J_OS7                 |                               | JUNCTION                 | 0.00          | 25.47         | 0 00:55                   |                 |
| 0                     | 1.14                          | 0.000                    |               |               |                           |                 |
| J_OS8                 |                               | JUNCTION                 | 0.00          | 58.69         | 0 00:43                   |                 |
| 0                     | 1.41                          | 0.000                    |               |               |                           |                 |
| J_OS9                 |                               | JUNCTION                 | 0.00          | 136.42        | 0 01:08                   |                 |
| 0                     | 6.72                          | -0.000                   |               |               |                           |                 |
| J1                    |                               | JUNCTION                 | 0.00          | 47.34         | 0 01:05                   |                 |
| 0                     | 1.64                          | 0.000                    |               |               |                           |                 |
| J2                    |                               | JUNCTION                 | 0.00          | 68.34         | 0 01:16                   |                 |
| 0                     | 2.84                          | 0.000                    |               |               |                           |                 |
| J2_OS2                |                               | JUNCTION                 | 0.00          | 49.69         | 0 01:15                   |                 |
| 0                     | 2.48                          | 0.000                    |               |               |                           |                 |

*SWMM Model Existing – 100 Year*

|            |       |          |         |         |   |       |
|------------|-------|----------|---------|---------|---|-------|
| J3         |       | JUNCTION | 0.00    | 194.11  | 0 | 01:18 |
| 0          | 8.94  | 0.000    |         |         |   |       |
| J4         |       | JUNCTION | 0.00    | 201.51  | 0 | 01:21 |
| 0          | 9.34  | 0.000    |         |         |   |       |
| LC_A10     |       | JUNCTION | 62.55   | 62.55   | 0 | 01:08 |
| 3.29       | 3.29  | 0.000    |         |         |   |       |
| LC_A20     |       | JUNCTION | 11.42   | 11.42   | 0 | 00:47 |
| 0.386      | 0.386 | 0.000    |         |         |   |       |
| LC_B       |       | JUNCTION | 698.54  | 698.54  | 0 | 01:17 |
| 32.4       | 32.4  | 0.000    |         |         |   |       |
| LC_C       |       | JUNCTION | 26.19   | 26.19   | 0 | 00:44 |
| 0.674      | 0.674 | 0.000    |         |         |   |       |
| LC_D       |       | JUNCTION | 25.11   | 25.11   | 0 | 00:48 |
| 0.828      | 0.828 | 0.000    |         |         |   |       |
| LC_E       |       | JUNCTION | 31.60   | 31.60   | 0 | 00:49 |
| 1.06       | 1.06  | 0.000    |         |         |   |       |
| LC_F       |       | JUNCTION | 111.12  | 111.12  | 0 | 00:46 |
| 2.84       | 2.84  | 0.000    |         |         |   |       |
| LC_G       |       | JUNCTION | 21.94   | 21.94   | 0 | 00:57 |
| 0.986      | 0.986 | 0.000    |         |         |   |       |
| LC_H       |       | JUNCTION | 18.92   | 18.92   | 0 | 00:43 |
| 0.491      | 0.491 | 0.000    |         |         |   |       |
| LC_I       |       | JUNCTION | 61.26   | 61.26   | 0 | 01:08 |
| 3.13       | 3.13  | 0.000    |         |         |   |       |
| OS1        |       | JUNCTION | 230.99  | 230.99  | 0 | 00:58 |
| 8.6        | 8.6   | 0.000    |         |         |   |       |
| OS2        |       | JUNCTION | 55.02   | 55.02   | 0 | 00:54 |
| 2.37       | 2.37  | 0.000    |         |         |   |       |
| OS3        |       | JUNCTION | 1831.23 | 1831.23 | 0 | 01:27 |
| 87.7       | 87.7  | 0.000    |         |         |   |       |
| OS4        |       | JUNCTION | 59.67   | 59.67   | 0 | 00:44 |
| 1.3        | 1.3   | 0.000    |         |         |   |       |
| OS5        |       | JUNCTION | 4.20    | 4.20    | 0 | 00:46 |
| 0.138      | 0.138 | 0.000    |         |         |   |       |
| OS6        |       | JUNCTION | 26.86   | 26.86   | 0 | 00:54 |
| 1.14       | 1.14  | 0.000    |         |         |   |       |
| OS7        |       | JUNCTION | 25.47   | 25.47   | 0 | 00:55 |
| 1.14       | 1.14  | 0.000    |         |         |   |       |
| OS8        |       | JUNCTION | 58.70   | 58.70   | 0 | 00:43 |
| 1.41       | 1.41  | 0.000    |         |         |   |       |
| OS9        |       | JUNCTION | 136.42  | 136.42  | 0 | 01:08 |
| 6.72       | 6.72  | 0.000    |         |         |   |       |
| Out_Dr_A   |       | JUNCTION | 0.00    | 37.13   | 0 | 00:55 |
| 0          | 1.49  | 0.000    |         |         |   |       |
| Out_Dr_B   |       | JUNCTION | 0.00    | 17.72   | 0 | 00:46 |
| 0          | 0.512 | 0.000    |         |         |   |       |
| Out_LC_A10 |       | JUNCTION | 0.00    | 131.30  | 0 | 01:09 |
| 0          | 6.06  | 0.000    |         |         |   |       |
| Out_LC_A20 |       | JUNCTION | 0.00    | 11.42   | 0 | 00:47 |
| 0          | 0.386 | 0.000    |         |         |   |       |
| Out_LC_B   |       | JUNCTION | 0.00    | 2731.71 | 0 | 01:38 |
| 0          | 142   | 0.000    |         |         |   |       |
| Out_LC_C   |       | JUNCTION | 0.00    | 26.19   | 0 | 00:44 |
| 0          | 0.674 | 0.000    |         |         |   |       |

*SWMM Model Existing – 100 Year*

|            |       |          |       |         |   |       |
|------------|-------|----------|-------|---------|---|-------|
| Out_LC_D   |       | JUNCTION | 0.00  | 25.11   | 0 | 00:48 |
| 0          | 0.828 | 0.000    |       |         |   |       |
| Out_LC_E   |       | JUNCTION | 0.00  | 31.60   | 0 | 00:49 |
| 0          | 1.06  | 0.000    |       |         |   |       |
| Out_LC_F   |       | JUNCTION | 0.00  | 111.12  | 0 | 00:46 |
| 0          | 2.84  | 0.000    |       |         |   |       |
| Out_LC_G   |       | JUNCTION | 0.00  | 21.94   | 0 | 00:57 |
| 0          | 0.986 | 0.000    |       |         |   |       |
| Out_LC_H   |       | JUNCTION | 0.00  | 18.92   | 0 | 00:43 |
| 0          | 0.491 | 0.000    |       |         |   |       |
| Out_UEC_A  |       | JUNCTION | 0.00  | 174.55  | 0 | 01:20 |
| 0          | 9.22  | 0.000    |       |         |   |       |
| Out_UEC_B  |       | JUNCTION | 0.00  | 87.55   | 0 | 00:49 |
| 0          | 2.32  | 0.000    |       |         |   |       |
| Out_UEC_C  |       | JUNCTION | 0.00  | 12.30   | 0 | 00:51 |
| 0          | 0.469 | 0.000    |       |         |   |       |
| Out_UEC_D  |       | JUNCTION | 0.00  | 15.19   | 0 | 00:48 |
| 0          | 0.505 | 0.000    |       |         |   |       |
| UEC_A      |       | JUNCTION | 49.42 | 49.42   | 0 | 01:02 |
| 2.33       | 2.33  | 0.000    |       |         |   |       |
| UEC_B      |       | JUNCTION | 87.55 | 87.55   | 0 | 00:49 |
| 2.32       | 2.32  | 0.000    |       |         |   |       |
| UEC_C      |       | JUNCTION | 12.30 | 12.30   | 0 | 00:51 |
| 0.469      | 0.469 | 0.000    |       |         |   |       |
| UEC_D      |       | JUNCTION | 15.19 | 15.19   | 0 | 00:48 |
| 0.505      | 0.505 | 0.000    |       |         |   |       |
| Out.Dr     |       | OUTFALL  | 0.00  | 53.62   | 0 | 00:54 |
| 0          | 2.01  | 0.000    |       |         |   |       |
| Out_C.D.E  |       | OUTFALL  | 0.00  | 79.93   | 0 | 00:53 |
| 0          | 2.59  | 0.000    |       |         |   |       |
| Out_LC.B.F |       | OUTFALL  | 0.00  | 2767.50 | 0 | 01:40 |
| 0          | 145   | 0.000    |       |         |   |       |
| Out_LC.G.H |       | OUTFALL  | 0.00  | 39.53   | 0 | 00:53 |
| 0          | 1.48  | 0.000    |       |         |   |       |
| Out_LC_I   |       | OUTFALL  | 0.00  | 61.26   | 0 | 01:08 |
| 0          | 3.13  | 0.000    |       |         |   |       |
| UEC_Out    |       | OUTFALL  | 0.00  | 248.30  | 0 | 01:21 |
| 0          | 12.6  | 0.000    |       |         |   |       |

\*\*\*\*\*  
Node Flooding Summary  
\*\*\*\*\*

No nodes were flooded.

\*\*\*\*\*  
Outfall Loading Summary  
\*\*\*\*\*

-----  
Flow            Avg            Max            Total  
Freq            Flow            Flow            Volume

*SWMM Model Existing – 100 Year*

| Outfall Node | Pcnt  | CFS    | CFS     | 10 <sup>6</sup> gal |
|--------------|-------|--------|---------|---------------------|
| Out.Dr       | 22.61 | 13.73  | 53.62   | 2.006               |
| Out_C.D.E    | 56.24 | 7.13   | 79.93   | 2.593               |
| Out_LC.B.F   | 97.93 | 229.30 | 2767.50 | 145.128             |
| Out_LC.G.H   | 29.64 | 7.75   | 39.53   | 1.484               |
| Out_LC_I     | 24.80 | 19.54  | 61.26   | 3.132               |
| UEC_Out      | 97.78 | 20.01  | 248.30  | 12.642              |
| System       | 54.83 | 297.46 | 3124.43 | 166.987             |

\*\*\*\*\*  
 Link Flow Summary  
 \*\*\*\*\*

| Max/<br>Full<br>Link<br>Depth | Type    | Maximum<br> Flow <br>CFS | Time of Max<br>Occurrence<br>days hr:min | Maximum<br> Veloc <br>ft/sec | Max/<br>Full<br>Flow |
|-------------------------------|---------|--------------------------|------------------------------------------|------------------------------|----------------------|
| Ch.Dr_A<br>0.25               | CONDUIT | 37.06                    | 0 00:58                                  | 4.76                         | 0.03                 |
| Ch.UEC_B<br>0.10              | CONDUIT | 86.74                    | 0 00:53                                  | 3.55                         | 0.02                 |
| CH_1<br>0.07                  | CONDUIT | 44.49                    | 0 01:20                                  | 2.56                         | 0.01                 |
| Ch_2<br>0.09                  | CONDUIT | 67.44                    | 0 01:24                                  | 2.80                         | 0.02                 |
| Ch_3<br>0.19                  | CONDUIT | 193.81                   | 0 01:21                                  | 3.73                         | 0.05                 |
| Ch_4<br>0.19                  | CONDUIT | 201.20                   | 0 01:24                                  | 3.78                         | 0.05                 |
| Ch_5<br>0.32                  | CONDUIT | 46.42                    | 0 01:36                                  | 3.75                         | 0.05                 |
| Ch_LC_A10<br>0.06             | CONDUIT | 131.22                   | 0 01:12                                  | 5.27                         | 0.01                 |
| Ch_Main<br>0.89               | CONDUIT | 1961.00                  | 0 01:42                                  | 8.56                         | 0.74                 |
| Ch_OS6<br>0.12                | CONDUIT | 26.09                    | 0 01:05                                  | 3.83                         | 0.00                 |
| Ch_OS7<br>0.17                | CONDUIT | 25.40                    | 0 00:59                                  | 4.07                         | 0.04                 |
| Ch_UEC<br>0.26                | CONDUIT | 225.54                   | 0 01:22                                  | 3.11                         | 0.10                 |
| Culv_LC_A10<br>0.17           | CONDUIT | 131.30                   | 0 01:10                                  | 16.12                        | 0.11                 |
| Culv_LC_A20<br>0.14           | CONDUIT | 11.42                    | 0 00:47                                  | 8.99                         | 0.08                 |

*SWMM Model Existing – 100 Year*

|      |              |         |         |   |       |       |      |
|------|--------------|---------|---------|---|-------|-------|------|
| 0.69 | Culv_OS1     | CONDUIT | 230.99  | 0 | 00:58 | 14.76 | 0.82 |
| 0.56 | Culv_OS2     | CONDUIT | 55.02   | 0 | 00:54 | 9.73  | 0.60 |
| 0.75 | Culv_OS4     | CONDUIT | 59.67   | 0 | 00:44 | 3.87  | 0.91 |
| 0.23 | Culv_OS6     | CONDUIT | 26.86   | 0 | 00:54 | 10.90 | 0.12 |
| 0.42 | Culv_OS7     | CONDUIT | 25.47   | 0 | 00:55 | 6.84  | 0.36 |
| 0.71 | Culv_OS8     | CONDUIT | 58.69   | 0 | 00:43 | 5.24  | 0.85 |
| 0.73 | Culv_OS9     | CONDUIT | 136.42  | 0 | 01:08 | 8.23  | 0.88 |
|      | Dummy_Dr_A   | DUMMY   | 37.13   | 0 | 00:55 |       |      |
|      | Dummy_Dr_B   | DUMMY   | 17.72   | 0 | 00:46 |       |      |
|      | Dummy_LC_A10 | DUMMY   | 62.55   | 0 | 01:08 |       |      |
|      | dummy_LC_A20 | DUMMY   | 11.42   | 0 | 00:47 |       |      |
|      | Dummy_LC_B   | DUMMY   | 698.54  | 0 | 01:17 |       |      |
|      | Dummy_LC_C   | DUMMY   | 26.19   | 0 | 00:44 |       |      |
|      | Dummy_LC_D   | DUMMY   | 25.11   | 0 | 00:48 |       |      |
|      | Dummy_LC_E   | DUMMY   | 31.60   | 0 | 00:49 |       |      |
|      | Dummy_LC_F   | DUMMY   | 111.12  | 0 | 00:46 |       |      |
|      | Dummy_LC_G   | DUMMY   | 21.94   | 0 | 00:57 |       |      |
|      | Dummy_LC_H   | DUMMY   | 18.92   | 0 | 00:43 |       |      |
|      | Dummy_LC_I   | DUMMY   | 61.26   | 0 | 01:08 |       |      |
|      | Dummy_OS1    | DUMMY   | 230.99  | 0 | 00:58 |       |      |
|      | Dummy_OS2    | DUMMY   | 55.02   | 0 | 00:54 |       |      |
|      | Dummy_OS3    | DUMMY   | 1831.23 | 0 | 01:27 |       |      |
|      | Dummy_OS4    | DUMMY   | 59.67   | 0 | 00:44 |       |      |
|      | Dummy_OS5    | DUMMY   | 4.20    | 0 | 00:46 |       |      |
|      | Dummy_OS6    | DUMMY   | 26.86   | 0 | 00:54 |       |      |
|      | Dummy_OS7    | DUMMY   | 25.47   | 0 | 00:55 |       |      |
|      | Dummy_Os8    | DUMMY   | 58.70   | 0 | 00:43 |       |      |
|      | Dummy_OS9    | DUMMY   | 136.42  | 0 | 01:08 |       |      |
|      | Dummy_UEC_A  | DUMMY   | 49.42   | 0 | 01:02 |       |      |
|      | Dummy_UEC_B  | DUMMY   | 87.55   | 0 | 00:49 |       |      |
|      | Dummy_UEC_C  | DUMMY   | 12.30   | 0 | 00:51 |       |      |
|      | Dummy_UEC_D  | DUMMY   | 15.19   | 0 | 00:48 |       |      |
| 0.05 | Over.Dr_B    | CONDUIT | 17.69   | 0 | 00:48 | 1.78  | 0.01 |
| 0.82 | Over.LC_B    | CONDUIT | 2730.59 | 0 | 01:40 | 4.91  | 0.73 |
| 0.09 | Over.LC_C    | CONDUIT | 24.24   | 0 | 00:56 | 1.35  | 0.02 |
| 0.17 | Over.LC_D    | CONDUIT | 25.10   | 0 | 00:49 | 0.74  | 0.05 |
| 0.24 | Over.LC_E    | CONDUIT | 31.58   | 0 | 00:50 | 0.65  | 0.10 |
| 0.22 | Over.LC_F    | CONDUIT | 110.84  | 0 | 00:48 | 2.54  | 0.08 |
| 0.07 | Over.LC_G    | CONDUIT | 21.92   | 0 | 00:59 | 1.64  | 0.01 |

SWMM Model Existing – 100 Year

|                     |         |        |   |       |      |      |
|---------------------|---------|--------|---|-------|------|------|
| Over.LC_H<br>0.06   | CONDUIT | 18.83  | 0 | 00:46 | 1.52 | 0.01 |
| Over.UEC_A<br>0.23  | CONDUIT | 173.94 | 0 | 01:24 | 3.73 | 0.09 |
| Over.UEC_C<br>0.04  | CONDUIT | 11.27  | 0 | 01:06 | 1.41 | 0.01 |
| Over.UEC_D<br>0.04  | CONDUIT | 14.16  | 0 | 01:09 | 1.64 | 0.01 |
| Over_LC_A20<br>0.64 | CONDUIT | 11.35  | 0 | 00:51 | 2.25 | 0.30 |
| Over_OS1<br>0.19    | CONDUIT | 186.17 | 0 | 01:27 | 2.58 | 0.07 |
| Over_OS2<br>0.03    | CONDUIT | 49.69  | 0 | 01:15 | 1.78 | 0.00 |
| Over_OS4<br>0.04    | CONDUIT | 45.43  | 0 | 01:04 | 2.19 | 0.01 |
| Over_OS5<br>0.01    | CONDUIT | 2.80   | 0 | 01:30 | 0.93 | 0.00 |
| Over_OS8<br>0.08    | CONDUIT | 44.58  | 0 | 01:13 | 1.60 | 0.01 |
| Over_OS9<br>0.15    | CONDUIT | 131.62 | 0 | 01:22 | 2.27 | 0.04 |

\*\*\*\*\*  
Conduit Surcharge Summary  
\*\*\*\*\*

No conduits were surcharged.

Analysis begun on: Mon Dec 16 16:50:51 2024  
Analysis ended on: Mon Dec 16 16:50:51 2024  
Total elapsed time: < 1 sec



## SWMM Model Proposed – 5 Year

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.4)

---

WARNING 02: maximum depth increased for Node J.B\_Main.2

\*\*\*\*\*

Element Count

\*\*\*\*\*

Number of rain gages ..... 0  
 Number of subcatchments ... 0  
 Number of nodes ..... 136  
 Number of links ..... 130  
 Number of pollutants ..... 0  
 Number of land uses ..... 0

\*\*\*\*\*

Node Summary

\*\*\*\*\*

| External |      | Invert | Max.  | Ponded |
|----------|------|--------|-------|--------|
| Name     | Type | Elev.  | Depth | Area   |

---

|            |          |         |      |     |
|------------|----------|---------|------|-----|
| DP_LC_I    | JUNCTION | 6254.57 | 6.00 | 0.0 |
| DP_LC_A20  | JUNCTION | 6370.00 | 6.00 | 0.0 |
| DP_LC_A30  | JUNCTION | 6377.95 | 6.00 | 0.0 |
| DP_LC_B110 | JUNCTION | 6284.29 | 3.00 | 0.0 |
| DP_LC_B120 | JUNCTION | 6286.76 | 6.00 | 0.0 |
| DP_LC_B130 | JUNCTION | 6336.08 | 3.00 | 0.0 |
| DP_LC_B140 | JUNCTION | 6376.76 | 2.00 | 0.0 |
| DP_LC_B150 | JUNCTION | 6338.57 | 2.00 | 0.0 |
| DP_LC_B160 | JUNCTION | 6318.55 | 2.00 | 0.0 |
| DP_LC_B170 | JUNCTION | 6403.16 | 2.00 | 0.0 |
| DP_LC_B180 | JUNCTION | 6350.67 | 2.00 | 0.0 |
| DP_LC_B190 | JUNCTION | 6339.17 | 2.00 | 0.0 |
| DP_LC_B20  | JUNCTION | 6221.82 | 5.00 | 0.0 |
| DP_LC_B30  | JUNCTION | 6241.12 | 5.00 | 0.0 |
| DP_LC_B40  | JUNCTION | 6268.03 | 5.00 | 0.0 |
| DP_LC_B50  | JUNCTION | 6271.98 | 5.00 | 0.0 |
| DP_LC_B70  | JUNCTION | 6249.24 | 4.00 | 0.0 |
| DP_LC_B80  | JUNCTION | 6249.80 | 3.00 | 0.0 |
| DP_LC_B90  | JUNCTION | 6270.44 | 2.00 | 0.0 |
| DP_LC_C.D  | JUNCTION | 6244.97 | 2.00 | 0.0 |
| DP_LC_F20  | JUNCTION | 6229.95 | 3.00 | 0.0 |
| DP_LC_I20  | JUNCTION | 6276.74 | 2.00 | 0.0 |
| DP_OS_B1   | JUNCTION | 6293.06 | 2.00 | 0.0 |
| DP_OS_B2   | JUNCTION | 6289.70 | 2.00 | 0.0 |
| DP_OS1     | JUNCTION | 6282.45 | 3.00 | 0.0 |
| DP_OS10    | JUNCTION | 6373.07 | 3.00 | 0.0 |
| DP_OS2     | JUNCTION | 6313.76 | 2.50 | 0.0 |
| DP_OS3     | JUNCTION | 6290.51 | 5.00 | 0.0 |

*SWMM Model Proposed – 5 Year*

|                   |          |         |       |     |
|-------------------|----------|---------|-------|-----|
| DP_OS4            | JUNCTION | 6420.09 | 3.50  | 0.0 |
| DP_OS5            | JUNCTION | 6440.72 | 5.00  | 0.0 |
| DP_OS6            | JUNCTION | 6428.06 | 3.00  | 0.0 |
| DP_OS7            | JUNCTION | 6392.28 | 2.00  | 0.0 |
| DP_OS8            | JUNCTION | 6393.20 | 2.50  | 0.0 |
| DP_OS9            | JUNCTION | 6359.19 | 3.00  | 0.0 |
| DP_UEC_A20        | JUNCTION | 6377.69 | 2.00  | 0.0 |
| DP_UEC_B10        | JUNCTION | 6307.98 | 2.00  | 0.0 |
| DP_UEC_B20        | JUNCTION | 6314.12 | 2.00  | 0.0 |
| DP_UEC_B30        | JUNCTION | 6367.93 | 3.00  | 0.0 |
| DP_UEC_B40        | JUNCTION | 6362.77 | 3.00  | 0.0 |
| Dr_A10            | JUNCTION | 6347.11 | 0.00  | 0.0 |
| Dr_B10            | JUNCTION | 6329.34 | 0.00  | 0.0 |
| J.B_Main.1        | JUNCTION | 6219.15 | 5.50  | 0.0 |
| J.B_Main.2        | JUNCTION | 6238.37 | 6.00  | 0.0 |
| J.B_Main.3        | JUNCTION | 6258.52 | 6.00  | 0.0 |
| J.B_Main.4        | JUNCTION | 6274.10 | 6.00  | 0.0 |
| J.B_Main.5        | JUNCTION | 6287.43 | 6.00  | 0.0 |
| J.B_Side.120      | JUNCTION | 6287.54 | 22.07 | 0.0 |
| J.B_Upper.Main_.2 | JUNCTION | 6250.19 | 5.00  | 0.0 |
| J.B_Upper.Main_1  | JUNCTION | 6246.00 | 5.00  | 0.0 |
| J.UEC_B.1         | JUNCTION | 6361.65 | 5.00  | 0.0 |
| J_LC.G.H          | JUNCTION | 6212.79 | 2.00  | 0.0 |
| J_LC_A10          | JUNCTION | 6346.58 | 10.00 | 0.0 |
| J_LC_A25          | JUNCTION | 6320.63 | 3.00  | 0.0 |
| J_OS1             | JUNCTION | 6277.94 | 5.00  | 0.0 |
| J_OS2             | JUNCTION | 6310.41 | 3.00  | 0.0 |
| J_OS4             | JUNCTION | 6420.00 | 5.00  | 0.0 |
| J_OS6             | JUNCTION | 6425.61 | 5.00  | 0.0 |
| J_OS7             | JUNCTION | 6388.69 | 3.00  | 0.0 |
| J_OS8             | JUNCTION | 6391.98 | 2.50  | 0.0 |
| J_OS9             | JUNCTION | 6357.73 | 3.00  | 0.0 |
| J1                | JUNCTION | 6355.74 | 5.00  | 0.0 |
| J2                | JUNCTION | 6323.35 | 5.00  | 0.0 |
| J3                | JUNCTION | 6305.72 | 10.00 | 0.0 |
| J4                | JUNCTION | 6298.21 | 5.00  | 0.0 |
| LC_A10            | JUNCTION | 6373.50 | 0.00  | 0.0 |
| LC_A20            | JUNCTION | 6394.79 | 0.00  | 0.0 |
| LC_A25            | JUNCTION | 6358.75 | 0.00  | 0.0 |
| LC_A30            | JUNCTION | 6377.99 | 0.00  | 0.0 |
| LC_B10            | JUNCTION | 6227.60 | 0.00  | 0.0 |
| LC_B100           | JUNCTION | 6278.59 | 0.00  | 0.0 |
| LC_B110           | JUNCTION | 6305.11 | 0.00  | 0.0 |
| LC_B120           | JUNCTION | 6328.08 | 0.00  | 0.0 |
| LC_B130           | JUNCTION | 6376.10 | 0.00  | 0.0 |
| LC_B140           | JUNCTION | 6390.52 | 0.00  | 0.0 |
| LC_B150           | JUNCTION | 6364.46 | 0.00  | 0.0 |
| LC_B160           | JUNCTION | 6354.39 | 0.00  | 0.0 |
| LC_B170           | JUNCTION | 6416.30 | 0.00  | 0.0 |
| LC_B180           | JUNCTION | 6366.21 | 0.00  | 0.0 |
| LC_B190           | JUNCTION | 6345.00 | 0.00  | 0.0 |
| LC_B20            | JUNCTION | 6256.91 | 0.00  | 0.0 |
| LC_B30            | JUNCTION | 6277.65 | 0.00  | 0.0 |
| LC_B40            | JUNCTION | 6309.88 | 0.00  | 0.0 |

*SWMM Model Proposed – 5 Year*

|             |          |         |       |     |
|-------------|----------|---------|-------|-----|
| LC_B50      | JUNCTION | 6278.66 | 0.00  | 0.0 |
| LC_B60      | JUNCTION | 6259.78 | 0.00  | 0.0 |
| LC_B70      | JUNCTION | 6284.81 | 0.00  | 0.0 |
| LC_B80      | JUNCTION | 6318.25 | 0.00  | 0.0 |
| LC_B90      | JUNCTION | 6343.74 | 0.00  | 0.0 |
| LC_C10      | JUNCTION | 6267.21 | 0.00  | 0.0 |
| LC_D10      | JUNCTION | 6248.16 | 0.00  | 0.0 |
| LC_F10      | JUNCTION | 6246.12 | 0.00  | 0.0 |
| LC_F20      | JUNCTION | 6250.36 | 0.00  | 0.0 |
| LC_G10      | JUNCTION | 6234.42 | 0.00  | 0.0 |
| LC_H10      | JUNCTION | 6237.87 | 0.00  | 0.0 |
| LC_I10      | JUNCTION | 6269.94 | 12.56 | 0.0 |
| LC_I20      | JUNCTION | 6313.14 | 0.00  | 0.0 |
| OS_B1       | JUNCTION | 6309.16 | 0.00  | 0.0 |
| OS_B2       | JUNCTION | 6309.56 | 0.00  | 0.0 |
| OS1         | JUNCTION | 6349.15 | 0.00  | 0.0 |
| OS10        | JUNCTION | 6392.72 | 0.00  | 0.0 |
| OS10_In     | JUNCTION | 6372.34 | 3.00  | 0.0 |
| OS2         | JUNCTION | 6342.30 | 0.00  | 0.0 |
| OS3         | JUNCTION | 6453.31 | 0.00  | 0.0 |
| OS4         | JUNCTION | 6462.88 | 0.00  | 0.0 |
| OS5         | JUNCTION | 6448.20 | 0.00  | 0.0 |
| OS6         | JUNCTION | 6428.17 | 0.00  | 0.0 |
| OS7         | JUNCTION | 6416.17 | 0.00  | 0.0 |
| OS8         | JUNCTION | 6415.01 | 0.00  | 0.0 |
| OS9         | JUNCTION | 6429.66 | 0.00  | 0.0 |
| Out_Dr_A10  | JUNCTION | 6327.48 | 2.00  | 0.0 |
| Out_Dr_B10  | JUNCTION | 6315.89 | 2.00  | 0.0 |
| Out_LC_A10  | JUNCTION | 6349.20 | 8.00  | 0.0 |
| Out_LC_A25  | JUNCTION | 6322.30 | 3.00  | 0.0 |
| Out_LC_B    | JUNCTION | 6214.77 | 5.00  | 0.0 |
| Out_LC_C    | JUNCTION | 6249.92 | 5.30  | 0.0 |
| Out_LC_E    | JUNCTION | 6245.81 | 2.00  | 0.0 |
| Out_LC_F    | JUNCTION | 6208.99 | 2.00  | 0.0 |
| Out_LC_G10  | JUNCTION | 6212.98 | 2.00  | 0.0 |
| Out_LC_H10  | JUNCTION | 6213.78 | 2.00  | 0.0 |
| Out_UEC_A   | JUNCTION | 6318.87 | 2.00  | 0.0 |
| Out_UEC_B   | JUNCTION | 6302.81 | 5.00  | 0.0 |
| Out_UEC_C10 | JUNCTION | 6327.09 | 2.00  | 0.0 |
| Out_UEC_D10 | JUNCTION | 6344.99 | 2.00  | 0.0 |
| UEC_A10     | JUNCTION | 6349.56 | 0.00  | 0.0 |
| UEC_A20     | JUNCTION | 6402.62 | 0.00  | 0.0 |
| UEC_B10     | JUNCTION | 6351.73 | 3.12  | 0.0 |
| UEC_B20     | JUNCTION | 6362.49 | 0.00  | 0.0 |
| UEC_B30     | JUNCTION | 6398.18 | 0.00  | 0.0 |
| UEC_B40     | JUNCTION | 6375.31 | 0.00  | 0.0 |
| UEC_C10     | JUNCTION | 6357.45 | 0.00  | 0.0 |
| UEC_D10     | JUNCTION | 6349.03 | 0.00  | 0.0 |
| Out.Dr      | OUTFALL  | 6303.54 | 2.00  | 0.0 |
| Out_C.D     | OUTFALL  | 6244.40 | 2.00  | 0.0 |
| Out_LC.B.F  | OUTFALL  | 6201.46 | 2.00  | 0.0 |
| Out_LC.G.H  | OUTFALL  | 6202.14 | 2.00  | 0.0 |
| Out_LC_I    | OUTFALL  | 6254.31 | 6.00  | 0.0 |
| UEC_Out     | OUTFALL  | 6278.95 | 5.00  | 0.0 |

SWMM Model Proposed – 5 Year

\*\*\*\*\*  
 Link Summary  
 \*\*\*\*\*

| Name             | From Node    | To Node      | Type    |
|------------------|--------------|--------------|---------|
| Length           | %Slope       | Roughness    |         |
| Ch.Dr_A.Main10   | Out_Dr_A10   | Out_Dr_B10   | CONDUIT |
| 927.5            | 1.2497       | 0.0320       |         |
| Ch.LC_A.Main10   | DP_LC_A20    | Out_LC_A10   | CONDUIT |
| 987.0            | 2.1077       | 0.0320       |         |
| Ch.LC_A.Side10   | J_OS7        | OS10_In      | CONDUIT |
| 1200.9           | 1.3615       | 0.0350       |         |
| Ch.LC_A.Side11   | OS10_In      | Out_LC_A10   | CONDUIT |
| 231.0            | 10.0662      | 0.0350       |         |
| Ch.LC_B.30       | DP_LC_B30    | DP_LC_F20    | CONDUIT |
| 1089.3           | 1.0255       | 0.0320       |         |
| Ch.LC_B.Side.120 | DP_LC_B150   | J.B_Side.120 | CONDUIT |
| 1404.9           | 3.6348       | 0.0320       |         |
| Ch.LC_B.Side.121 | J.B_Side.120 | DP_LC_B120   | CONDUIT |
| 1109.0           | 0.0710       | 0.0320       |         |
| Ch.LC_B.Side.140 | DP_LC_B170   | DP_LC_B140   | CONDUIT |
| 1649.8           | 1.6009       | 0.0320       |         |
| Ch.Lc_B.Side.150 | DP_LC_B140   | DP_LC_B150   | CONDUIT |
| 947.2            | 4.0342       | 0.0320       |         |
| Ch.LC_B.Side.160 | DP_LC_B180   | DP_LC_B160   | CONDUIT |
| 1415.2           | 2.2698       | 0.0320       |         |
| Ch.LC_B.Side.90  | DP_LC_B190   | DP_LC_B90    | CONDUIT |
| 2996.6           | 2.2943       | 0.0320       |         |
| Ch.LC_B.Side.91  | DP_LC_B90    | J.B_Main.3   | CONDUIT |
| 274.4            | 4.3486       | 0.0320       |         |
| Ch.LC_B.Side122  | DP_LC_B160   | DP_LC_B120   | CONDUIT |
| 1382.5           | 2.3006       | 0.0320       |         |
| Ch.LC_B.Side130  | DP_LC_B130   | J.B_Side.120 | CONDUIT |
| 1544.9           | 3.1432       | 0.0320       |         |
| Ch.LC_B.Side20   | DP_LC_B50    | DP_LC_B20    | CONDUIT |
| 3203.8           | 1.5660       | 0.0320       |         |
| Ch.LC_B.Side50   | J_OS1        | DP_LC_B50    | CONDUIT |
| 1722.7           | 0.3457       | 0.0320       |         |
| Ch.LC_B_Side10   | DP_LC_B20    | Out_LC_B     | CONDUIT |
| 1017.1           | 0.6925       | 0.0320       |         |
| Ch.LC_D.Main10   | Out_LC_C     | DP_LC_C.D    | CONDUIT |
| 502.8            | 0.9843       | 0.0320       |         |
| Ch.LC_D.Main11   | Out_LC_E     | DP_LC_C.D    | CONDUIT |
| 57.0             | 1.4747       | 0.0320       |         |
| Ch.LC_G.Main10   | Out_LC_G10   | J_LC.G.H     | CONDUIT |
| 53.8             | 0.3477       | 0.0320       |         |
| Ch.LC_H.Main10   | Out_LC_H10   | J_LC.G.H     | CONDUIT |
| 144.6            | 0.6821       | 0.0320       |         |
| Ch.LC_I.Main1    | DP_LC_I20    | DP.LC_I      | CONDUIT |
| 1436.5           | 1.5439       | 0.0350       |         |

*SWMM Model Proposed – 5 Year*

|                 |                   |                   |         |
|-----------------|-------------------|-------------------|---------|
| Ch.OS_B1        | DP_OS_B1          | J.B_Main.5        | CONDUIT |
| 278.4 2.0240    | 0.0320            |                   |         |
| Ch.OS_B2        | DP_OS_B2          | J.B_Upper.Main_.2 | CONDUIT |
| 1186.2 3.3324   | 0.0320            |                   |         |
| Ch.OS2          | J_OS2             | J.B_Upper.Main_.2 | CONDUIT |
| 2743.3 2.1958   | 0.0320            |                   |         |
| Ch.UEC_A.Main10 | J_OS9             | Out_UEC_A         | CONDUIT |
| 2802.5 1.3865   | 0.0350            |                   |         |
| Ch.UEC_A.Main11 | Out_UEC_A         | DP_UEC_B10        | CONDUIT |
| 503.3 2.1648    | 0.0320            |                   |         |
| Ch.UEC_A.Main20 | DP_UEC_A20        | J_OS9             | CONDUIT |
| 669.7 2.9830    | 0.0320            |                   |         |
| Ch.UEC_B        | Out_UEC_B         | UEC_Out           | CONDUIT |
| 2023.0 1.1797   | 0.0320            |                   |         |
| Ch.UEC_B.Main10 | J.UEC_B.1         | Out_UEC_B         | CONDUIT |
| 1999.1 2.9446   | 0.0320            |                   |         |
| Ch.UEC_B.Side10 | DP_UEC_B10        | Out_UEC_B         | CONDUIT |
| 106.0 4.8828    | 0.0320            |                   |         |
| Ch.UEC_B.Side20 | DP_UEC_B20        | Out_UEC_B         | CONDUIT |
| 185.5 6.1092    | 0.0320            |                   |         |
| Ch.UEC_C.Main10 | Out_UEC_C10       | DP_UEC_B20        | CONDUIT |
| 776.8 1.6701    | 0.0320            |                   |         |
| Ch.UEC_D.Main10 | Out_UEC_D10       | Out_UEC_C10       | CONDUIT |
| 996.7 1.7957    | 0.0320            |                   |         |
| Ch_1            | J1                | J2                | CONDUIT |
| 2593.7 1.2488   | 0.0320            |                   |         |
| Ch_2            | J2                | J3                | CONDUIT |
| 1678.2 1.0507   | 0.0320            |                   |         |
| Ch_3            | J3                | J4                | CONDUIT |
| 973.6 0.7710    | 0.0320            |                   |         |
| Ch_4            | J4                | DP_OS3            | CONDUIT |
| 998.0 0.7716    | 0.0320            |                   |         |
| Ch_LC_A10       | J_LC_A10          | J3                | CONDUIT |
| 1414.2 2.8909   | 0.0320            |                   |         |
| Ch_Main_1       | J.B_Main.1        | Out_LC_B          | CONDUIT |
| 338.2 1.2946    | 0.0320            |                   |         |
| Ch_Main_2       | J.B_Main.2        | J.B_Main.1        | CONDUIT |
| 3347.0 0.5741   | 0.0320            |                   |         |
| Ch_Main_3       | J.B_Main.3        | J.B_Main.2        | CONDUIT |
| 1567.9 1.2853   | 0.0320            |                   |         |
| Ch_Main_4       | J.B_Main.4        | J.B_Main.3        | CONDUIT |
| 1664.6 0.9360   | 0.0320            |                   |         |
| Ch_Main_5       | J.B_Main.5        | J.B_Main.4        | CONDUIT |
| 1845.4 0.7223   | 0.0320            |                   |         |
| Ch_Main_6       | DP_OS3            | J.B_Main.5        | CONDUIT |
| 608.4 0.5064    | 0.0320            |                   |         |
| Ch_OS10         | DP_OS10           | OS10_In           | CONDUIT |
| 19.2 3.7992     | 0.0350            |                   |         |
| Ch_OS6          | J_OS6             | J2                | CONDUIT |
| 2634.9 3.8840   | 0.0350            |                   |         |
| Ch_Upper.Main_1 | J.B_Upper.Main_1  | Out_LC_B          | CONDUIT |
| 3730.9 0.8371   | 0.0320            |                   |         |
| Ch_Upper.Main_2 | J.B_Upper.Main_.2 | J.B_Upper.Main_1  | CONDUIT |
| 1106.1 0.3784   | 0.0320            |                   |         |

*SWMM Model Proposed – 5 Year*

|               |            |            |         |
|---------------|------------|------------|---------|
| Culv_LC_A10   | Out_LC_A10 | J_LC_A10   | CONDUIT |
| 120.5 2.1763  | 0.0130     |            |         |
| Culv_LC_A20   | Out_LC_A25 | J_LC_A25   | CONDUIT |
| 61.7 2.7100   | 0.0130     |            |         |
| Culv_OS1      | DP_OS1     | J_OS1      | CONDUIT |
| 67.5 6.6934   | 0.0240     |            |         |
| Culv_OS2      | DP_OS2     | J_OS2      | CONDUIT |
| 79.1 4.2307   | 0.0240     |            |         |
| Culv_OS4      | DP_OS4     | J_OS4      | CONDUIT |
| 87.0 0.1068   | 0.0130     |            |         |
| Culv_OS6      | DP_OS6     | J_OS6      | CONDUIT |
| 82.4 2.9775   | 0.0130     |            |         |
| Culv_OS7      | DP_OS7     | J_OS7      | CONDUIT |
| 99.0 3.6291   | 0.0240     |            |         |
| Culv_OS8      | DP_OS8     | J_OS8      | CONDUIT |
| 114.8 1.0631  | 0.0240     |            |         |
| Culv_OS9      | DP_OS9     | J_OS9      | CONDUIT |
| 93.8 1.5617   | 0.0210     |            |         |
| Dummy_Dr_A10  | Dr_A10     | Out_Dr_A10 | CONDUIT |
| 1154.7 1.7000 | 0.0100     |            |         |
| Dummy_Dr_B10  | Dr_B10     | Out_Dr_B10 | CONDUIT |
| 641.3 2.0983  | 0.0100     |            |         |
| Dummy_LC_A10  | LC_A10     | Out_LC_A10 | CONDUIT |
| 577.6 4.2097  | 0.0100     |            |         |
| Dummy_LC_A20  | LC_A20     | DP_LC_A20  | CONDUIT |
| 621.2 3.9942  | 0.0100     |            |         |
| Dummy_LC_A25  | LC_A25     | Out_LC_A25 | CONDUIT |
| 613.0 5.9554  | 0.0100     |            |         |
| Dummy_LC_A30  | LC_A30     | DP_LC_A30  | CONDUIT |
| 340.9 0.0135  | 0.0100     |            |         |
| Dummy_LC_B10  | LC_B10     | Out_LC_B   | CONDUIT |
| 1888.7 0.6793 | 0.0100     |            |         |
| Dummy_LC_B100 | LC_B100    | J.B_Main.4 | CONDUIT |
| 637.0 0.7044  | 0.0100     |            |         |
| Dummy_LC_B110 | LC_B110    | DP_LC_B110 | CONDUIT |
| 685.6 3.0385  | 0.0100     |            |         |
| Dummy_LC_B120 | LC_B120    | DP_LC_B120 | CONDUIT |
| 1132.3 3.6524 | 0.0100     |            |         |
| Dummy_LC_B130 | LC_B130    | DP_LC_B130 | CONDUIT |
| 1211.0 3.3062 | 0.0100     |            |         |
| Dummy_LC_B140 | LC_B140    | DP_LC_B140 | CONDUIT |
| 685.1 2.0096  | 0.0100     |            |         |
| Dummy_LC_B150 | LC_B150    | DP_LC_B150 | CONDUIT |
| 770.6 3.3608  | 0.0100     |            |         |
| Dummy_LC_B160 | LC_B160    | DP_LC_B160 | CONDUIT |
| 826.2 4.3415  | 0.0100     |            |         |
| Dummy_LC_B170 | LC_B170    | DP_LC_B170 | CONDUIT |
| 500.4 2.6261  | 0.0100     |            |         |
| Dummy_LC_B180 | LC_B180    | DP_LC_B180 | CONDUIT |
| 945.1 1.6444  | 0.0100     |            |         |
| Dummy_LC_B190 | LC_B190    | DP_LC_B190 | CONDUIT |
| 560.4 1.0402  | 0.0100     |            |         |
| Dummy_LC_B20  | LC_B20     | DP_LC_B20  | CONDUIT |
| 2209.8 1.5882 | 0.0100     |            |         |

*SWMM Model Proposed – 5 Year*

|              |        |            |         |
|--------------|--------|------------|---------|
| Dummy_LC_B30 | LC_B30 | DP_LC_B30  | CONDUIT |
| 886.1        | 4.1255 | 0.0100     |         |
| Dummy_LC_B40 | LC_B40 | DP_LC_B40  | CONDUIT |
| 1126.6       | 3.7169 | 0.0100     |         |
| Dummy_LC_B50 | LC_B50 | DP_LC_B50  | CONDUIT |
| 1140.0       | 0.5861 | 0.0100     |         |
| Dummy_LC_B60 | LC_B60 | J.B_Main.2 | CONDUIT |
| 1522.6       | 1.4066 | 0.0100     |         |
| Dummy_LC_B70 | LC_B70 | DP_LC_B70  | CONDUIT |
| 1947.8       | 1.8267 | 0.0100     |         |
| Dummy_LC_B80 | LC_B80 | DP_LC_B80  | CONDUIT |
| 1370.6       | 5.0007 | 0.0100     |         |
| Dummy_LC_B90 | LC_B90 | DP_LC_B90  | CONDUIT |
| 1477.3       | 4.9680 | 0.0100     |         |
| Dummy_LC_C10 | LC_C10 | Out_LC_C   | CONDUIT |
| 1192.4       | 1.4501 | 0.0100     |         |
| Dummy_LC_D10 | LC_D10 | Out_LC_E   | CONDUIT |
| 608.2        | 0.3861 | 0.0100     |         |
| Dummy_LC_F10 | LC_F10 | Out_LC_F   | CONDUIT |
| 1188.1       | 3.1263 | 0.0100     |         |
| Dummy_LC_F20 | LC_F20 | DP_LC_F20  | CONDUIT |
| 309.1        | 6.6180 | 0.0100     |         |
| Dummy_LC_G10 | LC_G10 | Out_LC_G10 | CONDUIT |
| 797.2        | 2.6904 | 0.0100     |         |
| Dummy_LC_H10 | LC_H10 | Out_LC_H10 | CONDUIT |
| 546.2        | 4.4143 | 0.0100     |         |
| Dummy_LC_I10 | LC_I10 | DP.LC_I    | CONDUIT |
| 1196.0       | 1.2855 | 0.0100     |         |
| Dummy_LC_I20 | LC_I20 | DP_LC_I20  | CONDUIT |
| 1520.7       | 2.3941 | 0.0100     |         |
| Dummy_OS_B1  | OS_B1  | DP_OS_B1   | CONDUIT |
| 388.8        | 4.1459 | 0.0100     |         |
| Dummy_OS_B2  | OS_B2  | DP_OS_B2   | CONDUIT |
| 836.3        | 2.3765 | 0.0100     |         |
| Dummy_OS1    | OS1    | DP_OS1     | CONDUIT |
| 3482.0       | 1.9161 | 0.0100     |         |
| Dummy_OS10   | OS10   | DP_OS10    | CONDUIT |
| 460.8        | 4.2688 | 0.0100     |         |
| Dummy_OS2    | OS2    | DP_OS2     | CONDUIT |
| 1242.8       | 2.2974 | 0.0100     |         |
| Dummy_OS3    | OS3    | DP_OS3     | CONDUIT |
| 9018.4       | 1.8056 | 0.0100     |         |
| Dummy_OS4    | OS4    | DP_OS4     | CONDUIT |
| 811.6        | 5.2783 | 0.0100     |         |
| Dummy_OS5    | OS5    | DP_OS5     | CONDUIT |
| 395.2        | 1.8938 | 0.0100     |         |
| Dummy_OS6    | OS6    | DP_OS6     | CONDUIT |
| 1040.0       | 0.0101 | 0.0100     |         |
| Dummy_OS7    | OS7    | DP_OS7     | CONDUIT |
| 657.7        | 3.6352 | 0.0100     |         |
| Dummy_OS8    | OS8    | DP_OS8     | CONDUIT |
| 393.2        | 5.5555 | 0.0100     |         |
| Dummy_OS9    | OS9    | DP_OS9     | CONDUIT |
| 2515.8       | 2.8023 | 0.0100     |         |

*SWMM Model Proposed – 5 Year*

|               |            |                  |         |
|---------------|------------|------------------|---------|
| Dummy_UEC_A10 | UEC_A10    | Out_UEC_A        | CONDUIT |
| 1521.5        | 2.0172     | 0.0100           |         |
| Dummy_UEC_A20 | UEC_A20    | DP_UEC_A20       | CONDUIT |
| 440.2         | 5.6715     | 0.0100           |         |
| Dummy_UEC_B   | UEC_B10    | DP_UEC_B10       | CONDUIT |
| 1883.2        | 2.3236     | 0.0100           |         |
| Dummy_UEC_B20 | UEC_B20    | DP_UEC_B20       | CONDUIT |
| 1490.5        | 3.2471     | 0.0100           |         |
| Dummy_UEC_B30 | UEC_B30    | DP_UEC_B30       | CONDUIT |
| 640.4         | 4.7294     | 0.0100           |         |
| Dummy_UEC_B40 | UEC_B40    | DP_UEC_B40       | CONDUIT |
| 380.6         | 3.2948     | 0.0100           |         |
| Dummy_UEC_C10 | UEC_C10    | Out_UEC_C10      | CONDUIT |
| 695.7         | 4.3682     | 0.0100           |         |
| Dummy_UEC_D10 | UEC_D10    | Out_UEC_D10      | CONDUIT |
| 352.4         | 1.1481     | 0.0100           |         |
| Over.Dr_B     | Out_Dr_B10 | Out.Dr           | CONDUIT |
| 369.4         | 3.3442     | 0.0350           |         |
| Over.LC.G     | J_LC.G.H   | Out_LC.G.H       | CONDUIT |
| 480.7         | 2.2179     | 0.0350           |         |
| Over.LC_B     | Out_LC_B   | Out_LC.B.F       | CONDUIT |
| 886.1         | 1.5033     | 0.0350           |         |
| Over.LC_D     | DP_LC_C.D  | Out_C.D          | CONDUIT |
| 131.0         | 0.4351     | 0.0350           |         |
| Over.LC_F     | Out_LC_F   | Out_LC.B.F       | CONDUIT |
| 684.7         | 1.1008     | 0.0350           |         |
| Over_LC_A25   | J_LC_A25   | J4               | CONDUIT |
| 707.8         | 3.1696     | 0.0350           |         |
| Over_OS4      | J_OS4      | J1               | CONDUIT |
| 3674.0        | 1.7494     | 0.0350           |         |
| Over_OS5      | DP_OS5     | J1               | CONDUIT |
| 3464.9        | 2.4535     | 0.0300           |         |
| Over_OS8_1    | J_OS8      | DP_LC_A30        | CONDUIT |
| 1266.5        | 1.1078     | 0.0350           |         |
| Pipe.LC_A.20  | DP_LC_A30  | DP_LC_A20        | CONDUIT |
| 2307.6        | 0.3444     | 0.0130           |         |
| Pipe.LC_B.110 | DP_LC_B110 | J.B_Main.4       | CONDUIT |
| 586.5         | 1.7379     | 0.0130           |         |
| Pipe.LC_B.120 | DP_LC_B120 | J.B_Main.4       | CONDUIT |
| 524.8         | 2.4125     | 0.0130           |         |
| Pipe.LC_B.40  | DP_LC_B40  | DP_LC_B30        | CONDUIT |
| 1334.5        | 2.0169     | 0.0130           |         |
| Pipe.LC_B.70  | DP_LC_B70  | J.B_Upper.Main_1 | CONDUIT |
| 256.9         | 1.2598     | 0.0130           |         |
| Pipe.LC_B.80  | DP_LC_B80  | J.B_Main.2       | CONDUIT |
| 242.8         | 4.7145     | 0.0130           |         |
| Pipe.LC_F.10  | DP_LC_F20  | J.B_Main.1       | CONDUIT |
| 1284.8        | 0.8406     | 0.0320           |         |
| Pipe.LC_I     | DP.LC_I    | Out_LC_I         | CONDUIT |
| 53.1          | 0.4805     | 0.0130           |         |
| Pipe.UEC_B.30 | DP_UEC_B30 | J.UEC_B.1        | CONDUIT |
| 126.5         | 4.9680     | 0.0130           |         |
| Pipe.UEC_B40  | DP_UEC_B40 | J.UEC_B.1        | CONDUIT |
| 141.4         | 0.7923     | 0.0130           |         |



## SWMM Model Proposed – 5 Year

\*\*\*\*\*  
 Cross Section Summary  
 \*\*\*\*\*

| No. of<br>Conduit<br>Barrels | Full<br>Flow               | Shape       | Full<br>Depth | Full<br>Area | Hyd.<br>Rad. | Max.<br>Width |
|------------------------------|----------------------------|-------------|---------------|--------------|--------------|---------------|
| 1                            | Ch.Dr_A.Main10<br>229.28   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_A.Main10<br>3427.98  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_A.Side10<br>501.56   | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_A.Side11<br>1363.79  | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_B.30<br>612.34       | TRAPEZOIDAL | 3.00          | 81.00        | 2.04         | 39.00         |
| 1                            | Ch.LC_B.Side.120<br>391.02 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.121<br>161.09 | TRAPEZOIDAL | 3.00          | 81.00        | 2.04         | 39.00         |
| 1                            | Ch.LC_B.Side.140<br>259.50 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.Lc_B.Side.150<br>411.94 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.160<br>309.00 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.90<br>310.66  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.91<br>427.70  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side122<br>311.09  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side130<br>833.53  | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_B.Side20<br>3641.46  | RECT_OPEN   | 2.00          | 400.00       | 1.96         | 200.00        |
| 1                            | Ch.LC_B.Side50<br>1388.25  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_B_Side10<br>1964.97  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_D.Main10<br>203.48   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_D.Main11<br>249.06   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_G.Main10<br>120.93   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_H.Main10<br>169.38   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |

*SWMM Model Proposed – 5 Year*

|                 |             |       |        |      |        |
|-----------------|-------------|-------|--------|------|--------|
| Ch.LC_I.Main1   | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 232.99        |             |       |        |      |        |
| Ch.OS_B1        | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 291.78        |             |       |        |      |        |
| Ch.OS_B2        | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 374.40        |             |       |        |      |        |
| Ch.OS2          | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
| 1 696.68        |             |       |        |      |        |
| Ch.UEC_A.Main10 | RECT_OPEN   | 2.00  | 400.00 | 1.96 | 200.00 |
| 1 3132.77       |             |       |        |      |        |
| Ch.UEC_A.Main11 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 301.76        |             |       |        |      |        |
| Ch.UEC_A.Main20 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 354.23        |             |       |        |      |        |
| Ch.UEC_B        | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
| 1 4326.21       |             |       |        |      |        |
| Ch.UEC_B.Main10 | TRAPEZOIDAL | 5.00  | 225.00 | 3.40 | 65.00  |
| 1 4051.76       |             |       |        |      |        |
| Ch.UEC_B.Side10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 453.20        |             |       |        |      |        |
| Ch.UEC_B.Side20 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 506.94        |             |       |        |      |        |
| Ch.UEC_C.Main10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 265.05        |             |       |        |      |        |
| Ch.UEC_D.Main10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
| 1 274.84        |             |       |        |      |        |
| Ch_1            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1 4666.46       |             |       |        |      |        |
| Ch_2            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1 4280.31       |             |       |        |      |        |
| Ch_3            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1 3666.59       |             |       |        |      |        |
| Ch_4            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
| 1 3668.12       |             |       |        |      |        |
| Ch_LC_A10       | TRAPEZOIDAL | 10.00 | 900.00 | 6.34 | 140.00 |
| 1 24339.02      |             |       |        |      |        |
| Ch_Main_1       | TRIANGULAR  | 5.00  | 375.00 | 2.49 | 150.00 |
| 1 3644.29       |             |       |        |      |        |
| Ch_Main_2       | TRIANGULAR  | 5.50  | 412.50 | 2.74 | 150.00 |
| 1 2843.80       |             |       |        |      |        |
| Ch_Main_3       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
| 1 3269.68       |             |       |        |      |        |
| Ch_Main_4       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
| 1 2790.18       |             |       |        |      |        |
| Ch_Main_5       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
| 1 2451.08       |             |       |        |      |        |
| Ch_Main_6       | TRAPEZOIDAL | 5.00  | 400.00 | 3.95 | 100.00 |
| 1 3303.73       |             |       |        |      |        |
| Ch_OS10         | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
| 1 837.84        |             |       |        |      |        |
| Ch_OS6          | TRIANGULAR  | 5.00  | 500.00 | 2.50 | 200.00 |
| 1 7700.00       |             |       |        |      |        |
| Ch_Upper.Main_1 | TRIANGULAR  | 5.00  | 125.00 | 2.45 | 50.00  |
| 1 965.54        |             |       |        |      |        |

*SWMM Model Proposed – 5 Year*

|   |                           |             |      |        |      |       |
|---|---------------------------|-------------|------|--------|------|-------|
| 1 | Ch_Upper.Main_2<br>649.23 | TRIANGULAR  | 5.00 | 125.00 | 2.45 | 50.00 |
| 1 | Culv_LC_A10<br>1159.39    | RECT_CLOSED | 8.00 | 48.00  | 1.71 | 6.00  |
| 1 | Culv_LC_A20<br>139.80     | RECT_CLOSED | 3.00 | 9.00   | 0.75 | 3.00  |
| 3 | Culv_OS1<br>93.47         | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 2 | Culv_OS2<br>45.70         | CIRCULAR    | 2.50 | 4.91   | 0.62 | 2.50  |
| 2 | Culv_OS4<br>32.88         | CIRCULAR    | 3.50 | 9.62   | 0.88 | 3.50  |
| 2 | Culv_OS6<br>115.09        | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 3 | Culv_OS7<br>23.34         | CIRCULAR    | 2.00 | 3.14   | 0.50 | 2.00  |
| 3 | Culv_OS8<br>22.91         | CIRCULAR    | 2.50 | 4.91   | 0.62 | 2.50  |
| 3 | Culv_OS9<br>51.60         | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 1 | Dummy_Dr_A10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_Dr_B10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A20<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A25<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A30<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B100<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B110<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B120<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B130<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B140<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B150<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B160<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B170<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B180<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B190<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |

*SWMM Model Proposed – 5 Year*

|   |              |       |      |      |      |      |
|---|--------------|-------|------|------|------|------|
| 1 | Dummy_LC_B20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B30 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B40 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B50 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B60 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B70 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B80 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B90 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_C10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_D10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_F10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_F20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_G10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_H10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_I10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_I20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS_B1  | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS_B2  | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS1    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS10   | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS2    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS3    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS4    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS5    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS6    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS7    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_Os8    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |

*SWMM Model Proposed – 5 Year*

|   |                         |             |      |        |      |        |
|---|-------------------------|-------------|------|--------|------|--------|
| 1 | Dummy_OS9<br>0.00       | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_A10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_A20<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B20<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B30<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B40<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_C10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_D10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Over.Dr_B<br>2401.37    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC.G<br>1955.60    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC_B<br>4584.09    | RECT_OPEN   | 1.50 | 675.00 | 1.49 | 450.00 |
| 1 | Over.LC_D<br>866.20     | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC_F<br>1377.75    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over_LC_A25<br>108.65   | TRAPEZOIDAL | 0.50 | 23.50  | 0.48 | 49.00  |
| 1 | Over_OS4<br>8838.21     | TRAPEZOIDAL | 5.00 | 600.00 | 4.25 | 140.00 |
| 1 | Over_OS5<br>10645.06    | RECT_OPEN   | 5.00 | 500.00 | 4.55 | 100.00 |
| 1 | Over_OS8_1<br>2800.25   | RECT_OPEN   | 2.00 | 400.00 | 1.96 | 200.00 |
| 1 | Pipe.LC_A.20<br>248.55  | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.LC_B.110<br>87.93  | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |
| 1 | Pipe.LC_B.120<br>657.81 | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.LC_B.40<br>369.87  | CIRCULAR    | 5.00 | 19.63  | 1.25 | 5.00   |
| 1 | Pipe.LC_B.70<br>161.22  | CIRCULAR    | 4.00 | 12.57  | 1.00 | 4.00   |
| 1 | Pipe.LC_B.80<br>144.82  | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |
| 1 | Pipe.LC_F.10<br>554.40  | TRAPEZOIDAL | 3.00 | 81.00  | 2.04 | 39.00  |
| 1 | Pipe.LC_I<br>293.56     | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.UEC_B.30<br>148.66 | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |

SWMM Model Proposed – 5 Year

1 Pipe.UEC\_B40 CIRCULAR 3.00 7.07 0.75 3.00  
 59.37

\*\*\*\*\*

Analysis Options

\*\*\*\*\*

Flow Units ..... CFS

Process Models:

Rainfall/Runoff ..... NO  
 RDII ..... NO  
 Snowmelt ..... NO  
 Groundwater ..... NO  
 Flow Routing ..... YES  
 Ponding Allowed ..... NO  
 Water Quality ..... NO

Flow Routing Method ..... KINWAVE

Starting Date ..... 01/01/2024 00:00:00

Ending Date ..... 01/02/2024 00:00:00

Antecedent Dry Days ..... 0.0

Report Time Step ..... 00:01:00

Routing Time Step ..... 5.00 sec

\*\*\*\*\*

|                            | Volume    | Volume   |
|----------------------------|-----------|----------|
|                            | acre-feet | 10^6 gal |
| *****                      | -----     | -----    |
| Dry Weather Inflow .....   | 0.000     | 0.000    |
| Wet Weather Inflow .....   | 0.000     | 0.000    |
| Groundwater Inflow .....   | 0.000     | 0.000    |
| RDII Inflow .....          | 0.000     | 0.000    |
| External Inflow .....      | 88.025    | 28.684   |
| External Outflow .....     | 90.411    | 29.462   |
| Flooding Loss .....        | 0.000     | 0.000    |
| Evaporation Loss .....     | 0.000     | 0.000    |
| Exfiltration Loss .....    | 0.000     | 0.000    |
| Initial Stored Volume .... | 0.000     | 0.000    |
| Final Stored Volume .....  | 0.045     | 0.015    |
| Continuity Error (%) ..... | -2.762    |          |

\*\*\*\*\*

Highest Flow Instability Indexes

\*\*\*\*\*

All links are stable.

\*\*\*\*\*

Routing Time Step Summary

\*\*\*\*\*

Minimum Time Step : 5.00 sec  
 Average Time Step : 5.00 sec  
 Maximum Time Step : 5.00 sec  
 % of Time in Steady State : 0.00

*SWMM Model Proposed – 5 Year*

Average Iterations per Step : 1.00  
 % of Steps Not Converging : 0.00

\*\*\*\*\*  
 Node Depth Summary  
 \*\*\*\*\*

| Reported<br>Max Depth<br>Node<br>Feet | Type     | Average<br>Depth<br>Feet | Maximum<br>Depth<br>Feet | Maximum<br>HGL<br>Feet | Time of Max<br>Occurrence<br>days hr:min |
|---------------------------------------|----------|--------------------------|--------------------------|------------------------|------------------------------------------|
| 1.83                                  | JUNCTION | 0.13                     | 1.84                     | 6256.40                | 0 00:37                                  |
| 1.77                                  | JUNCTION | 0.13                     | 1.77                     | 6371.77                | 0 00:35                                  |
| 1.83                                  | JUNCTION | 0.12                     | 1.83                     | 6379.78                | 0 00:31                                  |
| 0.81                                  | JUNCTION | 0.06                     | 0.81                     | 6285.10                | 0 00:33                                  |
| 1.54                                  | JUNCTION | 0.15                     | 1.54                     | 6288.30                | 0 00:44                                  |
| 0.32                                  | JUNCTION | 0.03                     | 0.32                     | 6336.40                | 0 00:41                                  |
| 0.29                                  | JUNCTION | 0.02                     | 0.29                     | 6377.04                | 0 00:34                                  |
| 0.45                                  | JUNCTION | 0.03                     | 0.45                     | 6339.02                | 0 00:35                                  |
| 0.83                                  | JUNCTION | 0.04                     | 0.83                     | 6319.38                | 0 00:33                                  |
| 0.12                                  | JUNCTION | 0.01                     | 0.12                     | 6403.28                | 0 00:35                                  |
| 0.58                                  | JUNCTION | 0.03                     | 0.59                     | 6351.25                | 0 00:31                                  |
| 0.69                                  | JUNCTION | 0.03                     | 0.69                     | 6339.86                | 0 00:30                                  |
| 0.55                                  | JUNCTION | 0.07                     | 0.55                     | 6222.37                | 0 01:06                                  |
| 1.44                                  | JUNCTION | 0.09                     | 1.44                     | 6242.56                | 0 00:35                                  |
| 1.44                                  | JUNCTION | 0.08                     | 1.44                     | 6269.47                | 0 00:34                                  |
| 0.28                                  | JUNCTION | 0.03                     | 0.28                     | 6272.26                | 0 01:10                                  |
| 1.26                                  | JUNCTION | 0.10                     | 1.26                     | 6250.50                | 0 00:38                                  |
| 0.84                                  | JUNCTION | 0.08                     | 0.84                     | 6250.64                | 0 00:41                                  |

*SWMM Model Proposed – 5 Year*

|                    |          |      |      |         |   |       |
|--------------------|----------|------|------|---------|---|-------|
| DP_LC_B90<br>0.74  | JUNCTION | 0.05 | 0.74 | 6271.18 | 0 | 00:37 |
| DP_LC_C.D<br>0.58  | JUNCTION | 0.03 | 0.58 | 6245.55 | 0 | 00:34 |
| DP_LC_F20<br>1.13  | JUNCTION | 0.06 | 1.13 | 6231.08 | 0 | 00:38 |
| DP_LC_I20<br>0.74  | JUNCTION | 0.04 | 0.74 | 6277.48 | 0 | 00:34 |
| DP_OS_B1<br>0.02   | JUNCTION | 0.00 | 0.02 | 6293.08 | 0 | 00:32 |
| DP_OS_B2<br>0.05   | JUNCTION | 0.00 | 0.05 | 6289.75 | 0 | 00:33 |
| DP_OS1<br>0.37     | JUNCTION | 0.04 | 0.37 | 6282.82 | 0 | 00:51 |
| DP_OS10<br>0.07    | JUNCTION | 0.01 | 0.07 | 6373.14 | 0 | 00:36 |
| DP_OS2<br>0.44     | JUNCTION | 0.05 | 0.44 | 6314.20 | 0 | 00:48 |
| DP_OS3<br>0.81     | JUNCTION | 0.09 | 0.81 | 6291.31 | 0 | 01:08 |
| DP_OS4<br>0.38     | JUNCTION | 0.02 | 0.38 | 6420.47 | 0 | 00:36 |
| DP_OS5<br>0.01     | JUNCTION | 0.00 | 0.01 | 6440.73 | 0 | 00:36 |
| DP_OS6<br>0.10     | JUNCTION | 0.01 | 0.10 | 6428.16 | 0 | 00:45 |
| DP_OS7<br>0.22     | JUNCTION | 0.02 | 0.22 | 6392.50 | 0 | 00:45 |
| DP_OS8<br>0.41     | JUNCTION | 0.03 | 0.41 | 6393.61 | 0 | 00:34 |
| DP_OS9<br>0.32     | JUNCTION | 0.04 | 0.32 | 6359.52 | 0 | 00:56 |
| DP_UEC_A20<br>0.26 | JUNCTION | 0.02 | 0.26 | 6377.96 | 0 | 00:32 |
| DP_UEC_B10<br>0.66 | JUNCTION | 0.07 | 0.66 | 6308.64 | 0 | 00:36 |
| DP_UEC_B20<br>0.57 | JUNCTION | 0.04 | 0.57 | 6314.69 | 0 | 00:35 |
| DP_UEC_B30<br>0.76 | JUNCTION | 0.04 | 0.76 | 6368.69 | 0 | 00:30 |
| DP_UEC_B40<br>0.59 | JUNCTION | 0.03 | 0.59 | 6363.36 | 0 | 00:30 |
| Dr_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6347.11 | 0 | 00:00 |
| Dr_B10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6329.34 | 0 | 00:00 |
| J.B_Main.1<br>2.28 | JUNCTION | 0.43 | 2.28 | 6221.44 | 0 | 01:19 |
| J.B_Main.2<br>2.33 | JUNCTION | 0.42 | 2.33 | 6240.69 | 0 | 01:06 |
| J.B_Main.3<br>2.33 | JUNCTION | 0.43 | 2.33 | 6260.85 | 0 | 01:02 |
| J.B_Main.4<br>2.33 | JUNCTION | 0.42 | 2.33 | 6276.43 | 0 | 00:59 |



*SWMM Model Proposed – 5 Year*

|                           |          |      |      |         |   |       |
|---------------------------|----------|------|------|---------|---|-------|
| J.B_Main.5<br>2.06        | JUNCTION | 0.37 | 2.06 | 6289.48 | 0 | 01:09 |
| J.B_Side.120<br>1.38      | JUNCTION | 0.11 | 1.38 | 6288.92 | 0 | 00:40 |
| J.B_Upper.Main_.2<br>0.88 | JUNCTION | 0.14 | 0.88 | 6251.07 | 0 | 01:03 |
| J.B_Upper.Main_1<br>1.44  | JUNCTION | 0.21 | 1.44 | 6247.44 | 0 | 00:38 |
| J.UEC_B.1<br>0.76         | JUNCTION | 0.04 | 0.76 | 6362.41 | 0 | 00:30 |
| J_LC.G.H<br>0.75          | JUNCTION | 0.05 | 0.75 | 6213.54 | 0 | 00:35 |
| J_LC_A10<br>1.08          | JUNCTION | 0.06 | 1.08 | 6347.66 | 0 | 00:36 |
| J_LC_A25<br>0.53          | JUNCTION | 0.03 | 0.53 | 6321.16 | 0 | 00:32 |
| J_OS1<br>0.37             | JUNCTION | 0.04 | 0.37 | 6278.31 | 0 | 00:51 |
| J_OS2<br>0.44             | JUNCTION | 0.05 | 0.44 | 6310.86 | 0 | 00:48 |
| J_OS4<br>0.38             | JUNCTION | 0.02 | 0.38 | 6420.38 | 0 | 00:36 |
| J_OS6<br>0.13             | JUNCTION | 0.02 | 0.13 | 6425.74 | 0 | 00:45 |
| J_OS7<br>0.22             | JUNCTION | 0.02 | 0.22 | 6388.91 | 0 | 00:46 |
| J_OS8<br>0.41             | JUNCTION | 0.03 | 0.41 | 6392.39 | 0 | 00:34 |
| J_OS9<br>0.32             | JUNCTION | 0.04 | 0.32 | 6358.05 | 0 | 00:56 |
| J1<br>0.03                | JUNCTION | 0.01 | 0.03 | 6355.77 | 0 | 01:34 |
| J2<br>0.12                | JUNCTION | 0.02 | 0.12 | 6323.47 | 0 | 01:16 |
| J3<br>0.61                | JUNCTION | 0.05 | 0.61 | 6306.33 | 0 | 00:39 |
| J4<br>0.66                | JUNCTION | 0.05 | 0.66 | 6298.87 | 0 | 00:43 |
| LC_A10<br>0.00            | JUNCTION | 0.00 | 0.00 | 6373.50 | 0 | 00:00 |
| LC_A20<br>0.00            | JUNCTION | 0.00 | 0.00 | 6394.79 | 0 | 00:00 |
| LC_A25<br>0.00            | JUNCTION | 0.00 | 0.00 | 6358.75 | 0 | 00:00 |
| LC_A30<br>0.00            | JUNCTION | 0.00 | 0.00 | 6377.99 | 0 | 00:00 |
| LC_B10<br>0.00            | JUNCTION | 0.00 | 0.00 | 6227.60 | 0 | 00:00 |
| LC_B100<br>0.00           | JUNCTION | 0.00 | 0.00 | 6278.59 | 0 | 00:00 |
| LC_B110<br>0.00           | JUNCTION | 0.00 | 0.00 | 6305.11 | 0 | 00:00 |
| LC_B120<br>0.00           | JUNCTION | 0.00 | 0.00 | 6328.08 | 0 | 00:00 |

SWMM Model Proposed – 5 Year

|         |          |      |      |         |   |       |
|---------|----------|------|------|---------|---|-------|
| LC_B130 | JUNCTION | 0.00 | 0.00 | 6376.10 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B140 | JUNCTION | 0.00 | 0.00 | 6390.52 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B150 | JUNCTION | 0.00 | 0.00 | 6364.46 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B160 | JUNCTION | 0.00 | 0.00 | 6354.39 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B170 | JUNCTION | 0.00 | 0.00 | 6416.30 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B180 | JUNCTION | 0.00 | 0.00 | 6366.21 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B190 | JUNCTION | 0.00 | 0.00 | 6345.00 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B20  | JUNCTION | 0.00 | 0.00 | 6256.91 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B30  | JUNCTION | 0.00 | 0.00 | 6277.65 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B40  | JUNCTION | 0.00 | 0.00 | 6309.88 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B50  | JUNCTION | 0.00 | 0.00 | 6278.66 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B60  | JUNCTION | 0.00 | 0.00 | 6259.78 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B70  | JUNCTION | 0.00 | 0.00 | 6284.81 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B80  | JUNCTION | 0.00 | 0.00 | 6318.25 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_B90  | JUNCTION | 0.00 | 0.00 | 6343.74 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_C10  | JUNCTION | 0.00 | 0.00 | 6267.21 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_D10  | JUNCTION | 0.00 | 0.00 | 6248.16 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_F10  | JUNCTION | 0.00 | 0.00 | 6246.12 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_F20  | JUNCTION | 0.00 | 0.00 | 6250.36 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_G10  | JUNCTION | 0.00 | 0.00 | 6234.42 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_H10  | JUNCTION | 0.00 | 0.00 | 6237.87 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_I10  | JUNCTION | 0.00 | 0.00 | 6269.94 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| LC_I20  | JUNCTION | 0.00 | 0.00 | 6313.14 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| OS_B1   | JUNCTION | 0.00 | 0.00 | 6309.16 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| OS_B2   | JUNCTION | 0.00 | 0.00 | 6309.56 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| OS1     | JUNCTION | 0.00 | 0.00 | 6349.15 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |
| OS10    | JUNCTION | 0.00 | 0.00 | 6392.72 | 0 | 00:00 |
| 0.00    |          |      |      |         |   |       |

*SWMM Model Proposed – 5 Year*

|                     |          |      |      |         |   |       |
|---------------------|----------|------|------|---------|---|-------|
| OS10_In<br>0.13     | JUNCTION | 0.02 | 0.13 | 6372.47 | 0 | 01:00 |
| OS2<br>0.00         | JUNCTION | 0.00 | 0.00 | 6342.30 | 0 | 00:00 |
| OS3<br>0.00         | JUNCTION | 0.00 | 0.00 | 6453.31 | 0 | 00:00 |
| OS4<br>0.00         | JUNCTION | 0.00 | 0.00 | 6462.88 | 0 | 00:00 |
| OS5<br>0.00         | JUNCTION | 0.00 | 0.00 | 6448.20 | 0 | 00:00 |
| OS6<br>0.00         | JUNCTION | 0.00 | 0.00 | 6428.17 | 0 | 00:00 |
| OS7<br>0.00         | JUNCTION | 0.00 | 0.00 | 6416.17 | 0 | 00:00 |
| OS8<br>0.00         | JUNCTION | 0.00 | 0.00 | 6415.01 | 0 | 00:00 |
| OS9<br>0.00         | JUNCTION | 0.00 | 0.00 | 6429.66 | 0 | 00:00 |
| Out_Dr_A10<br>0.69  | JUNCTION | 0.04 | 0.69 | 6328.17 | 0 | 00:35 |
| Out_Dr_B10<br>0.69  | JUNCTION | 0.05 | 0.69 | 6316.58 | 0 | 00:38 |
| Out_LC_A10<br>1.08  | JUNCTION | 0.06 | 1.08 | 6350.28 | 0 | 00:36 |
| Out_LC_A25<br>0.53  | JUNCTION | 0.03 | 0.53 | 6322.83 | 0 | 00:32 |
| Out_LC_B<br>2.00    | JUNCTION | 0.37 | 2.00 | 6216.77 | 0 | 01:17 |
| Out_LC_C<br>0.58    | JUNCTION | 0.03 | 0.58 | 6250.50 | 0 | 00:33 |
| Out_LC_E<br>0.37    | JUNCTION | 0.02 | 0.37 | 6246.18 | 0 | 00:36 |
| Out_LC_F<br>0.26    | JUNCTION | 0.01 | 0.26 | 6209.26 | 0 | 00:32 |
| Out_LC_G10<br>0.75  | JUNCTION | 0.05 | 0.75 | 6213.73 | 0 | 00:35 |
| Out_LC_H10<br>0.29  | JUNCTION | 0.02 | 0.29 | 6214.07 | 0 | 00:32 |
| Out_UEC_A<br>0.61   | JUNCTION | 0.07 | 0.61 | 6319.48 | 0 | 00:37 |
| Out_UEC_B<br>0.66   | JUNCTION | 0.06 | 0.66 | 6303.47 | 0 | 00:36 |
| Out_UEC_C10<br>0.51 | JUNCTION | 0.03 | 0.51 | 6327.60 | 0 | 00:36 |
| Out_UEC_D10<br>0.31 | JUNCTION | 0.02 | 0.31 | 6345.29 | 0 | 00:32 |
| UEC_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6349.56 | 0 | 00:00 |
| UEC_A20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6402.62 | 0 | 00:00 |
| UEC_B10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6351.73 | 0 | 00:00 |
| UEC_B20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6362.49 | 0 | 00:00 |

*SWMM Model Proposed – 5 Year*

|            |          |      |      |         |   |       |
|------------|----------|------|------|---------|---|-------|
| UEC_B30    | JUNCTION | 0.00 | 0.00 | 6398.18 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_B40    | JUNCTION | 0.00 | 0.00 | 6375.31 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_C10    | JUNCTION | 0.00 | 0.00 | 6357.45 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_D10    | JUNCTION | 0.00 | 0.00 | 6349.03 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| Out.Dr     | OUTFALL  | 0.01 | 0.17 | 6303.71 | 0 | 00:38 |
| 0.17       |          |      |      |         |   |       |
| Out_C.D    | OUTFALL  | 0.02 | 0.27 | 6244.67 | 0 | 00:36 |
| 0.27       |          |      |      |         |   |       |
| Out_LC.B.F | OUTFALL  | 0.04 | 0.34 | 6201.79 | 0 | 01:20 |
| 0.34       |          |      |      |         |   |       |
| Out_LC.G.H | OUTFALL  | 0.01 | 0.14 | 6202.28 | 0 | 00:38 |
| 0.14       |          |      |      |         |   |       |
| Out_LC_I   | OUTFALL  | 0.13 | 1.84 | 6256.15 | 0 | 00:37 |
| 1.83       |          |      |      |         |   |       |
| UEC_Out    | OUTFALL  | 0.05 | 0.64 | 6279.59 | 0 | 00:43 |
| 0.64       |          |      |      |         |   |       |

\*\*\*\*\*  
Node Inflow Summary  
\*\*\*\*\*

-----

| Lateral    | Total    | Flow     | Maximum | Maximum | Time of Max |       | 10^6 |
|------------|----------|----------|---------|---------|-------------|-------|------|
|            |          |          | Lateral | Total   |             |       |      |
| Inflow     | Inflow   | Balance  | Inflow  | Inflow  | Occurrence  |       |      |
| Volume     | Volume   | Error    | CFS     | CFS     | days hr:min |       |      |
| Node       | 10^6 gal | Type     |         |         |             |       |      |
| gal        | 10^6 gal | Percent  |         |         |             |       |      |
| DP_LC_I    |          | JUNCTION | 0.00    | 59.67   | 0           | 00:37 |      |
| 0          | 1.63     | 0.000    |         |         |             |       |      |
| DP_LC_A20  |          | JUNCTION | 0.00    | 69.17   | 0           | 00:34 |      |
| 0          | 1.69     | 0.000    |         |         |             |       |      |
| DP_LC_A30  |          | JUNCTION | 0.00    | 50.19   | 0           | 00:31 |      |
| 0          | 1.07     | 0.000    |         |         |             |       |      |
| DP_LC_B110 |          | JUNCTION | 0.00    | 14.08   | 0           | 00:33 |      |
| 0          | 0.416    | -0.000   |         |         |             |       |      |
| DP_LC_B120 |          | JUNCTION | 0.00    | 95.10   | 0           | 00:44 |      |
| 0          | 3.25     | -0.000   |         |         |             |       |      |
| DP_LC_B130 |          | JUNCTION | 0.00    | 12.69   | 0           | 00:41 |      |
| 0          | 0.566    | 0.000    |         |         |             |       |      |
| DP_LC_B140 |          | JUNCTION | 0.00    | 12.16   | 0           | 00:34 |      |
| 0          | 0.376    | 0.000    |         |         |             |       |      |
| DP_LC_B150 |          | JUNCTION | 0.00    | 24.94   | 0           | 00:35 |      |
| 0          | 0.738    | 0.000    |         |         |             |       |      |

*SWMM Model Proposed – 5 Year*

|            |          |      |        |   |       |
|------------|----------|------|--------|---|-------|
| DP_LC_B160 | JUNCTION | 0.00 | 58.85  | 0 | 00:33 |
| 0 1.26     | 0.000    |      |        |   |       |
| DP_LC_B170 | JUNCTION | 0.00 | 1.71   | 0 | 00:35 |
| 0 0.0632   | 0.000    |      |        |   |       |
| DP_LC_B180 | JUNCTION | 0.00 | 31.29  | 0 | 00:31 |
| 0 0.645    | 0.000    |      |        |   |       |
| DP_LC_B190 | JUNCTION | 0.00 | 41.78  | 0 | 00:30 |
| 0 0.696    | 0.000    |      |        |   |       |
| DP_LC_B20  | JUNCTION | 0.00 | 36.77  | 0 | 01:06 |
| 0 1.9      | 0.000    |      |        |   |       |
| DP_LC_B30  | JUNCTION | 0.00 | 86.82  | 0 | 00:34 |
| 0 2.08     | 0.000    |      |        |   |       |
| DP_LC_B40  | JUNCTION | 0.00 | 66.69  | 0 | 00:34 |
| 0 1.62     | 0.000    |      |        |   |       |
| DP_LC_B50  | JUNCTION | 0.00 | 40.74  | 0 | 00:33 |
| 0 1.37     | 0.000    |      |        |   |       |
| DP_LC_B70  | JUNCTION | 0.00 | 34.93  | 0 | 00:38 |
| 0 1.26     | 0.000    |      |        |   |       |
| DP_LC_B80  | JUNCTION | 0.00 | 24.60  | 0 | 00:41 |
| 0 0.985    | 0.000    |      |        |   |       |
| DP_LC_B90  | JUNCTION | 0.00 | 66.24  | 0 | 00:37 |
| 0 1.92     | 0.000    |      |        |   |       |
| DP_LC_C.D  | JUNCTION | 0.00 | 31.41  | 0 | 00:35 |
| 0 0.836    | 0.000    |      |        |   |       |
| DP_LC_F20  | JUNCTION | 0.00 | 87.38  | 0 | 00:38 |
| 0 2.16     | 0.000    |      |        |   |       |
| DP_LC_I20  | JUNCTION | 0.00 | 35.85  | 0 | 00:34 |
| 0 0.972    | 0.000    |      |        |   |       |
| DP_OS_B1   | JUNCTION | 0.00 | 0.08   | 0 | 00:32 |
| 0 0.00161  | 0.000    |      |        |   |       |
| DP_OS_B2   | JUNCTION | 0.00 | 0.59   | 0 | 00:33 |
| 0 0.0109   | 0.000    |      |        |   |       |
| DP_OS1     | JUNCTION | 0.00 | 9.17   | 0 | 00:51 |
| 0 0.378    | 0.000    |      |        |   |       |
| DP_OS10    | JUNCTION | 0.00 | 0.95   | 0 | 00:36 |
| 0 0.037    | 0.000    |      |        |   |       |
| DP_OS2     | JUNCTION | 0.00 | 6.27   | 0 | 00:48 |
| 0 0.322    | 0.000    |      |        |   |       |
| DP_OS3     | JUNCTION | 0.00 | 140.83 | 0 | 01:08 |
| 0 7.23     | 0.000    |      |        |   |       |
| DP_OS4     | JUNCTION | 0.00 | 1.62   | 0 | 00:36 |
| 0 0.0371   | 0.000    |      |        |   |       |
| DP_OS5     | JUNCTION | 0.00 | 0.15   | 0 | 00:36 |
| 0 0.00551  | 0.000    |      |        |   |       |
| DP_OS6     | JUNCTION | 0.00 | 0.43   | 0 | 00:45 |
| 0 0.0193   | 0.000    |      |        |   |       |
| DP_OS7     | JUNCTION | 0.00 | 1.84   | 0 | 00:45 |
| 0 0.087    | 0.000    |      |        |   |       |
| DP_OS8     | JUNCTION | 0.00 | 4.08   | 0 | 00:34 |
| 0 0.0985   | 0.000    |      |        |   |       |
| DP_OS9     | JUNCTION | 0.00 | 3.80   | 0 | 00:56 |
| 0 0.186    | 0.000    |      |        |   |       |
| DP_UEC_A20 | JUNCTION | 0.00 | 8.92   | 0 | 00:32 |
| 0 0.252    | 0.000    |      |        |   |       |

*SWMM Model Proposed – 5 Year*

|                   |          |       |        |   |       |
|-------------------|----------|-------|--------|---|-------|
| DP_UEC_B10        | JUNCTION | 0.00  | 56.08  | 0 | 00:36 |
| 0 2.16            | 0.000    |       |        |   |       |
| DP_UEC_B20        | JUNCTION | 0.00  | 49.02  | 0 | 00:35 |
| 0 1.35            | 0.000    |       |        |   |       |
| DP_UEC_B30        | JUNCTION | 0.00  | 20.75  | 0 | 00:30 |
| 0 0.407           | 0.000    |       |        |   |       |
| DP_UEC_B40        | JUNCTION | 0.00  | 4.99   | 0 | 00:30 |
| 0 0.104           | 0.000    |       |        |   |       |
| Dr_A10            | JUNCTION | 31.27 | 31.27  | 0 | 00:35 |
| 0.925 0.925       | 0.000    |       |        |   |       |
| Dr_B10            | JUNCTION | 11.07 | 11.07  | 0 | 00:31 |
| 0.267 0.267       | 0.000    |       |        |   |       |
| J.B_Main.1        | JUNCTION | 0.00  | 315.92 | 0 | 01:16 |
| 0 16.3            | 0.000    |       |        |   |       |
| J.B_Main.2        | JUNCTION | 0.00  | 283.19 | 0 | 01:05 |
| 0 14              | 0.000    |       |        |   |       |
| J.B_Main.3        | JUNCTION | 0.00  | 262.49 | 0 | 01:02 |
| 0 12.9            | 0.000    |       |        |   |       |
| J.B_Main.4        | JUNCTION | 0.00  | 224.01 | 0 | 00:59 |
| 0 11              | 0.000    |       |        |   |       |
| J.B_Main.5        | JUNCTION | 0.00  | 140.82 | 0 | 01:09 |
| 0 7.23            | 0.000    |       |        |   |       |
| J.B_Side.120      | JUNCTION | 0.00  | 36.62  | 0 | 00:40 |
| 0 1.31            | -0.000   |       |        |   |       |
| J.B_Upper.Main_.2 | JUNCTION | 0.00  | 6.32   | 0 | 01:03 |
| 0 0.341           | 0.000    |       |        |   |       |
| J.B_Upper.Main_1  | JUNCTION | 0.00  | 34.92  | 0 | 00:38 |
| 0 1.6             | 0.000    |       |        |   |       |
| J.UEC_B.1         | JUNCTION | 0.00  | 25.71  | 0 | 00:30 |
| 0 0.51            | 0.000    |       |        |   |       |
| J_LC.G.H          | JUNCTION | 0.00  | 24.05  | 0 | 00:34 |
| 0 0.722           | 0.000    |       |        |   |       |
| J_LC_A10          | JUNCTION | 0.00  | 93.44  | 0 | 00:36 |
| 0 2.33            | 0.000    |       |        |   |       |
| J_LC_A25          | JUNCTION | 0.00  | 16.06  | 0 | 00:32 |
| 0 0.451           | 0.000    |       |        |   |       |
| J_OS1             | JUNCTION | 0.00  | 9.17   | 0 | 00:51 |
| 0 0.378           | 0.000    |       |        |   |       |
| J_OS2             | JUNCTION | 0.00  | 6.27   | 0 | 00:48 |
| 0 0.322           | 0.000    |       |        |   |       |
| J_OS4             | JUNCTION | 0.00  | 1.62   | 0 | 00:36 |
| 0 0.0371          | 0.000    |       |        |   |       |
| J_OS6             | JUNCTION | 0.00  | 0.43   | 0 | 00:45 |
| 0 0.0193          | 0.000    |       |        |   |       |
| J_OS7             | JUNCTION | 0.00  | 1.84   | 0 | 00:46 |
| 0 0.087           | 0.000    |       |        |   |       |
| J_OS8             | JUNCTION | 0.00  | 4.07   | 0 | 00:34 |
| 0 0.0984          | 0.000    |       |        |   |       |
| J_OS9             | JUNCTION | 0.00  | 11.20  | 0 | 00:42 |
| 0 0.439           | 0.000    |       |        |   |       |
| J1                | JUNCTION | 0.00  | 0.81   | 0 | 01:34 |
| 0 0.0723          | 0.000    |       |        |   |       |
| J2                | JUNCTION | 0.00  | 0.90   | 0 | 02:46 |
| 0 0.0981          | 0.000    |       |        |   |       |

*SWMM Model Proposed – 5 Year*

|         |        |          |       |        |   |       |
|---------|--------|----------|-------|--------|---|-------|
| J3      |        | JUNCTION | 0.00  | 92.15  | 0 | 00:39 |
| 0       | 2.44   | 0.000    |       |        |   |       |
| J4      |        | JUNCTION | 0.00  | 104.91 | 0 | 00:43 |
| 0       | 2.91   | 0.000    |       |        |   |       |
| LC_A10  |        | JUNCTION | 31.12 | 31.12  | 0 | 00:30 |
| 0.516   | 0.516  | 0.000    |       |        |   |       |
| LC_A20  |        | JUNCTION | 22.05 | 22.05  | 0 | 00:33 |
| 0.626   | 0.626  | 0.000    |       |        |   |       |
| LC_A25  |        | JUNCTION | 16.06 | 16.06  | 0 | 00:32 |
| 0.451   | 0.451  | 0.000    |       |        |   |       |
| LC_A30  |        | JUNCTION | 50.19 | 50.19  | 0 | 00:31 |
| 0.952   | 0.952  | 0.000    |       |        |   |       |
| LC_B10  |        | JUNCTION | 1.17  | 1.17   | 0 | 00:58 |
| 0.0648  | 0.0648 | 0.000    |       |        |   |       |
| LC_B100 |        | JUNCTION | 0.25  | 0.25   | 0 | 00:57 |
| 0.0157  | 0.0157 | 0.000    |       |        |   |       |
| LC_B110 |        | JUNCTION | 14.08 | 14.08  | 0 | 00:33 |
| 0.416   | 0.416  | 0.000    |       |        |   |       |
| LC_B120 |        | JUNCTION | 19.04 | 19.04  | 0 | 00:36 |
| 0.644   | 0.644  | 0.000    |       |        |   |       |
| LC_B130 |        | JUNCTION | 12.69 | 12.69  | 0 | 00:41 |
| 0.566   | 0.566  | 0.000    |       |        |   |       |
| LC_B140 |        | JUNCTION | 11.79 | 11.79  | 0 | 00:32 |
| 0.311   | 0.311  | 0.000    |       |        |   |       |
| LC_B150 |        | JUNCTION | 13.18 | 13.18  | 0 | 00:32 |
| 0.361   | 0.361  | 0.000    |       |        |   |       |
| LC_B160 |        | JUNCTION | 30.50 | 30.50  | 0 | 00:31 |
| 0.614   | 0.614  | 0.000    |       |        |   |       |
| LC_B170 |        | JUNCTION | 1.71  | 1.71   | 0 | 00:35 |
| 0.0632  | 0.0632 | 0.000    |       |        |   |       |
| LC_B180 |        | JUNCTION | 31.29 | 31.29  | 0 | 00:31 |
| 0.645   | 0.645  | 0.000    |       |        |   |       |
| LC_B190 |        | JUNCTION | 41.78 | 41.78  | 0 | 00:30 |
| 0.696   | 0.696  | 0.000    |       |        |   |       |
| LC_B20  |        | JUNCTION | 8.45  | 8.45   | 0 | 00:45 |
| 0.389   | 0.389  | 0.000    |       |        |   |       |
| LC_B30  |        | JUNCTION | 20.33 | 20.33  | 0 | 00:33 |
| 0.464   | 0.464  | 0.000    |       |        |   |       |
| LC_B40  |        | JUNCTION | 66.69 | 66.69  | 0 | 00:34 |
| 1.62    | 1.62   | 0.000    |       |        |   |       |
| LC_B50  |        | JUNCTION | 40.74 | 40.74  | 0 | 00:33 |
| 0.974   | 0.974  | 0.000    |       |        |   |       |
| LC_B60  |        | JUNCTION | 2.14  | 2.14   | 0 | 00:48 |
| 0.0928  | 0.0928 | 0.000    |       |        |   |       |
| LC_B70  |        | JUNCTION | 34.93 | 34.93  | 0 | 00:38 |
| 1.26    | 1.26   | 0.000    |       |        |   |       |
| LC_B80  |        | JUNCTION | 24.60 | 24.60  | 0 | 00:41 |
| 0.985   | 0.985  | 0.000    |       |        |   |       |
| LC_B90  |        | JUNCTION | 29.93 | 29.93  | 0 | 00:41 |
| 1.2     | 1.2    | 0.000    |       |        |   |       |
| LC_C10  |        | JUNCTION | 20.27 | 20.27  | 0 | 00:33 |
| 0.519   | 0.519  | 0.000    |       |        |   |       |
| LC_D10  |        | JUNCTION | 11.34 | 11.34  | 0 | 00:36 |
| 0.315   | 0.315  | 0.000    |       |        |   |       |

*SWMM Model Proposed – 5 Year*

|            |         |          |       |        |   |       |
|------------|---------|----------|-------|--------|---|-------|
| LC_F10     |         | JUNCTION | 48.28 | 48.28  | 0 | 00:32 |
| 1.06       | 1.06    | 0.000    |       |        |   |       |
| LC_F20     |         | JUNCTION | 1.65  | 1.65   | 0 | 00:42 |
| 0.0751     | 0.0751  | 0.000    |       |        |   |       |
| LC_G10     |         | JUNCTION | 18.87 | 18.87  | 0 | 00:35 |
| 0.581      | 0.581   | 0.000    |       |        |   |       |
| LC_H10     |         | JUNCTION | 5.22  | 5.22   | 0 | 00:32 |
| 0.14       | 0.14    | 0.000    |       |        |   |       |
| LC_I10     |         | JUNCTION | 25.93 | 25.93  | 0 | 00:33 |
| 0.652      | 0.652   | 0.000    |       |        |   |       |
| LC_I20     |         | JUNCTION | 35.85 | 35.85  | 0 | 00:34 |
| 0.972      | 0.972   | 0.000    |       |        |   |       |
| OS_B1      |         | JUNCTION | 0.08  | 0.08   | 0 | 00:32 |
| 0.00161    | 0.00161 | 0.000    |       |        |   |       |
| OS_B2      |         | JUNCTION | 0.59  | 0.59   | 0 | 00:33 |
| 0.0109     | 0.0109  | 0.000    |       |        |   |       |
| OS1        |         | JUNCTION | 9.17  | 9.17   | 0 | 00:51 |
| 0.378      | 0.378   | 0.000    |       |        |   |       |
| OS10       |         | JUNCTION | 0.95  | 0.95   | 0 | 00:36 |
| 0.037      | 0.037   | 0.000    |       |        |   |       |
| OS10_In    |         | JUNCTION | 0.00  | 2.58   | 0 | 00:57 |
| 0          | 0.126   | 0.000    |       |        |   |       |
| OS2        |         | JUNCTION | 6.27  | 6.27   | 0 | 00:48 |
| 0.322      | 0.322   | 0.000    |       |        |   |       |
| OS3        |         | JUNCTION | 83.24 | 83.24  | 0 | 01:22 |
| 4.31       | 4.31    | 0.000    |       |        |   |       |
| OS4        |         | JUNCTION | 1.62  | 1.62   | 0 | 00:36 |
| 0.0371     | 0.0371  | 0.000    |       |        |   |       |
| OS5        |         | JUNCTION | 0.15  | 0.15   | 0 | 00:36 |
| 0.00551    | 0.00551 | 0.000    |       |        |   |       |
| OS6        |         | JUNCTION | 0.43  | 0.43   | 0 | 00:45 |
| 0.0193     | 0.0193  | 0.000    |       |        |   |       |
| OS7        |         | JUNCTION | 1.84  | 1.84   | 0 | 00:45 |
| 0.087      | 0.087   | 0.000    |       |        |   |       |
| OS8        |         | JUNCTION | 4.08  | 4.08   | 0 | 00:34 |
| 0.0985     | 0.0985  | 0.000    |       |        |   |       |
| OS9        |         | JUNCTION | 3.80  | 3.80   | 0 | 00:56 |
| 0.186      | 0.186   | 0.000    |       |        |   |       |
| Out_Dr_A10 |         | JUNCTION | 0.00  | 31.27  | 0 | 00:35 |
| 0          | 0.925   | 0.000    |       |        |   |       |
| Out_Dr_B10 |         | JUNCTION | 0.00  | 41.08  | 0 | 00:37 |
| 0          | 1.19    | 0.000    |       |        |   |       |
| Out_LC_A10 |         | JUNCTION | 0.00  | 93.44  | 0 | 00:36 |
| 0          | 2.33    | 0.000    |       |        |   |       |
| Out_LC_A25 |         | JUNCTION | 0.00  | 16.06  | 0 | 00:32 |
| 0          | 0.451   | 0.000    |       |        |   |       |
| Out_LC_B   |         | JUNCTION | 0.00  | 385.82 | 0 | 01:16 |
| 0          | 19.9    | 0.000    |       |        |   |       |
| Out_LC_C   |         | JUNCTION | 0.00  | 20.27  | 0 | 00:33 |
| 0          | 0.519   | -0.000   |       |        |   |       |
| Out_LC_E   |         | JUNCTION | 0.00  | 11.34  | 0 | 00:36 |
| 0          | 0.315   | 0.000    |       |        |   |       |
| Out_LC_F   |         | JUNCTION | 0.00  | 48.28  | 0 | 00:32 |
| 0          | 1.06    | 0.000    |       |        |   |       |



*SWMM Model Proposed – 5 Year*

|             |       |          |       |        |   |       |
|-------------|-------|----------|-------|--------|---|-------|
| Out_LC_G10  |       | JUNCTION | 0.00  | 18.87  | 0 | 00:35 |
| 0           | 0.581 | 0.000    |       |        |   |       |
| Out_LC_H10  |       | JUNCTION | 0.00  | 5.22   | 0 | 00:32 |
| 0           | 0.14  | 0.000    |       |        |   |       |
| Out_UEC_A   |       | JUNCTION | 0.00  | 32.48  | 0 | 00:37 |
| 0           | 1.5   | 0.000    |       |        |   |       |
| Out_UEC_B   |       | JUNCTION | 0.00  | 128.36 | 0 | 00:36 |
| 0           | 4.03  | 0.000    |       |        |   |       |
| Out_UEC_C10 |       | JUNCTION | 0.00  | 20.77  | 0 | 00:36 |
| 0           | 0.606 | 0.000    |       |        |   |       |
| Out_UEC_D10 |       | JUNCTION | 0.00  | 9.12   | 0 | 00:32 |
| 0           | 0.222 | 0.000    |       |        |   |       |
| UEC_A10     |       | JUNCTION | 32.34 | 32.34  | 0 | 00:36 |
| 0.987       | 0.987 | 0.000    |       |        |   |       |
| UEC_A20     |       | JUNCTION | 8.92  | 8.92   | 0 | 00:32 |
| 0.252       | 0.252 | 0.000    |       |        |   |       |
| UEC_B10     |       | JUNCTION | 24.45 | 24.45  | 0 | 00:33 |
| 0.662       | 0.662 | 0.000    |       |        |   |       |
| UEC_B20     |       | JUNCTION | 30.59 | 30.59  | 0 | 00:32 |
| 0.743       | 0.743 | 0.000    |       |        |   |       |
| UEC_B30     |       | JUNCTION | 20.75 | 20.75  | 0 | 00:30 |
| 0.407       | 0.407 | 0.000    |       |        |   |       |
| UEC_B40     |       | JUNCTION | 4.99  | 4.99   | 0 | 00:30 |
| 0.104       | 0.104 | 0.000    |       |        |   |       |
| UEC_C10     |       | JUNCTION | 12.08 | 12.08  | 0 | 00:34 |
| 0.383       | 0.383 | 0.000    |       |        |   |       |
| UEC_D10     |       | JUNCTION | 9.12  | 9.12   | 0 | 00:32 |
| 0.222       | 0.222 | 0.000    |       |        |   |       |
| Out.Dr      |       | OUTFALL  | 0.00  | 41.01  | 0 | 00:38 |
| 0           | 1.2   | 0.000    |       |        |   |       |
| Out_C.D     |       | OUTFALL  | 0.00  | 31.38  | 0 | 00:36 |
| 0           | 0.836 | 0.000    |       |        |   |       |
| Out_LC.B.F  |       | OUTFALL  | 0.00  | 402.74 | 0 | 01:19 |
| 0           | 21    | 0.000    |       |        |   |       |
| Out_LC.G.H  |       | OUTFALL  | 0.00  | 23.89  | 0 | 00:38 |
| 0           | 0.725 | 0.000    |       |        |   |       |
| Out_LC_I    |       | OUTFALL  | 0.00  | 59.67  | 0 | 00:37 |
| 0           | 1.63  | 0.000    |       |        |   |       |
| UEC_Out     |       | OUTFALL  | 0.00  | 122.64 | 0 | 00:43 |
| 0           | 4.07  | 0.000    |       |        |   |       |

\*\*\*\*\*  
Node Flooding Summary  
\*\*\*\*\*

No nodes were flooded.

\*\*\*\*\*  
Outfall Loading Summary  
\*\*\*\*\*

-----

*SWMM Model Proposed – 5 Year*

| Outfall Node | Flow Freq Pcnt | Avg Flow CFS | Max Flow CFS | Total Volume 10 <sup>6</sup> gal |
|--------------|----------------|--------------|--------------|----------------------------------|
| Out.Dr       | 28.07          | 6.59         | 41.01        | 1.196                            |
| Out_C.D      | 25.35          | 5.10         | 31.38        | 0.836                            |
| Out_LC.B.F   | 98.78          | 32.89        | 402.74       | 20.998                           |
| Out_LC.G.H   | 25.36          | 4.42         | 23.89        | 0.725                            |
| Out_LC_I     | 33.67          | 7.49         | 59.67        | 1.630                            |
| UEC_Out      | 98.50          | 6.40         | 122.64       | 4.075                            |
| System       | 51.62          | 62.90        | 563.17       | 29.460                           |

\*\*\*\*\*  
 Link Flow Summary  
 \*\*\*\*\*

| Link                     | Type    | Maximum  Flow  CFS | Time of Max Occurrence days hr:min | Maximum  Veloc  ft/sec | Max/Full Flow |
|--------------------------|---------|--------------------|------------------------------------|------------------------|---------------|
| Ch.Dr_A.Main10<br>0.34   | CONDUIT | 31.00              | 0 00:38                            | 3.56                   | 0.14          |
| Ch.LC_A.Main10<br>0.11   | CONDUIT | 68.55              | 0 00:37                            | 4.43                   | 0.02          |
| Ch.LC_A.Side10<br>0.04   | CONDUIT | 1.78               | 0 01:00                            | 1.28                   | 0.00          |
| Ch.LC_A.Side11<br>0.03   | CONDUIT | 2.58               | 0 00:58                            | 2.69                   | 0.00          |
| Ch.LC_B.30<br>0.35       | CONDUIT | 85.76              | 0 00:38                            | 4.28                   | 0.14          |
| Ch.LC_B.Side.120<br>0.22 | CONDUIT | 24.67              | 0 00:38                            | 4.72                   | 0.06          |
| Ch.LC_B.Side.121<br>0.44 | CONDUIT | 33.82              | 0 00:55                            | 1.30                   | 0.21          |
| Ch.LC_B.Side.140<br>0.05 | CONDUIT | 1.51               | 0 00:55                            | 1.34                   | 0.01          |
| Ch.Lc_B.Side.150<br>0.14 | CONDUIT | 12.11              | 0 00:37                            | 3.80                   | 0.03          |
| Ch.LC_B.Side.160<br>0.29 | CONDUIT | 30.26              | 0 00:35                            | 4.37                   | 0.10          |
| Ch.LC_B.Side.90<br>0.31  | CONDUIT | 36.84              | 0 00:36                            | 4.91                   | 0.12          |
| Ch.LC_B.Side.91<br>0.37  | CONDUIT | 66.23              | 0 00:37                            | 6.87                   | 0.15          |
| Ch.LC_B.Side122<br>0.41  | CONDUIT | 57.95              | 0 00:36                            | 5.37                   | 0.19          |

*SWMM Model Proposed – 5 Year*

|                         |         |        |   |       |      |      |
|-------------------------|---------|--------|---|-------|------|------|
| Ch.LC_B.Side130<br>0.11 | CONDUIT | 12.59  | 0 | 00:46 | 3.56 | 0.02 |
| Ch.LC_B.Side20<br>0.05  | CONDUIT | 29.52  | 0 | 01:09 | 1.42 | 0.01 |
| Ch.LC_B.Side50<br>0.05  | CONDUIT | 8.15   | 0 | 01:10 | 1.16 | 0.01 |
| Ch.LC_B.Side10<br>0.11  | CONDUIT | 36.69  | 0 | 01:11 | 2.46 | 0.02 |
| Ch.LC_D.Main10<br>0.29  | CONDUIT | 20.15  | 0 | 00:34 | 2.85 | 0.10 |
| Ch.LC_D.Main11<br>0.19  | CONDUIT | 11.34  | 0 | 00:36 | 2.67 | 0.05 |
| Ch.LC_G.Main10<br>0.37  | CONDUIT | 18.87  | 0 | 00:35 | 1.95 | 0.16 |
| Ch.LC_H.Main10<br>0.15  | CONDUIT | 5.21   | 0 | 00:33 | 1.58 | 0.03 |
| Ch.LC_I.Main1<br>0.36   | CONDUIT | 34.91  | 0 | 00:39 | 3.76 | 0.15 |
| Ch.OS_B1<br>0.01        | CONDUIT | 0.07   | 0 | 00:41 | 0.45 | 0.00 |
| Ch.OS_B2<br>0.02        | CONDUIT | 0.45   | 0 | 00:48 | 1.09 | 0.00 |
| Ch.OS2<br>0.08          | CONDUIT | 5.97   | 0 | 01:04 | 2.46 | 0.01 |
| Ch.UEC_A.Main10<br>0.03 | CONDUIT | 8.16   | 0 | 01:27 | 0.81 | 0.00 |
| Ch.UEC_A.Main11<br>0.30 | CONDUIT | 32.46  | 0 | 00:38 | 4.32 | 0.11 |
| Ch.UEC_A.Main20<br>0.13 | CONDUIT | 8.84   | 0 | 00:34 | 3.09 | 0.02 |
| Ch.UEC_B<br>0.13        | CONDUIT | 122.64 | 0 | 00:43 | 3.70 | 0.03 |
| Ch.UEC_B.Main10<br>0.05 | CONDUIT | 23.37  | 0 | 00:37 | 3.39 | 0.01 |
| Ch.UEC_B.Side10<br>0.33 | CONDUIT | 56.08  | 0 | 00:36 | 6.78 | 0.12 |
| Ch.UEC_B.Side20<br>0.29 | CONDUIT | 49.02  | 0 | 00:36 | 7.00 | 0.10 |
| Ch.UEC_C.Main10<br>0.25 | CONDUIT | 20.65  | 0 | 00:39 | 3.43 | 0.08 |
| Ch.UEC_D.Main10<br>0.15 | CONDUIT | 8.84   | 0 | 00:37 | 2.65 | 0.03 |
| Ch_1<br>0.01            | CONDUIT | 0.74   | 0 | 02:56 | 0.54 | 0.00 |
| Ch_2<br>0.01            | CONDUIT | 0.86   | 0 | 03:21 | 0.52 | 0.00 |
| Ch_3<br>0.12            | CONDUIT | 90.25  | 0 | 00:43 | 2.85 | 0.02 |
| Ch_4<br>0.13            | CONDUIT | 102.82 | 0 | 00:47 | 2.99 | 0.03 |
| Ch_LC_A10<br>0.05       | CONDUIT | 92.15  | 0 | 00:39 | 4.67 | 0.00 |
| Ch_Main_1<br>0.40       | CONDUIT | 315.90 | 0 | 01:17 | 5.27 | 0.09 |

*SWMM Model Proposed – 5 Year*

|                 |         |        |   |       |       |      |
|-----------------|---------|--------|---|-------|-------|------|
| Ch_Main_2       | CONDUIT | 272.95 | 0 | 01:19 | 3.91  | 0.10 |
| 0.41            |         |        |   |       |       |      |
| Ch_Main_3       | CONDUIT | 261.44 | 0 | 01:06 | 5.82  | 0.08 |
| 0.39            |         |        |   |       |       |      |
| Ch_Main_4       | CONDUIT | 222.61 | 0 | 01:04 | 4.96  | 0.08 |
| 0.39            |         |        |   |       |       |      |
| Ch_Main_5       | CONDUIT | 140.64 | 0 | 01:15 | 4.03  | 0.06 |
| 0.34            |         |        |   |       |       |      |
| Ch_Main_6       | CONDUIT | 140.78 | 0 | 01:09 | 2.76  | 0.04 |
| 0.16            |         |        |   |       |       |      |
| Ch_OS10         | CONDUIT | 0.95   | 0 | 00:36 | 1.36  | 0.00 |
| 0.02            |         |        |   |       |       |      |
| Ch_OS6          | CONDUIT | 0.36   | 0 | 01:16 | 1.36  | 0.00 |
| 0.02            |         |        |   |       |       |      |
| Ch_Upper.Main_1 | CONDUIT | 32.97  | 0 | 01:07 | 3.44  | 0.03 |
| 0.28            |         |        |   |       |       |      |
| Ch_Upper.Main_2 | CONDUIT | 6.19   | 0 | 01:13 | 1.64  | 0.01 |
| 0.17            |         |        |   |       |       |      |
| Culv_LC_A10     | CONDUIT | 93.44  | 0 | 00:36 | 14.45 | 0.08 |
| 0.13            |         |        |   |       |       |      |
| Culv_LC_A20     | CONDUIT | 16.06  | 0 | 00:32 | 10.08 | 0.11 |
| 0.18            |         |        |   |       |       |      |
| Culv_OS1        | CONDUIT | 9.17   | 0 | 00:51 | 6.10  | 0.03 |
| 0.12            |         |        |   |       |       |      |
| Culv_OS2        | CONDUIT | 6.27   | 0 | 00:48 | 5.33  | 0.07 |
| 0.18            |         |        |   |       |       |      |
| Culv_OS4        | CONDUIT | 1.62   | 0 | 00:36 | 1.44  | 0.02 |
| 0.11            |         |        |   |       |       |      |
| Culv_OS6        | CONDUIT | 0.43   | 0 | 00:45 | 3.13  | 0.00 |
| 0.03            |         |        |   |       |       |      |
| Culv_OS7        | CONDUIT | 1.84   | 0 | 00:46 | 3.19  | 0.03 |
| 0.11            |         |        |   |       |       |      |
| Culv_OS8        | CONDUIT | 4.07   | 0 | 00:34 | 2.57  | 0.06 |
| 0.16            |         |        |   |       |       |      |
| Culv_OS9        | CONDUIT | 3.80   | 0 | 00:56 | 3.08  | 0.02 |
| 0.11            |         |        |   |       |       |      |
| Dummy_Dr_A10    | DUMMY   | 31.27  | 0 | 00:35 |       |      |
| Dummy_Dr_B10    | DUMMY   | 11.07  | 0 | 00:31 |       |      |
| Dummy_LC_A10    | DUMMY   | 31.12  | 0 | 00:30 |       |      |
| Dummy_LC_A20    | DUMMY   | 22.05  | 0 | 00:33 |       |      |
| Dummy_LC_A25    | DUMMY   | 16.06  | 0 | 00:32 |       |      |
| Dummy_LC_A30    | DUMMY   | 50.19  | 0 | 00:31 |       |      |
| Dummy_LC_B10    | DUMMY   | 1.17   | 0 | 00:58 |       |      |
| Dummy_LC_B100   | DUMMY   | 0.25   | 0 | 00:57 |       |      |
| Dummy_LC_B110   | DUMMY   | 14.08  | 0 | 00:33 |       |      |
| Dummy_LC_B120   | DUMMY   | 19.04  | 0 | 00:36 |       |      |
| Dummy_LC_B130   | DUMMY   | 12.69  | 0 | 00:41 |       |      |
| Dummy_LC_B140   | DUMMY   | 11.79  | 0 | 00:32 |       |      |
| Dummy_LC_B150   | DUMMY   | 13.18  | 0 | 00:32 |       |      |
| Dummy_LC_B160   | DUMMY   | 30.50  | 0 | 00:31 |       |      |
| Dummy_LC_B170   | DUMMY   | 1.71   | 0 | 00:35 |       |      |
| Dummy_LC_B180   | DUMMY   | 31.29  | 0 | 00:31 |       |      |
| Dummy_LC_B190   | DUMMY   | 41.78  | 0 | 00:30 |       |      |
| Dummy_LC_B20    | DUMMY   | 8.45   | 0 | 00:45 |       |      |

*SWMM Model Proposed – 5 Year*

|               |         |        |   |       |      |      |
|---------------|---------|--------|---|-------|------|------|
| Dummy_LC_B30  | DUMMY   | 20.33  | 0 | 00:33 |      |      |
| Dummy_LC_B40  | DUMMY   | 66.69  | 0 | 00:34 |      |      |
| Dummy_LC_B50  | DUMMY   | 40.74  | 0 | 00:33 |      |      |
| Dummy_LC_B60  | DUMMY   | 2.14   | 0 | 00:48 |      |      |
| Dummy_LC_B70  | DUMMY   | 34.93  | 0 | 00:38 |      |      |
| Dummy_LC_B80  | DUMMY   | 24.60  | 0 | 00:41 |      |      |
| Dummy_LC_B90  | DUMMY   | 29.93  | 0 | 00:41 |      |      |
| Dummy_LC_C10  | DUMMY   | 20.27  | 0 | 00:33 |      |      |
| Dummy_LC_D10  | DUMMY   | 11.34  | 0 | 00:36 |      |      |
| Dummy_LC_F10  | DUMMY   | 48.28  | 0 | 00:32 |      |      |
| Dummy_LC_F20  | DUMMY   | 1.65   | 0 | 00:42 |      |      |
| Dummy_LC_G10  | DUMMY   | 18.87  | 0 | 00:35 |      |      |
| Dummy_LC_H10  | DUMMY   | 5.22   | 0 | 00:32 |      |      |
| Dummy_LC_I10  | DUMMY   | 25.93  | 0 | 00:33 |      |      |
| Dummy_LC_I20  | DUMMY   | 35.85  | 0 | 00:34 |      |      |
| Dummy_OS_B1   | DUMMY   | 0.08   | 0 | 00:32 |      |      |
| Dummy_OS_B2   | DUMMY   | 0.59   | 0 | 00:33 |      |      |
| Dummy_OS1     | DUMMY   | 9.17   | 0 | 00:51 |      |      |
| Dummy_OS10    | DUMMY   | 0.95   | 0 | 00:36 |      |      |
| Dummy_OS2     | DUMMY   | 6.27   | 0 | 00:48 |      |      |
| Dummy_OS3     | DUMMY   | 83.24  | 0 | 01:22 |      |      |
| Dummy_OS4     | DUMMY   | 1.62   | 0 | 00:36 |      |      |
| Dummy_OS5     | DUMMY   | 0.15   | 0 | 00:36 |      |      |
| Dummy_OS6     | DUMMY   | 0.43   | 0 | 00:45 |      |      |
| Dummy_OS7     | DUMMY   | 1.84   | 0 | 00:45 |      |      |
| Dummy_OS8     | DUMMY   | 4.08   | 0 | 00:34 |      |      |
| Dummy_OS9     | DUMMY   | 3.80   | 0 | 00:56 |      |      |
| Dummy_UEC_A10 | DUMMY   | 32.34  | 0 | 00:36 |      |      |
| Dummy_UEC_A20 | DUMMY   | 8.92   | 0 | 00:32 |      |      |
| Dummy_UEC_B   | DUMMY   | 24.45  | 0 | 00:33 |      |      |
| Dummy_UEC_B20 | DUMMY   | 30.59  | 0 | 00:32 |      |      |
| Dummy_UEC_B30 | DUMMY   | 20.75  | 0 | 00:30 |      |      |
| Dummy_UEC_B40 | DUMMY   | 4.99   | 0 | 00:30 |      |      |
| Dummy_UEC_C10 | DUMMY   | 12.08  | 0 | 00:34 |      |      |
| Dummy_UEC_D10 | DUMMY   | 9.12   | 0 | 00:32 |      |      |
| Over.Dr_B     | CONDUIT | 41.01  | 0 | 00:38 | 2.40 | 0.02 |
| 0.09          |         |        |   |       |      |      |
| Over.LC.G     | CONDUIT | 23.89  | 0 | 00:38 | 1.71 | 0.01 |
| 0.07          |         |        |   |       |      |      |
| Over.LC_B     | CONDUIT | 385.17 | 0 | 01:20 | 2.53 | 0.08 |
| 0.23          |         |        |   |       |      |      |
| Over.LC_D     | CONDUIT | 31.38  | 0 | 00:36 | 1.17 | 0.04 |
| 0.13          |         |        |   |       |      |      |
| Over.LC_F     | CONDUIT | 46.72  | 0 | 00:35 | 1.83 | 0.03 |
| 0.13          |         |        |   |       |      |      |
| Over_LC_A25   | CONDUIT | 15.82  | 0 | 00:36 | 2.21 | 0.15 |
| 0.32          |         |        |   |       |      |      |
| Over_OS4      | CONDUIT | 0.77   | 0 | 01:33 | 0.64 | 0.00 |
| 0.00          |         |        |   |       |      |      |
| Over_OS5      | CONDUIT | 0.08   | 0 | 03:35 | 0.00 | 0.00 |
| 0.00          |         |        |   |       |      |      |
| Over_OS8_1    | CONDUIT | 2.61   | 0 | 01:09 | 0.49 | 0.00 |
| 0.01          |         |        |   |       |      |      |

SWMM Model Proposed – 5 Year

|                       |         |       |   |       |       |      |
|-----------------------|---------|-------|---|-------|-------|------|
| Pipe.LC_A.20<br>0.29  | CONDUIT | 47.34 | 0 | 00:35 | 6.98  | 0.19 |
| Pipe.LC_B.110<br>0.27 | CONDUIT | 14.07 | 0 | 00:34 | 9.12  | 0.16 |
| Pipe.LC_B.120<br>0.26 | CONDUIT | 95.10 | 0 | 00:44 | 16.55 | 0.14 |
| Pipe.LC_B.40<br>0.29  | CONDUIT | 66.54 | 0 | 00:35 | 14.30 | 0.18 |
| Pipe.LC_B.70<br>0.32  | CONDUIT | 34.92 | 0 | 00:38 | 10.25 | 0.22 |
| Pipe.LC_B.80<br>0.28  | CONDUIT | 24.60 | 0 | 00:41 | 15.27 | 0.17 |
| Pipe.LC_F.10<br>0.37  | CONDUIT | 85.47 | 0 | 00:42 | 4.01  | 0.15 |
| Pipe.LC_I<br>0.31     | CONDUIT | 59.67 | 0 | 00:37 | 8.14  | 0.20 |
| Pipe.UEC_B.30<br>0.25 | CONDUIT | 20.74 | 0 | 00:30 | 14.81 | 0.14 |
| Pipe.UEC_B40<br>0.20  | CONDUIT | 4.98  | 0 | 00:30 | 5.11  | 0.08 |

\*\*\*\*\*  
Conduit Surcharge Summary  
\*\*\*\*\*

No conduits were surcharged.

Analysis begun on: Mon Dec 16 18:39:15 2024  
Analysis ended on: Mon Dec 16 18:39:16 2024  
Total elapsed time: 00:00:01

## SWMM Model Proposed – 100 Year

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.2 (Build 5.2.4)

---

WARNING 02: maximum depth increased for Node J.B\_Main.2

\*\*\*\*\*

Element Count

\*\*\*\*\*

Number of rain gages ..... 0  
 Number of subcatchments ... 0  
 Number of nodes ..... 136  
 Number of links ..... 130  
 Number of pollutants ..... 0  
 Number of land uses ..... 0

\*\*\*\*\*

Node Summary

\*\*\*\*\*

| External<br>Name | Type     | Invert<br>Elev. | Max.<br>Depth | Ponded<br>Area |
|------------------|----------|-----------------|---------------|----------------|
| DP_LC_I          | JUNCTION | 6254.57         | 6.00          | 0.0            |
| DP_LC_A20        | JUNCTION | 6370.00         | 6.00          | 0.0            |
| DP_LC_A30        | JUNCTION | 6377.95         | 6.00          | 0.0            |
| DP_LC_B110       | JUNCTION | 6284.29         | 3.00          | 0.0            |
| DP_LC_B120       | JUNCTION | 6286.76         | 6.00          | 0.0            |
| DP_LC_B130       | JUNCTION | 6336.08         | 3.00          | 0.0            |
| DP_LC_B140       | JUNCTION | 6376.76         | 2.00          | 0.0            |
| DP_LC_B150       | JUNCTION | 6338.57         | 2.00          | 0.0            |
| DP_LC_B160       | JUNCTION | 6318.55         | 2.00          | 0.0            |
| DP_LC_B170       | JUNCTION | 6403.16         | 2.00          | 0.0            |
| DP_LC_B180       | JUNCTION | 6350.67         | 2.00          | 0.0            |
| DP_LC_B190       | JUNCTION | 6339.17         | 2.00          | 0.0            |
| DP_LC_B20        | JUNCTION | 6221.82         | 5.00          | 0.0            |
| DP_LC_B30        | JUNCTION | 6241.12         | 5.00          | 0.0            |
| DP_LC_B40        | JUNCTION | 6268.03         | 5.00          | 0.0            |
| DP_LC_B50        | JUNCTION | 6271.98         | 5.00          | 0.0            |
| DP_LC_B70        | JUNCTION | 6249.24         | 4.00          | 0.0            |
| DP_LC_B80        | JUNCTION | 6249.80         | 3.00          | 0.0            |
| DP_LC_B90        | JUNCTION | 6270.44         | 2.00          | 0.0            |
| DP_LC_C.D        | JUNCTION | 6244.97         | 2.00          | 0.0            |
| DP_LC_F20        | JUNCTION | 6229.95         | 3.00          | 0.0            |
| DP_LC_I20        | JUNCTION | 6276.74         | 2.00          | 0.0            |
| DP_OS_B1         | JUNCTION | 6293.06         | 2.00          | 0.0            |
| DP_OS_B2         | JUNCTION | 6289.70         | 2.00          | 0.0            |
| DP_OS1           | JUNCTION | 6282.45         | 3.00          | 0.0            |
| DP_OS10          | JUNCTION | 6373.07         | 3.00          | 0.0            |
| DP_OS2           | JUNCTION | 6313.76         | 2.50          | 0.0            |
| DP_OS3           | JUNCTION | 6290.51         | 5.00          | 0.0            |

*SWMM Model Proposed – 100 Year*

|                   |          |         |       |     |
|-------------------|----------|---------|-------|-----|
| DP_OS4            | JUNCTION | 6420.09 | 3.50  | 0.0 |
| DP_OS5            | JUNCTION | 6440.72 | 5.00  | 0.0 |
| DP_OS6            | JUNCTION | 6428.06 | 3.00  | 0.0 |
| DP_OS7            | JUNCTION | 6392.28 | 2.00  | 0.0 |
| DP_OS8            | JUNCTION | 6393.20 | 2.50  | 0.0 |
| DP_OS9            | JUNCTION | 6359.19 | 3.00  | 0.0 |
| DP_UEC_A20        | JUNCTION | 6377.69 | 2.00  | 0.0 |
| DP_UEC_B10        | JUNCTION | 6307.98 | 2.00  | 0.0 |
| DP_UEC_B20        | JUNCTION | 6314.12 | 2.00  | 0.0 |
| DP_UEC_B30        | JUNCTION | 6367.93 | 3.00  | 0.0 |
| DP_UEC_B40        | JUNCTION | 6362.77 | 3.00  | 0.0 |
| Dr_A10            | JUNCTION | 6347.11 | 0.00  | 0.0 |
| Dr_B10            | JUNCTION | 6329.34 | 0.00  | 0.0 |
| J.B_Main.1        | JUNCTION | 6219.15 | 5.50  | 0.0 |
| J.B_Main.2        | JUNCTION | 6238.37 | 6.00  | 0.0 |
| J.B_Main.3        | JUNCTION | 6258.52 | 6.00  | 0.0 |
| J.B_Main.4        | JUNCTION | 6274.10 | 6.00  | 0.0 |
| J.B_Main.5        | JUNCTION | 6287.43 | 6.00  | 0.0 |
| J.B_Side.120      | JUNCTION | 6287.54 | 22.07 | 0.0 |
| J.B_Upper.Main_.2 | JUNCTION | 6250.19 | 5.00  | 0.0 |
| J.B_Upper.Main_1  | JUNCTION | 6246.00 | 5.00  | 0.0 |
| J.UEC_B.1         | JUNCTION | 6361.65 | 5.00  | 0.0 |
| J_LC.G.H          | JUNCTION | 6212.79 | 2.00  | 0.0 |
| J_LC_A10          | JUNCTION | 6346.58 | 10.00 | 0.0 |
| J_LC_A25          | JUNCTION | 6320.63 | 3.00  | 0.0 |
| J_OS1             | JUNCTION | 6277.94 | 5.00  | 0.0 |
| J_OS2             | JUNCTION | 6310.41 | 3.00  | 0.0 |
| J_OS4             | JUNCTION | 6420.00 | 5.00  | 0.0 |
| J_OS6             | JUNCTION | 6425.61 | 5.00  | 0.0 |
| J_OS7             | JUNCTION | 6388.69 | 3.00  | 0.0 |
| J_OS8             | JUNCTION | 6391.98 | 2.50  | 0.0 |
| J_OS9             | JUNCTION | 6357.73 | 3.00  | 0.0 |
| J1                | JUNCTION | 6355.74 | 5.00  | 0.0 |
| J2                | JUNCTION | 6323.35 | 5.00  | 0.0 |
| J3                | JUNCTION | 6305.72 | 10.00 | 0.0 |
| J4                | JUNCTION | 6298.21 | 5.00  | 0.0 |
| LC_A10            | JUNCTION | 6373.50 | 0.00  | 0.0 |
| LC_A20            | JUNCTION | 6394.79 | 0.00  | 0.0 |
| LC_A25            | JUNCTION | 6358.75 | 0.00  | 0.0 |
| LC_A30            | JUNCTION | 6377.99 | 0.00  | 0.0 |
| LC_B10            | JUNCTION | 6227.60 | 0.00  | 0.0 |
| LC_B100           | JUNCTION | 6278.59 | 0.00  | 0.0 |
| LC_B110           | JUNCTION | 6305.11 | 0.00  | 0.0 |
| LC_B120           | JUNCTION | 6328.08 | 0.00  | 0.0 |
| LC_B130           | JUNCTION | 6376.10 | 0.00  | 0.0 |
| LC_B140           | JUNCTION | 6390.52 | 0.00  | 0.0 |
| LC_B150           | JUNCTION | 6364.46 | 0.00  | 0.0 |
| LC_B160           | JUNCTION | 6354.39 | 0.00  | 0.0 |
| LC_B170           | JUNCTION | 6416.30 | 0.00  | 0.0 |
| LC_B180           | JUNCTION | 6366.21 | 0.00  | 0.0 |
| LC_B190           | JUNCTION | 6345.00 | 0.00  | 0.0 |
| LC_B20            | JUNCTION | 6256.91 | 0.00  | 0.0 |
| LC_B30            | JUNCTION | 6277.65 | 0.00  | 0.0 |
| LC_B40            | JUNCTION | 6309.88 | 0.00  | 0.0 |



*SWMM Model Proposed – 100 Year*

|             |          |         |       |     |
|-------------|----------|---------|-------|-----|
| LC_B50      | JUNCTION | 6278.66 | 0.00  | 0.0 |
| LC_B60      | JUNCTION | 6259.78 | 0.00  | 0.0 |
| LC_B70      | JUNCTION | 6284.81 | 0.00  | 0.0 |
| LC_B80      | JUNCTION | 6318.25 | 0.00  | 0.0 |
| LC_B90      | JUNCTION | 6343.74 | 0.00  | 0.0 |
| LC_C10      | JUNCTION | 6267.21 | 0.00  | 0.0 |
| LC_D10      | JUNCTION | 6248.16 | 0.00  | 0.0 |
| LC_F10      | JUNCTION | 6246.12 | 0.00  | 0.0 |
| LC_F20      | JUNCTION | 6250.36 | 0.00  | 0.0 |
| LC_G10      | JUNCTION | 6234.42 | 0.00  | 0.0 |
| LC_H10      | JUNCTION | 6237.87 | 0.00  | 0.0 |
| LC_I10      | JUNCTION | 6269.94 | 12.56 | 0.0 |
| LC_I20      | JUNCTION | 6313.14 | 0.00  | 0.0 |
| OS_B1       | JUNCTION | 6309.16 | 0.00  | 0.0 |
| OS_B2       | JUNCTION | 6309.56 | 0.00  | 0.0 |
| OS1         | JUNCTION | 6349.15 | 0.00  | 0.0 |
| OS10        | JUNCTION | 6392.72 | 0.00  | 0.0 |
| OS10_In     | JUNCTION | 6372.34 | 3.00  | 0.0 |
| OS2         | JUNCTION | 6342.30 | 0.00  | 0.0 |
| OS3         | JUNCTION | 6453.31 | 0.00  | 0.0 |
| OS4         | JUNCTION | 6462.88 | 0.00  | 0.0 |
| OS5         | JUNCTION | 6448.20 | 0.00  | 0.0 |
| OS6         | JUNCTION | 6428.17 | 0.00  | 0.0 |
| OS7         | JUNCTION | 6416.17 | 0.00  | 0.0 |
| OS8         | JUNCTION | 6415.01 | 0.00  | 0.0 |
| OS9         | JUNCTION | 6429.66 | 0.00  | 0.0 |
| Out_Dr_A10  | JUNCTION | 6327.48 | 2.00  | 0.0 |
| Out_Dr_B10  | JUNCTION | 6315.89 | 2.00  | 0.0 |
| Out_LC_A10  | JUNCTION | 6349.20 | 8.00  | 0.0 |
| Out_LC_A25  | JUNCTION | 6322.30 | 3.00  | 0.0 |
| Out_LC_B    | JUNCTION | 6214.77 | 5.00  | 0.0 |
| Out_LC_C    | JUNCTION | 6249.92 | 5.30  | 0.0 |
| Out_LC_E    | JUNCTION | 6245.81 | 2.00  | 0.0 |
| Out_LC_F    | JUNCTION | 6208.99 | 2.00  | 0.0 |
| Out_LC_G10  | JUNCTION | 6212.98 | 2.00  | 0.0 |
| Out_LC_H10  | JUNCTION | 6213.78 | 2.00  | 0.0 |
| Out_UEC_A   | JUNCTION | 6318.87 | 2.00  | 0.0 |
| Out_UEC_B   | JUNCTION | 6302.81 | 5.00  | 0.0 |
| Out_UEC_C10 | JUNCTION | 6327.09 | 2.00  | 0.0 |
| Out_UEC_D10 | JUNCTION | 6344.99 | 2.00  | 0.0 |
| UEC_A10     | JUNCTION | 6349.56 | 0.00  | 0.0 |
| UEC_A20     | JUNCTION | 6402.62 | 0.00  | 0.0 |
| UEC_B10     | JUNCTION | 6351.73 | 3.12  | 0.0 |
| UEC_B20     | JUNCTION | 6362.49 | 0.00  | 0.0 |
| UEC_B30     | JUNCTION | 6398.18 | 0.00  | 0.0 |
| UEC_B40     | JUNCTION | 6375.31 | 0.00  | 0.0 |
| UEC_C10     | JUNCTION | 6357.45 | 0.00  | 0.0 |
| UEC_D10     | JUNCTION | 6349.03 | 0.00  | 0.0 |
| Out.Dr      | OUTFALL  | 6303.54 | 2.00  | 0.0 |
| Out_C.D     | OUTFALL  | 6244.40 | 2.00  | 0.0 |
| Out_LC.B.F  | OUTFALL  | 6201.46 | 2.00  | 0.0 |
| Out_LC.G.H  | OUTFALL  | 6202.14 | 2.00  | 0.0 |
| Out_LC_I    | OUTFALL  | 6254.31 | 6.00  | 0.0 |
| UEC_Out     | OUTFALL  | 6278.95 | 5.00  | 0.0 |

SWMM Model Proposed – 100 Year

\*\*\*\*\*  
 Link Summary  
 \*\*\*\*\*

| Name             | From Node    | To Node      | Type    |
|------------------|--------------|--------------|---------|
| Length           | %Slope       | Roughness    |         |
| Ch.Dr_A.Main10   | Out_Dr_A10   | Out_Dr_B10   | CONDUIT |
| 927.5            | 1.2497       | 0.0320       |         |
| Ch.LC_A.Main10   | DP_LC_A20    | Out_LC_A10   | CONDUIT |
| 987.0            | 2.1077       | 0.0320       |         |
| Ch.LC_A.Side10   | J_OS7        | OS10_In      | CONDUIT |
| 1200.9           | 1.3615       | 0.0350       |         |
| Ch.LC_A.Side11   | OS10_In      | Out_LC_A10   | CONDUIT |
| 231.0            | 10.0662      | 0.0350       |         |
| Ch.LC_B.30       | DP_LC_B30    | DP_LC_F20    | CONDUIT |
| 1089.3           | 1.0255       | 0.0320       |         |
| Ch.LC_B.Side.120 | DP_LC_B150   | J.B_Side.120 | CONDUIT |
| 1404.9           | 3.6348       | 0.0320       |         |
| Ch.LC_B.Side.121 | J.B_Side.120 | DP_LC_B120   | CONDUIT |
| 1109.0           | 0.0710       | 0.0320       |         |
| Ch.LC_B.Side.140 | DP_LC_B170   | DP_LC_B140   | CONDUIT |
| 1649.8           | 1.6009       | 0.0320       |         |
| Ch.Lc_B.Side.150 | DP_LC_B140   | DP_LC_B150   | CONDUIT |
| 947.2            | 4.0342       | 0.0320       |         |
| Ch.LC_B.Side.160 | DP_LC_B180   | DP_LC_B160   | CONDUIT |
| 1415.2           | 2.2698       | 0.0320       |         |
| Ch.LC_B.Side.90  | DP_LC_B190   | DP_LC_B90    | CONDUIT |
| 2996.6           | 2.2943       | 0.0320       |         |
| Ch.LC_B.Side.91  | DP_LC_B90    | J.B_Main.3   | CONDUIT |
| 274.4            | 4.3486       | 0.0320       |         |
| Ch.LC_B.Side122  | DP_LC_B160   | DP_LC_B120   | CONDUIT |
| 1382.5           | 2.3006       | 0.0320       |         |
| Ch.LC_B.Side130  | DP_LC_B130   | J.B_Side.120 | CONDUIT |
| 1544.9           | 3.1432       | 0.0320       |         |
| Ch.LC_B.Side20   | DP_LC_B50    | DP_LC_B20    | CONDUIT |
| 3203.8           | 1.5660       | 0.0320       |         |
| Ch.LC_B.Side50   | J_OS1        | DP_LC_B50    | CONDUIT |
| 1722.7           | 0.3457       | 0.0320       |         |
| Ch.LC_B_Side10   | DP_LC_B20    | Out_LC_B     | CONDUIT |
| 1017.1           | 0.6925       | 0.0320       |         |
| Ch.LC_D.Main10   | Out_LC_C     | DP_LC_C.D    | CONDUIT |
| 502.8            | 0.9843       | 0.0320       |         |
| Ch.LC_D.Main11   | Out_LC_E     | DP_LC_C.D    | CONDUIT |
| 57.0             | 1.4747       | 0.0320       |         |
| Ch.LC_G.Main10   | Out_LC_G10   | J_LC.G.H     | CONDUIT |
| 53.8             | 0.3477       | 0.0320       |         |
| Ch.LC_H.Main10   | Out_LC_H10   | J_LC.G.H     | CONDUIT |
| 144.6            | 0.6821       | 0.0320       |         |
| Ch.LC_I.Main1    | DP_LC_I20    | DP.LC_I      | CONDUIT |
| 1436.5           | 1.5439       | 0.0350       |         |

*SWMM Model Proposed – 100 Year*

|                 |                   |                   |         |
|-----------------|-------------------|-------------------|---------|
| Ch.OS_B1        | DP_OS_B1          | J.B_Main.5        | CONDUIT |
| 278.4 2.0240    | 0.0320            |                   |         |
| Ch.OS_B2        | DP_OS_B2          | J.B_Upper.Main_.2 | CONDUIT |
| 1186.2 3.3324   | 0.0320            |                   |         |
| Ch.OS2          | J_OS2             | J.B_Upper.Main_.2 | CONDUIT |
| 2743.3 2.1958   | 0.0320            |                   |         |
| Ch.UEC_A.Main10 | J_OS9             | Out_UEC_A         | CONDUIT |
| 2802.5 1.3865   | 0.0350            |                   |         |
| Ch.UEC_A.Main11 | Out_UEC_A         | DP_UEC_B10        | CONDUIT |
| 503.3 2.1648    | 0.0320            |                   |         |
| Ch.UEC_A.Main20 | DP_UEC_A20        | J_OS9             | CONDUIT |
| 669.7 2.9830    | 0.0320            |                   |         |
| Ch.UEC_B        | Out_UEC_B         | UEC_Out           | CONDUIT |
| 2023.0 1.1797   | 0.0320            |                   |         |
| Ch.UEC_B.Main10 | J.UEC_B.1         | Out_UEC_B         | CONDUIT |
| 1999.1 2.9446   | 0.0320            |                   |         |
| Ch.UEC_B.Side10 | DP_UEC_B10        | Out_UEC_B         | CONDUIT |
| 106.0 4.8828    | 0.0320            |                   |         |
| Ch.UEC_B.Side20 | DP_UEC_B20        | Out_UEC_B         | CONDUIT |
| 185.5 6.1092    | 0.0320            |                   |         |
| Ch.UEC_C.Main10 | Out_UEC_C10       | DP_UEC_B20        | CONDUIT |
| 776.8 1.6701    | 0.0320            |                   |         |
| Ch.UEC_D.Main10 | Out_UEC_D10       | Out_UEC_C10       | CONDUIT |
| 996.7 1.7957    | 0.0320            |                   |         |
| Ch_1            | J1                | J2                | CONDUIT |
| 2593.7 1.2488   | 0.0320            |                   |         |
| Ch_2            | J2                | J3                | CONDUIT |
| 1678.2 1.0507   | 0.0320            |                   |         |
| Ch_3            | J3                | J4                | CONDUIT |
| 973.6 0.7710    | 0.0320            |                   |         |
| Ch_4            | J4                | DP_OS3            | CONDUIT |
| 998.0 0.7716    | 0.0320            |                   |         |
| Ch_LC_A10       | J_LC_A10          | J3                | CONDUIT |
| 1414.2 2.8909   | 0.0320            |                   |         |
| Ch_Main_1       | J.B_Main.1        | Out_LC_B          | CONDUIT |
| 338.2 1.2946    | 0.0320            |                   |         |
| Ch_Main_2       | J.B_Main.2        | J.B_Main.1        | CONDUIT |
| 3347.0 0.5741   | 0.0320            |                   |         |
| Ch_Main_3       | J.B_Main.3        | J.B_Main.2        | CONDUIT |
| 1567.9 1.2853   | 0.0320            |                   |         |
| Ch_Main_4       | J.B_Main.4        | J.B_Main.3        | CONDUIT |
| 1664.6 0.9360   | 0.0320            |                   |         |
| Ch_Main_5       | J.B_Main.5        | J.B_Main.4        | CONDUIT |
| 1845.4 0.7223   | 0.0320            |                   |         |
| Ch_Main_6       | DP_OS3            | J.B_Main.5        | CONDUIT |
| 608.4 0.5064    | 0.0320            |                   |         |
| Ch_OS10         | DP_OS10           | OS10_In           | CONDUIT |
| 19.2 3.7992     | 0.0350            |                   |         |
| Ch_OS6          | J_OS6             | J2                | CONDUIT |
| 2634.9 3.8840   | 0.0350            |                   |         |
| Ch_Upper.Main_1 | J.B_Upper.Main_1  | Out_LC_B          | CONDUIT |
| 3730.9 0.8371   | 0.0320            |                   |         |
| Ch_Upper.Main_2 | J.B_Upper.Main_.2 | J.B_Upper.Main_1  | CONDUIT |
| 1106.1 0.3784   | 0.0320            |                   |         |

*SWMM Model Proposed – 100 Year*

|               |            |            |         |
|---------------|------------|------------|---------|
| Culv_LC_A10   | Out_LC_A10 | J_LC_A10   | CONDUIT |
| 120.5 2.1763  | 0.0130     |            |         |
| Culv_LC_A20   | Out_LC_A25 | J_LC_A25   | CONDUIT |
| 61.7 2.7100   | 0.0130     |            |         |
| Culv_OS1      | DP_OS1     | J_OS1      | CONDUIT |
| 67.5 6.6934   | 0.0240     |            |         |
| Culv_OS2      | DP_OS2     | J_OS2      | CONDUIT |
| 79.1 4.2307   | 0.0240     |            |         |
| Culv_OS4      | DP_OS4     | J_OS4      | CONDUIT |
| 87.0 0.1068   | 0.0130     |            |         |
| Culv_OS6      | DP_OS6     | J_OS6      | CONDUIT |
| 82.4 2.9775   | 0.0130     |            |         |
| Culv_OS7      | DP_OS7     | J_OS7      | CONDUIT |
| 99.0 3.6291   | 0.0240     |            |         |
| Culv_OS8      | DP_OS8     | J_OS8      | CONDUIT |
| 114.8 1.0631  | 0.0240     |            |         |
| Culv_OS9      | DP_OS9     | J_OS9      | CONDUIT |
| 93.8 1.5617   | 0.0210     |            |         |
| Dummy_Dr_A10  | Dr_A10     | Out_Dr_A10 | CONDUIT |
| 1154.7 1.7000 | 0.0100     |            |         |
| Dummy_Dr_B10  | Dr_B10     | Out_Dr_B10 | CONDUIT |
| 641.3 2.0983  | 0.0100     |            |         |
| Dummy_LC_A10  | LC_A10     | Out_LC_A10 | CONDUIT |
| 577.6 4.2097  | 0.0100     |            |         |
| Dummy_LC_A20  | LC_A20     | DP_LC_A20  | CONDUIT |
| 621.2 3.9942  | 0.0100     |            |         |
| Dummy_LC_A25  | LC_A25     | Out_LC_A25 | CONDUIT |
| 613.0 5.9554  | 0.0100     |            |         |
| Dummy_LC_A30  | LC_A30     | DP_LC_A30  | CONDUIT |
| 340.9 0.0135  | 0.0100     |            |         |
| Dummy_LC_B10  | LC_B10     | Out_LC_B   | CONDUIT |
| 1888.7 0.6793 | 0.0100     |            |         |
| Dummy_LC_B100 | LC_B100    | J.B_Main.4 | CONDUIT |
| 637.0 0.7044  | 0.0100     |            |         |
| Dummy_LC_B110 | LC_B110    | DP_LC_B110 | CONDUIT |
| 685.6 3.0385  | 0.0100     |            |         |
| Dummy_LC_B120 | LC_B120    | DP_LC_B120 | CONDUIT |
| 1132.3 3.6524 | 0.0100     |            |         |
| Dummy_LC_B130 | LC_B130    | DP_LC_B130 | CONDUIT |
| 1211.0 3.3062 | 0.0100     |            |         |
| Dummy_LC_B140 | LC_B140    | DP_LC_B140 | CONDUIT |
| 685.1 2.0096  | 0.0100     |            |         |
| Dummy_LC_B150 | LC_B150    | DP_LC_B150 | CONDUIT |
| 770.6 3.3608  | 0.0100     |            |         |
| Dummy_LC_B160 | LC_B160    | DP_LC_B160 | CONDUIT |
| 826.2 4.3415  | 0.0100     |            |         |
| Dummy_LC_B170 | LC_B170    | DP_LC_B170 | CONDUIT |
| 500.4 2.6261  | 0.0100     |            |         |
| Dummy_LC_B180 | LC_B180    | DP_LC_B180 | CONDUIT |
| 945.1 1.6444  | 0.0100     |            |         |
| Dummy_LC_B190 | LC_B190    | DP_LC_B190 | CONDUIT |
| 560.4 1.0402  | 0.0100     |            |         |
| Dummy_LC_B20  | LC_B20     | DP_LC_B20  | CONDUIT |
| 2209.8 1.5882 | 0.0100     |            |         |

*SWMM Model Proposed – 100 Year*

|              |        |            |         |
|--------------|--------|------------|---------|
| Dummy_LC_B30 | LC_B30 | DP_LC_B30  | CONDUIT |
| 886.1        | 4.1255 | 0.0100     |         |
| Dummy_LC_B40 | LC_B40 | DP_LC_B40  | CONDUIT |
| 1126.6       | 3.7169 | 0.0100     |         |
| Dummy_LC_B50 | LC_B50 | DP_LC_B50  | CONDUIT |
| 1140.0       | 0.5861 | 0.0100     |         |
| Dummy_LC_B60 | LC_B60 | J.B_Main.2 | CONDUIT |
| 1522.6       | 1.4066 | 0.0100     |         |
| Dummy_LC_B70 | LC_B70 | DP_LC_B70  | CONDUIT |
| 1947.8       | 1.8267 | 0.0100     |         |
| Dummy_LC_B80 | LC_B80 | DP_LC_B80  | CONDUIT |
| 1370.6       | 5.0007 | 0.0100     |         |
| Dummy_LC_B90 | LC_B90 | DP_LC_B90  | CONDUIT |
| 1477.3       | 4.9680 | 0.0100     |         |
| Dummy_LC_C10 | LC_C10 | Out_LC_C   | CONDUIT |
| 1192.4       | 1.4501 | 0.0100     |         |
| Dummy_LC_D10 | LC_D10 | Out_LC_E   | CONDUIT |
| 608.2        | 0.3861 | 0.0100     |         |
| Dummy_LC_F10 | LC_F10 | Out_LC_F   | CONDUIT |
| 1188.1       | 3.1263 | 0.0100     |         |
| Dummy_LC_F20 | LC_F20 | DP_LC_F20  | CONDUIT |
| 309.1        | 6.6180 | 0.0100     |         |
| Dummy_LC_G10 | LC_G10 | Out_LC_G10 | CONDUIT |
| 797.2        | 2.6904 | 0.0100     |         |
| Dummy_LC_H10 | LC_H10 | Out_LC_H10 | CONDUIT |
| 546.2        | 4.4143 | 0.0100     |         |
| Dummy_LC_I10 | LC_I10 | DP.LC_I    | CONDUIT |
| 1196.0       | 1.2855 | 0.0100     |         |
| Dummy_LC_I20 | LC_I20 | DP_LC_I20  | CONDUIT |
| 1520.7       | 2.3941 | 0.0100     |         |
| Dummy_OS_B1  | OS_B1  | DP_OS_B1   | CONDUIT |
| 388.8        | 4.1459 | 0.0100     |         |
| Dummy_OS_B2  | OS_B2  | DP_OS_B2   | CONDUIT |
| 836.3        | 2.3765 | 0.0100     |         |
| Dummy_OS1    | OS1    | DP_OS1     | CONDUIT |
| 3482.0       | 1.9161 | 0.0100     |         |
| Dummy_OS10   | OS10   | DP_OS10    | CONDUIT |
| 460.8        | 4.2688 | 0.0100     |         |
| Dummy_OS2    | OS2    | DP_OS2     | CONDUIT |
| 1242.8       | 2.2974 | 0.0100     |         |
| Dummy_OS3    | OS3    | DP_OS3     | CONDUIT |
| 9018.4       | 1.8056 | 0.0100     |         |
| Dummy_OS4    | OS4    | DP_OS4     | CONDUIT |
| 811.6        | 5.2783 | 0.0100     |         |
| Dummy_OS5    | OS5    | DP_OS5     | CONDUIT |
| 395.2        | 1.8938 | 0.0100     |         |
| Dummy_OS6    | OS6    | DP_OS6     | CONDUIT |
| 1040.0       | 0.0101 | 0.0100     |         |
| Dummy_OS7    | OS7    | DP_OS7     | CONDUIT |
| 657.7        | 3.6352 | 0.0100     |         |
| Dummy_OS8    | OS8    | DP_OS8     | CONDUIT |
| 393.2        | 5.5555 | 0.0100     |         |
| Dummy_OS9    | OS9    | DP_OS9     | CONDUIT |
| 2515.8       | 2.8023 | 0.0100     |         |

*SWMM Model Proposed – 100 Year*

|               |            |                  |         |
|---------------|------------|------------------|---------|
| Dummy_UEC_A10 | UEC_A10    | Out_UEC_A        | CONDUIT |
| 1521.5        | 2.0172     | 0.0100           |         |
| Dummy_UEC_A20 | UEC_A20    | DP_UEC_A20       | CONDUIT |
| 440.2         | 5.6715     | 0.0100           |         |
| Dummy_UEC_B   | UEC_B10    | DP_UEC_B10       | CONDUIT |
| 1883.2        | 2.3236     | 0.0100           |         |
| Dummy_UEC_B20 | UEC_B20    | DP_UEC_B20       | CONDUIT |
| 1490.5        | 3.2471     | 0.0100           |         |
| Dummy_UEC_B30 | UEC_B30    | DP_UEC_B30       | CONDUIT |
| 640.4         | 4.7294     | 0.0100           |         |
| Dummy_UEC_B40 | UEC_B40    | DP_UEC_B40       | CONDUIT |
| 380.6         | 3.2948     | 0.0100           |         |
| Dummy_UEC_C10 | UEC_C10    | Out_UEC_C10      | CONDUIT |
| 695.7         | 4.3682     | 0.0100           |         |
| Dummy_UEC_D10 | UEC_D10    | Out_UEC_D10      | CONDUIT |
| 352.4         | 1.1481     | 0.0100           |         |
| Over.Dr_B     | Out_Dr_B10 | Out.Dr           | CONDUIT |
| 369.4         | 3.3442     | 0.0350           |         |
| Over.LC.G     | J_LC.G.H   | Out_LC.G.H       | CONDUIT |
| 480.7         | 2.2179     | 0.0350           |         |
| Over.LC_B     | Out_LC_B   | Out_LC.B.F       | CONDUIT |
| 886.1         | 1.5033     | 0.0350           |         |
| Over.LC_D     | DP_LC_C.D  | Out_C.D          | CONDUIT |
| 131.0         | 0.4351     | 0.0350           |         |
| Over.LC_F     | Out_LC_F   | Out_LC.B.F       | CONDUIT |
| 684.7         | 1.1008     | 0.0350           |         |
| Over_LC_A25   | J_LC_A25   | J4               | CONDUIT |
| 707.8         | 3.1696     | 0.0350           |         |
| Over_OS4      | J_OS4      | J1               | CONDUIT |
| 3674.0        | 1.7494     | 0.0350           |         |
| Over_OS5      | DP_OS5     | J1               | CONDUIT |
| 3464.9        | 2.4535     | 0.0300           |         |
| Over_OS8_1    | J_OS8      | DP_LC_A30        | CONDUIT |
| 1266.5        | 1.1078     | 0.0350           |         |
| Pipe.LC_A.20  | DP_LC_A30  | DP_LC_A20        | CONDUIT |
| 2307.6        | 0.3444     | 0.0130           |         |
| Pipe.LC_B.110 | DP_LC_B110 | J.B_Main.4       | CONDUIT |
| 586.5         | 1.7379     | 0.0130           |         |
| Pipe.LC_B.120 | DP_LC_B120 | J.B_Main.4       | CONDUIT |
| 524.8         | 2.4125     | 0.0130           |         |
| Pipe.LC_B.40  | DP_LC_B40  | DP_LC_B30        | CONDUIT |
| 1334.5        | 2.0169     | 0.0130           |         |
| Pipe.LC_B.70  | DP_LC_B70  | J.B_Upper.Main_1 | CONDUIT |
| 256.9         | 1.2598     | 0.0130           |         |
| Pipe.LC_B.80  | DP_LC_B80  | J.B_Main.2       | CONDUIT |
| 242.8         | 4.7145     | 0.0130           |         |
| Pipe.LC_F.10  | DP_LC_F20  | J.B_Main.1       | CONDUIT |
| 1284.8        | 0.8406     | 0.0320           |         |
| Pipe.LC_I     | DP.LC_I    | Out_LC_I         | CONDUIT |
| 53.1          | 0.4805     | 0.0130           |         |
| Pipe.UEC_B.30 | DP_UEC_B30 | J.UEC_B.1        | CONDUIT |
| 126.5         | 4.9680     | 0.0130           |         |
| Pipe.UEC_B40  | DP_UEC_B40 | J.UEC_B.1        | CONDUIT |
| 141.4         | 0.7923     | 0.0130           |         |

*SWMM Model Proposed – 100 Year*

\*\*\*\*\*  
 Cross Section Summary  
 \*\*\*\*\*

| No. of<br>Conduit<br>Barrels | Full<br>Flow               | Shape       | Full<br>Depth | Full<br>Area | Hyd.<br>Rad. | Max.<br>Width |
|------------------------------|----------------------------|-------------|---------------|--------------|--------------|---------------|
| 1                            | Ch.Dr_A.Main10<br>229.28   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_A.Main10<br>3427.98  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_A.Side10<br>501.56   | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_A.Side11<br>1363.79  | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_B.30<br>612.34       | TRAPEZOIDAL | 3.00          | 81.00        | 2.04         | 39.00         |
| 1                            | Ch.LC_B.Side.120<br>391.02 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.121<br>161.09 | TRAPEZOIDAL | 3.00          | 81.00        | 2.04         | 39.00         |
| 1                            | Ch.LC_B.Side.140<br>259.50 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.Lc_B.Side.150<br>411.94 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.160<br>309.00 | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.90<br>310.66  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side.91<br>427.70  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side122<br>311.09  | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_B.Side130<br>833.53  | TRAPEZOIDAL | 3.00          | 66.00        | 1.90         | 34.00         |
| 1                            | Ch.LC_B.Side20<br>3641.46  | RECT_OPEN   | 2.00          | 400.00       | 1.96         | 200.00        |
| 1                            | Ch.LC_B.Side50<br>1388.25  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_B_Side10<br>1964.97  | TRAPEZOIDAL | 5.00          | 225.00       | 3.40         | 65.00         |
| 1                            | Ch.LC_D.Main10<br>203.48   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_D.Main11<br>249.06   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_G.Main10<br>120.93   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |
| 1                            | Ch.LC_H.Main10<br>169.38   | TRAPEZOIDAL | 2.00          | 36.00        | 1.36         | 26.00         |

*SWMM Model Proposed – 100 Year*

|   |                 |             |       |        |      |        |
|---|-----------------|-------------|-------|--------|------|--------|
| 1 | Ch.LC_I.Main1   | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 232.99          |             |       |        |      |        |
| 1 | Ch.OS_B1        | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 291.78          |             |       |        |      |        |
| 1 | Ch.OS_B2        | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 374.40          |             |       |        |      |        |
| 1 | Ch.OS2          | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
|   | 696.68          |             |       |        |      |        |
| 1 | Ch.UEC_A.Main10 | RECT_OPEN   | 2.00  | 400.00 | 1.96 | 200.00 |
|   | 3132.77         |             |       |        |      |        |
| 1 | Ch.UEC_A.Main11 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 301.76          |             |       |        |      |        |
| 1 | Ch.UEC_A.Main20 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 354.23          |             |       |        |      |        |
| 1 | Ch.UEC_B        | TRAPEZOIDAL | 5.00  | 350.00 | 3.84 | 90.00  |
|   | 4326.21         |             |       |        |      |        |
| 1 | Ch.UEC_B.Main10 | TRAPEZOIDAL | 5.00  | 225.00 | 3.40 | 65.00  |
|   | 4051.76         |             |       |        |      |        |
| 1 | Ch.UEC_B.Side10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 453.20          |             |       |        |      |        |
| 1 | Ch.UEC_B.Side20 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 506.94          |             |       |        |      |        |
| 1 | Ch.UEC_C.Main10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 265.05          |             |       |        |      |        |
| 1 | Ch.UEC_D.Main10 | TRAPEZOIDAL | 2.00  | 36.00  | 1.36 | 26.00  |
|   | 274.84          |             |       |        |      |        |
| 1 | Ch_1            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
|   | 4666.46         |             |       |        |      |        |
| 1 | Ch_2            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
|   | 4280.31         |             |       |        |      |        |
| 1 | Ch_3            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
|   | 3666.59         |             |       |        |      |        |
| 1 | Ch_4            | TRAPEZOIDAL | 5.00  | 375.00 | 3.71 | 100.00 |
|   | 3668.12         |             |       |        |      |        |
| 1 | Ch_LC_A10       | TRAPEZOIDAL | 10.00 | 900.00 | 6.34 | 140.00 |
|   | 24339.02        |             |       |        |      |        |
| 1 | Ch_Main_1       | TRIANGULAR  | 5.00  | 375.00 | 2.49 | 150.00 |
|   | 3644.29         |             |       |        |      |        |
| 1 | Ch_Main_2       | TRIANGULAR  | 5.50  | 412.50 | 2.74 | 150.00 |
|   | 2843.80         |             |       |        |      |        |
| 1 | Ch_Main_3       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
|   | 3269.68         |             |       |        |      |        |
| 1 | Ch_Main_4       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
|   | 2790.18         |             |       |        |      |        |
| 1 | Ch_Main_5       | TRIANGULAR  | 6.00  | 300.00 | 2.98 | 100.00 |
|   | 2451.08         |             |       |        |      |        |
| 1 | Ch_Main_6       | TRAPEZOIDAL | 5.00  | 400.00 | 3.95 | 100.00 |
|   | 3303.73         |             |       |        |      |        |
| 1 | Ch_OS10         | TRAPEZOIDAL | 3.00  | 66.00  | 1.90 | 34.00  |
|   | 837.84          |             |       |        |      |        |
| 1 | Ch_OS6          | TRIANGULAR  | 5.00  | 500.00 | 2.50 | 200.00 |
|   | 7700.00         |             |       |        |      |        |
| 1 | Ch_Upper.Main_1 | TRIANGULAR  | 5.00  | 125.00 | 2.45 | 50.00  |
|   | 965.54          |             |       |        |      |        |



*SWMM Model Proposed – 100 Year*

|   |                           |             |      |        |      |       |
|---|---------------------------|-------------|------|--------|------|-------|
| 1 | Ch_Upper.Main_2<br>649.23 | TRIANGULAR  | 5.00 | 125.00 | 2.45 | 50.00 |
| 1 | Culv_LC_A10<br>1159.39    | RECT_CLOSED | 8.00 | 48.00  | 1.71 | 6.00  |
| 1 | Culv_LC_A20<br>139.80     | RECT_CLOSED | 3.00 | 9.00   | 0.75 | 3.00  |
| 3 | Culv_OS1<br>93.47         | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 2 | Culv_OS2<br>45.70         | CIRCULAR    | 2.50 | 4.91   | 0.62 | 2.50  |
| 2 | Culv_OS4<br>32.88         | CIRCULAR    | 3.50 | 9.62   | 0.88 | 3.50  |
| 2 | Culv_OS6<br>115.09        | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 3 | Culv_OS7<br>23.34         | CIRCULAR    | 2.00 | 3.14   | 0.50 | 2.00  |
| 3 | Culv_OS8<br>22.91         | CIRCULAR    | 2.50 | 4.91   | 0.62 | 2.50  |
| 3 | Culv_OS9<br>51.60         | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00  |
| 1 | Dummy_Dr_A10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_Dr_B10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A20<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A25<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_A30<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B10<br>0.00      | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B100<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B110<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B120<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B130<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B140<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B150<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B160<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B170<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B180<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |
| 1 | Dummy_LC_B190<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00  |

*SWMM Model Proposed – 100 Year*

|   |              |       |      |      |      |      |
|---|--------------|-------|------|------|------|------|
| 1 | Dummy_LC_B20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B30 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B40 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B50 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B60 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B70 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B80 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_B90 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_C10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_D10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_F10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_F20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_G10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_H10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_I10 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_LC_I20 | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS_B1  | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS_B2  | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS1    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS10   | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS2    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS3    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS4    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS5    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS6    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_OS7    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |
| 1 | Dummy_Os8    | DUMMY | 0.00 | 0.00 | 0.00 | 0.00 |
|   | 0.00         |       |      |      |      |      |

*SWMM Model Proposed – 100 Year*

|   |                         |             |      |        |      |        |
|---|-------------------------|-------------|------|--------|------|--------|
| 1 | Dummy_OS9<br>0.00       | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_A10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_A20<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B<br>0.00     | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B20<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B30<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_B40<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_C10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Dummy_UEC_D10<br>0.00   | DUMMY       | 0.00 | 0.00   | 0.00 | 0.00   |
| 1 | Over.Dr_B<br>2401.37    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC.G<br>1955.60    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC_B<br>4584.09    | RECT_OPEN   | 1.50 | 675.00 | 1.49 | 450.00 |
| 1 | Over.LC_D<br>866.20     | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over.LC_F<br>1377.75    | RECT_OPEN   | 2.00 | 200.00 | 1.92 | 100.00 |
| 1 | Over_LC_A25<br>108.65   | TRAPEZOIDAL | 0.50 | 23.50  | 0.48 | 49.00  |
| 1 | Over_OS4<br>8838.21     | TRAPEZOIDAL | 5.00 | 600.00 | 4.25 | 140.00 |
| 1 | Over_OS5<br>10645.06    | RECT_OPEN   | 5.00 | 500.00 | 4.55 | 100.00 |
| 1 | Over_OS8_1<br>2800.25   | RECT_OPEN   | 2.00 | 400.00 | 1.96 | 200.00 |
| 1 | Pipe.LC_A.20<br>248.55  | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.LC_B.110<br>87.93  | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |
| 1 | Pipe.LC_B.120<br>657.81 | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.LC_B.40<br>369.87  | CIRCULAR    | 5.00 | 19.63  | 1.25 | 5.00   |
| 1 | Pipe.LC_B.70<br>161.22  | CIRCULAR    | 4.00 | 12.57  | 1.00 | 4.00   |
| 1 | Pipe.LC_B.80<br>144.82  | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |
| 1 | Pipe.LC_F.10<br>554.40  | TRAPEZOIDAL | 3.00 | 81.00  | 2.04 | 39.00  |
| 1 | Pipe.LC_I<br>293.56     | CIRCULAR    | 6.00 | 28.27  | 1.50 | 6.00   |
| 1 | Pipe.UEC_B.30<br>148.66 | CIRCULAR    | 3.00 | 7.07   | 0.75 | 3.00   |

SWMM Model Proposed – 100 Year

1 Pipe.UEC\_B40 CIRCULAR 3.00 7.07 0.75 3.00  
59.37

\*\*\*\*\*

Analysis Options

\*\*\*\*\*

Flow Units ..... CFS

Process Models:

Rainfall/Runoff ..... NO  
RDII ..... NO  
Snowmelt ..... NO  
Groundwater ..... NO  
Flow Routing ..... YES  
Ponding Allowed ..... NO  
Water Quality ..... NO

Flow Routing Method ..... KINWAVE

Starting Date ..... 01/01/2024 00:00:00

Ending Date ..... 01/02/2024 00:00:00

Antecedent Dry Days ..... 0.0

Report Time Step ..... 00:01:00

Routing Time Step ..... 5.00 sec

\*\*\*\*\*

|                            | Volume<br>acre-feet | Volume<br>10 <sup>6</sup> gal |
|----------------------------|---------------------|-------------------------------|
| *****                      | -----               | -----                         |
| Flow Routing Continuity    |                     |                               |
| Dry Weather Inflow .....   | 0.000               | 0.000                         |
| Wet Weather Inflow .....   | 0.000               | 0.000                         |
| Groundwater Inflow .....   | 0.000               | 0.000                         |
| RDII Inflow .....          | 0.000               | 0.000                         |
| External Inflow .....      | 605.449             | 197.295                       |
| External Outflow .....     | 610.000             | 198.778                       |
| Flooding Loss .....        | 0.000               | 0.000                         |
| Evaporation Loss .....     | 0.000               | 0.000                         |
| Exfiltration Loss .....    | 0.000               | 0.000                         |
| Initial Stored Volume .... | 0.000               | 0.000                         |
| Final Stored Volume .....  | 0.054               | 0.017                         |
| Continuity Error (%) ..... | -0.761              |                               |

\*\*\*\*\*

Highest Flow Instability Indexes

\*\*\*\*\*

All links are stable.

\*\*\*\*\*

Routing Time Step Summary

\*\*\*\*\*

Minimum Time Step : 5.00 sec  
Average Time Step : 5.00 sec  
Maximum Time Step : 5.00 sec  
% of Time in Steady State : 0.00

*SWMM Model Proposed – 100 Year*

Average Iterations per Step : 1.01  
 % of Steps Not Converging : 0.00

\*\*\*\*\*  
 Node Depth Summary  
 \*\*\*\*\*

| Reported<br>Max Depth<br>Node<br>Feet | Type     | Average<br>Depth<br>Feet | Maximum<br>Depth<br>Feet | Maximum<br>HGL<br>Feet | Time of Max<br>Occurrence<br>days hr:min |
|---------------------------------------|----------|--------------------------|--------------------------|------------------------|------------------------------------------|
| 3.70                                  | JUNCTION | 0.21                     | 3.70                     | 6258.27                | 0 00:42                                  |
| 4.17                                  | JUNCTION | 0.25                     | 4.17                     | 6374.17                | 0 00:42                                  |
| 4.18                                  | JUNCTION | 0.24                     | 4.18                     | 6382.13                | 0 00:37                                  |
| 1.92                                  | JUNCTION | 0.11                     | 1.92                     | 6286.21                | 0 00:41                                  |
| 3.78                                  | JUNCTION | 0.26                     | 3.78                     | 6290.54                | 0 00:46                                  |
| 0.64                                  | JUNCTION | 0.05                     | 0.64                     | 6336.72                | 0 00:48                                  |
| 0.67                                  | JUNCTION | 0.04                     | 0.67                     | 6377.42                | 0 00:42                                  |
| 1.04                                  | JUNCTION | 0.06                     | 1.04                     | 6339.61                | 0 00:42                                  |
| 1.86                                  | JUNCTION | 0.08                     | 1.86                     | 6320.41                | 0 00:38                                  |
| 0.31                                  | JUNCTION | 0.02                     | 0.31                     | 6403.47                | 0 00:42                                  |
| 1.35                                  | JUNCTION | 0.06                     | 1.35                     | 6352.01                | 0 00:37                                  |
| 1.34                                  | JUNCTION | 0.05                     | 1.34                     | 6340.51                | 0 00:35                                  |
| 2.11                                  | JUNCTION | 0.20                     | 2.11                     | 6223.93                | 0 01:09                                  |
| 2.70                                  | JUNCTION | 0.14                     | 2.70                     | 6243.82                | 0 00:40                                  |
| 2.70                                  | JUNCTION | 0.14                     | 2.70                     | 6270.73                | 0 00:39                                  |
| 1.92                                  | JUNCTION | 0.17                     | 1.92                     | 6273.91                | 0 01:04                                  |
| 3.14                                  | JUNCTION | 0.19                     | 3.15                     | 6252.38                | 0 00:46                                  |
| 2.10                                  | JUNCTION | 0.15                     | 2.10                     | 6251.90                | 0 00:49                                  |

*SWMM Model Proposed – 100 Year*

|                    |          |      |      |         |   |       |
|--------------------|----------|------|------|---------|---|-------|
| DP_LC_B90<br>1.56  | JUNCTION | 0.10 | 1.56 | 6272.00 | 0 | 00:42 |
| DP_LC_C.D<br>1.23  | JUNCTION | 0.07 | 1.23 | 6246.21 | 0 | 00:40 |
| DP_LC_F20<br>2.30  | JUNCTION | 0.13 | 2.30 | 6232.25 | 0 | 00:42 |
| DP_LC_I20<br>1.43  | JUNCTION | 0.08 | 1.43 | 6278.17 | 0 | 00:40 |
| DP_OS_B1<br>0.26   | JUNCTION | 0.01 | 0.26 | 6293.32 | 0 | 00:41 |
| DP_OS_B2<br>0.54   | JUNCTION | 0.02 | 0.54 | 6290.23 | 0 | 00:41 |
| DP_OS1<br>2.07     | JUNCTION | 0.17 | 2.07 | 6284.52 | 0 | 00:58 |
| DP_OS10<br>0.13    | JUNCTION | 0.01 | 0.13 | 6373.19 | 0 | 00:44 |
| DP_OS2<br>1.41     | JUNCTION | 0.14 | 1.41 | 6315.17 | 0 | 00:54 |
| DP_OS3<br>3.87     | JUNCTION | 0.42 | 3.87 | 6294.38 | 0 | 01:25 |
| DP_OS4<br>2.62     | JUNCTION | 0.12 | 2.62 | 6422.71 | 0 | 00:44 |
| DP_OS5<br>0.04     | JUNCTION | 0.00 | 0.04 | 6440.77 | 0 | 00:46 |
| DP_OS6<br>0.69     | JUNCTION | 0.07 | 0.69 | 6428.75 | 0 | 00:54 |
| DP_OS7<br>0.83     | JUNCTION | 0.08 | 0.83 | 6393.11 | 0 | 00:55 |
| DP_OS8<br>1.79     | JUNCTION | 0.09 | 1.79 | 6394.98 | 0 | 00:43 |
| DP_OS9<br>2.18     | JUNCTION | 0.23 | 2.18 | 6361.37 | 0 | 01:08 |
| DP_UEC_A20<br>0.57 | JUNCTION | 0.03 | 0.57 | 6378.27 | 0 | 00:39 |
| DP_UEC_B10<br>1.74 | JUNCTION | 0.21 | 1.74 | 6309.72 | 0 | 01:11 |
| DP_UEC_B20<br>1.13 | JUNCTION | 0.06 | 1.13 | 6315.25 | 0 | 00:40 |
| DP_UEC_B30<br>1.40 | JUNCTION | 0.06 | 1.40 | 6369.33 | 0 | 00:36 |
| DP_UEC_B40<br>1.30 | JUNCTION | 0.06 | 1.30 | 6364.07 | 0 | 00:36 |
| Dr_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6347.11 | 0 | 00:00 |
| Dr_B10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6329.34 | 0 | 00:00 |
| J.B_Main.1<br>5.25 | JUNCTION | 0.87 | 5.25 | 6224.41 | 0 | 01:34 |
| J.B_Main.2<br>5.36 | JUNCTION | 0.86 | 5.36 | 6243.72 | 0 | 01:28 |
| J.B_Main.3<br>5.60 | JUNCTION | 0.89 | 5.60 | 6264.12 | 0 | 01:28 |
| J.B_Main.4<br>5.65 | JUNCTION | 0.91 | 5.65 | 6279.75 | 0 | 01:29 |

*SWMM Model Proposed – 100 Year*

|                           |          |      |      |         |   |       |
|---------------------------|----------|------|------|---------|---|-------|
| J.B_Main.5<br>5.65        | JUNCTION | 0.85 | 5.65 | 6293.08 | 0 | 01:25 |
| J.B_Side.120<br>2.91      | JUNCTION | 0.20 | 2.91 | 6290.45 | 0 | 00:46 |
| J.B_Upper.Main_.2<br>2.27 | JUNCTION | 0.28 | 2.27 | 6252.46 | 0 | 00:54 |
| J.B_Upper.Main_1<br>3.14  | JUNCTION | 0.35 | 3.14 | 6249.15 | 0 | 00:46 |
| J.UEC_B.1<br>1.40         | JUNCTION | 0.06 | 1.40 | 6363.05 | 0 | 00:36 |
| J_LC.G.H<br>1.38          | JUNCTION | 0.08 | 1.38 | 6214.18 | 0 | 00:42 |
| J_LC_A10<br>2.82          | JUNCTION | 0.15 | 2.82 | 6349.40 | 0 | 00:42 |
| J_LC_A25<br>1.15          | JUNCTION | 0.06 | 1.15 | 6321.78 | 0 | 00:39 |
| J_OS1<br>2.07             | JUNCTION | 0.17 | 2.07 | 6280.01 | 0 | 00:58 |
| J_OS2<br>1.41             | JUNCTION | 0.14 | 1.41 | 6311.82 | 0 | 00:54 |
| J_OS4<br>2.62             | JUNCTION | 0.12 | 2.62 | 6422.62 | 0 | 00:44 |
| J_OS6<br>0.69             | JUNCTION | 0.07 | 0.69 | 6426.30 | 0 | 00:54 |
| J_OS7<br>0.83             | JUNCTION | 0.08 | 0.83 | 6389.52 | 0 | 00:55 |
| J_OS8<br>1.79             | JUNCTION | 0.09 | 1.79 | 6393.76 | 0 | 00:43 |
| J_OS9<br>2.18             | JUNCTION | 0.23 | 2.18 | 6359.91 | 0 | 01:08 |
| J1<br>0.36                | JUNCTION | 0.03 | 0.36 | 6356.09 | 0 | 01:05 |
| J2<br>0.59                | JUNCTION | 0.08 | 0.59 | 6323.94 | 0 | 01:05 |
| J3<br>1.38                | JUNCTION | 0.11 | 1.38 | 6307.09 | 0 | 00:44 |
| J4<br>1.47                | JUNCTION | 0.12 | 1.47 | 6299.68 | 0 | 00:46 |
| LC_A10<br>0.00            | JUNCTION | 0.00 | 0.00 | 6373.50 | 0 | 00:00 |
| LC_A20<br>0.00            | JUNCTION | 0.00 | 0.00 | 6394.79 | 0 | 00:00 |
| LC_A25<br>0.00            | JUNCTION | 0.00 | 0.00 | 6358.75 | 0 | 00:00 |
| LC_A30<br>0.00            | JUNCTION | 0.00 | 0.00 | 6377.99 | 0 | 00:00 |
| LC_B10<br>0.00            | JUNCTION | 0.00 | 0.00 | 6227.60 | 0 | 00:00 |
| LC_B100<br>0.00           | JUNCTION | 0.00 | 0.00 | 6278.59 | 0 | 00:00 |
| LC_B110<br>0.00           | JUNCTION | 0.00 | 0.00 | 6305.11 | 0 | 00:00 |
| LC_B120<br>0.00           | JUNCTION | 0.00 | 0.00 | 6328.08 | 0 | 00:00 |

*SWMM Model Proposed – 100 Year*

|                 |          |      |      |         |   |       |
|-----------------|----------|------|------|---------|---|-------|
| LC_B130<br>0.00 | JUNCTION | 0.00 | 0.00 | 6376.10 | 0 | 00:00 |
| LC_B140<br>0.00 | JUNCTION | 0.00 | 0.00 | 6390.52 | 0 | 00:00 |
| LC_B150<br>0.00 | JUNCTION | 0.00 | 0.00 | 6364.46 | 0 | 00:00 |
| LC_B160<br>0.00 | JUNCTION | 0.00 | 0.00 | 6354.39 | 0 | 00:00 |
| LC_B170<br>0.00 | JUNCTION | 0.00 | 0.00 | 6416.30 | 0 | 00:00 |
| LC_B180<br>0.00 | JUNCTION | 0.00 | 0.00 | 6366.21 | 0 | 00:00 |
| LC_B190<br>0.00 | JUNCTION | 0.00 | 0.00 | 6345.00 | 0 | 00:00 |
| LC_B20<br>0.00  | JUNCTION | 0.00 | 0.00 | 6256.91 | 0 | 00:00 |
| LC_B30<br>0.00  | JUNCTION | 0.00 | 0.00 | 6277.65 | 0 | 00:00 |
| LC_B40<br>0.00  | JUNCTION | 0.00 | 0.00 | 6309.88 | 0 | 00:00 |
| LC_B50<br>0.00  | JUNCTION | 0.00 | 0.00 | 6278.66 | 0 | 00:00 |
| LC_B60<br>0.00  | JUNCTION | 0.00 | 0.00 | 6259.78 | 0 | 00:00 |
| LC_B70<br>0.00  | JUNCTION | 0.00 | 0.00 | 6284.81 | 0 | 00:00 |
| LC_B80<br>0.00  | JUNCTION | 0.00 | 0.00 | 6318.25 | 0 | 00:00 |
| LC_B90<br>0.00  | JUNCTION | 0.00 | 0.00 | 6343.74 | 0 | 00:00 |
| LC_C10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6267.21 | 0 | 00:00 |
| LC_D10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6248.16 | 0 | 00:00 |
| LC_F10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6246.12 | 0 | 00:00 |
| LC_F20<br>0.00  | JUNCTION | 0.00 | 0.00 | 6250.36 | 0 | 00:00 |
| LC_G10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6234.42 | 0 | 00:00 |
| LC_H10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6237.87 | 0 | 00:00 |
| LC_I10<br>0.00  | JUNCTION | 0.00 | 0.00 | 6269.94 | 0 | 00:00 |
| LC_I20<br>0.00  | JUNCTION | 0.00 | 0.00 | 6313.14 | 0 | 00:00 |
| OS_B1<br>0.00   | JUNCTION | 0.00 | 0.00 | 6309.16 | 0 | 00:00 |
| OS_B2<br>0.00   | JUNCTION | 0.00 | 0.00 | 6309.56 | 0 | 00:00 |
| OS1<br>0.00     | JUNCTION | 0.00 | 0.00 | 6349.15 | 0 | 00:00 |
| OS10<br>0.00    | JUNCTION | 0.00 | 0.00 | 6392.72 | 0 | 00:00 |



*SWMM Model Proposed – 100 Year*

|                     |          |      |      |         |   |       |
|---------------------|----------|------|------|---------|---|-------|
| OS10_In<br>0.63     | JUNCTION | 0.06 | 0.63 | 6372.97 | 0 | 00:59 |
| OS2<br>0.00         | JUNCTION | 0.00 | 0.00 | 6342.30 | 0 | 00:00 |
| OS3<br>0.00         | JUNCTION | 0.00 | 0.00 | 6453.31 | 0 | 00:00 |
| OS4<br>0.00         | JUNCTION | 0.00 | 0.00 | 6462.88 | 0 | 00:00 |
| OS5<br>0.00         | JUNCTION | 0.00 | 0.00 | 6448.20 | 0 | 00:00 |
| OS6<br>0.00         | JUNCTION | 0.00 | 0.00 | 6428.17 | 0 | 00:00 |
| OS7<br>0.00         | JUNCTION | 0.00 | 0.00 | 6416.17 | 0 | 00:00 |
| OS8<br>0.00         | JUNCTION | 0.00 | 0.00 | 6415.01 | 0 | 00:00 |
| OS9<br>0.00         | JUNCTION | 0.00 | 0.00 | 6429.66 | 0 | 00:00 |
| Out_Dr_A10<br>1.35  | JUNCTION | 0.08 | 1.35 | 6328.83 | 0 | 00:42 |
| Out_Dr_B10<br>1.35  | JUNCTION | 0.08 | 1.35 | 6317.23 | 0 | 00:43 |
| Out_LC_A10<br>2.82  | JUNCTION | 0.15 | 2.82 | 6352.02 | 0 | 00:42 |
| Out_LC_A25<br>1.15  | JUNCTION | 0.06 | 1.15 | 6323.45 | 0 | 00:39 |
| Out_LC_B<br>4.43    | JUNCTION | 0.73 | 4.43 | 6219.20 | 0 | 01:33 |
| Out_LC_C<br>1.23    | JUNCTION | 0.06 | 1.23 | 6251.15 | 0 | 00:39 |
| Out_LC_E<br>0.94    | JUNCTION | 0.06 | 0.94 | 6246.75 | 0 | 00:43 |
| Out_LC_F<br>0.53    | JUNCTION | 0.02 | 0.53 | 6209.52 | 0 | 00:37 |
| Out_LC_G10<br>1.38  | JUNCTION | 0.08 | 1.38 | 6214.36 | 0 | 00:42 |
| Out_LC_H10<br>0.73  | JUNCTION | 0.04 | 0.73 | 6214.51 | 0 | 00:40 |
| Out_UEC_A<br>1.74   | JUNCTION | 0.21 | 1.74 | 6320.61 | 0 | 01:10 |
| Out_UEC_B<br>1.58   | JUNCTION | 0.18 | 1.58 | 6304.39 | 0 | 01:07 |
| Out_UEC_C10<br>1.02 | JUNCTION | 0.06 | 1.02 | 6328.11 | 0 | 00:41 |
| Out_UEC_D10<br>0.62 | JUNCTION | 0.03 | 0.62 | 6345.61 | 0 | 00:37 |
| UEC_A10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6349.56 | 0 | 00:00 |
| UEC_A20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6402.62 | 0 | 00:00 |
| UEC_B10<br>0.00     | JUNCTION | 0.00 | 0.00 | 6351.73 | 0 | 00:00 |
| UEC_B20<br>0.00     | JUNCTION | 0.00 | 0.00 | 6362.49 | 0 | 00:00 |

*SWMM Model Proposed – 100 Year*

|            |          |      |      |         |   |       |
|------------|----------|------|------|---------|---|-------|
| UEC_B30    | JUNCTION | 0.00 | 0.00 | 6398.18 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_B40    | JUNCTION | 0.00 | 0.00 | 6375.31 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_C10    | JUNCTION | 0.00 | 0.00 | 6357.45 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| UEC_D10    | JUNCTION | 0.00 | 0.00 | 6349.03 | 0 | 00:00 |
| 0.00       |          |      |      |         |   |       |
| Out.Dr     | OUTFALL  | 0.02 | 0.37 | 6303.91 | 0 | 00:43 |
| 0.37       |          |      |      |         |   |       |
| Out_C.D    | OUTFALL  | 0.04 | 0.66 | 6245.06 | 0 | 00:42 |
| 0.66       |          |      |      |         |   |       |
| Out_LC.B.F | OUTFALL  | 0.14 | 1.19 | 6202.65 | 0 | 01:31 |
| 1.19       |          |      |      |         |   |       |
| Out_LC.G.H | OUTFALL  | 0.02 | 0.30 | 6202.43 | 0 | 00:43 |
| 0.30       |          |      |      |         |   |       |
| Out_LC_I   | OUTFALL  | 0.21 | 3.70 | 6258.02 | 0 | 00:42 |
| 3.70       |          |      |      |         |   |       |
| UEC_Out    | OUTFALL  | 0.14 | 1.40 | 6280.35 | 0 | 00:47 |
| 1.40       |          |      |      |         |   |       |

\*\*\*\*\*  
Node Inflow Summary  
\*\*\*\*\*

-----

| Lateral    | Total    | Flow     | Maximum | Maximum | Time of Max |        | 10^6 |
|------------|----------|----------|---------|---------|-------------|--------|------|
|            |          |          | Lateral | Total   |             |        |      |
| Inflow     | Inflow   | Balance  | Inflow  | Inflow  | Occurrence  |        |      |
| Volume     | Volume   | Error    | CFS     | CFS     | days        | hr:min |      |
| Node       | 10^6 gal | Type     |         |         |             |        |      |
| gal        | 10^6 gal | Percent  |         |         |             |        |      |
| DP_LC_I    |          | JUNCTION | 0.00    | 205.82  | 0           | 00:42  |      |
| 0          | 5.08     | 0.000    |         |         |             |        |      |
| DP_LC_A20  |          | JUNCTION | 0.00    | 275.95  | 0           | 00:42  |      |
| 0          | 6.5      | 0.000    |         |         |             |        |      |
| DP_LC_A30  |          | JUNCTION | 0.00    | 206.93  | 0           | 00:37  |      |
| 0          | 4.72     | 0.000    |         |         |             |        |      |
| DP_LC_B110 |          | JUNCTION | 0.00    | 65.28   | 0           | 00:41  |      |
| 0          | 1.64     | 0.000    |         |         |             |        |      |
| DP_LC_B120 |          | JUNCTION | 0.00    | 476.26  | 0           | 00:46  |      |
| 0          | 12.3     | 0.000    |         |         |             |        |      |
| DP_LC_B130 |          | JUNCTION | 0.00    | 42.94   | 0           | 00:48  |      |
| 0          | 1.63     | 0.000    |         |         |             |        |      |
| DP_LC_B140 |          | JUNCTION | 0.00    | 52.77   | 0           | 00:42  |      |
| 0          | 1.39     | 0.000    |         |         |             |        |      |
| DP_LC_B150 |          | JUNCTION | 0.00    | 110.83  | 0           | 00:42  |      |
| 0          | 2.79     | 0.000    |         |         |             |        |      |

-----

*SWMM Model Proposed – 100 Year*

|            |          |      |         |   |       |
|------------|----------|------|---------|---|-------|
| DP_LC_B160 | JUNCTION | 0.00 | 269.31  | 0 | 00:38 |
| 0 4.96     | 0.000    |      |         |   |       |
| DP_LC_B170 | JUNCTION | 0.00 | 8.74    | 0 | 00:42 |
| 0 0.264    | 0.000    |      |         |   |       |
| DP_LC_B180 | JUNCTION | 0.00 | 143.01  | 0 | 00:37 |
| 0 2.69     | 0.000    |      |         |   |       |
| DP_LC_B190 | JUNCTION | 0.00 | 142.63  | 0 | 00:35 |
| 0 2.11     | 0.000    |      |         |   |       |
| DP_LC_B20  | JUNCTION | 0.00 | 383.92  | 0 | 01:09 |
| 0 15.1     | 0.000    |      |         |   |       |
| DP_LC_B30  | JUNCTION | 0.00 | 309.99  | 0 | 00:40 |
| 0 7.12     | 0.000    |      |         |   |       |
| DP_LC_B40  | JUNCTION | 0.00 | 210.35  | 0 | 00:39 |
| 0 4.81     | 0.000    |      |         |   |       |
| DP_LC_B50  | JUNCTION | 0.00 | 328.60  | 0 | 00:59 |
| 0 11.9     | -0.000   |      |         |   |       |
| DP_LC_B70  | JUNCTION | 0.00 | 154.75  | 0 | 00:46 |
| 0 4.57     | 0.000    |      |         |   |       |
| DP_LC_B80  | JUNCTION | 0.00 | 120.82  | 0 | 00:49 |
| 0 4.18     | 0.000    |      |         |   |       |
| DP_LC_B90  | JUNCTION | 0.00 | 262.68  | 0 | 00:42 |
| 0 6.64     | -0.000   |      |         |   |       |
| DP_LC_C.D  | JUNCTION | 0.00 | 138.36  | 0 | 00:41 |
| 0 3.52     | 0.000    |      |         |   |       |
| DP_LC_F20  | JUNCTION | 0.00 | 328.28  | 0 | 00:42 |
| 0 8.06     | 0.000    |      |         |   |       |
| DP_LC_I20  | JUNCTION | 0.00 | 121.23  | 0 | 00:40 |
| 0 2.98     | 0.000    |      |         |   |       |
| DP_OS_B1   | JUNCTION | 0.00 | 7.25    | 0 | 00:41 |
| 0 0.154    | 0.000    |      |         |   |       |
| DP_OS_B2   | JUNCTION | 0.00 | 32.70   | 0 | 00:41 |
| 0 0.615    | 0.000    |      |         |   |       |
| DP_OS1     | JUNCTION | 0.00 | 230.59  | 0 | 00:58 |
| 0 8.58     | 0.000    |      |         |   |       |
| DP_OS10    | JUNCTION | 0.00 | 2.67    | 0 | 00:44 |
| 0 0.0948   | 0.000    |      |         |   |       |
| DP_OS2     | JUNCTION | 0.00 | 55.71   | 0 | 00:54 |
| 0 2.4      | 0.000    |      |         |   |       |
| DP_OS3     | JUNCTION | 0.00 | 2085.98 | 0 | 01:25 |
| 0 101      | 0.000    |      |         |   |       |
| DP_OS4     | JUNCTION | 0.00 | 59.67   | 0 | 00:44 |
| 0 1.3      | 0.000    |      |         |   |       |
| DP_OS5     | JUNCTION | 0.00 | 4.20    | 0 | 00:46 |
| 0 0.138    | 0.000    |      |         |   |       |
| DP_OS6     | JUNCTION | 0.00 | 26.86   | 0 | 00:54 |
| 0 1.14     | 0.000    |      |         |   |       |
| DP_OS7     | JUNCTION | 0.00 | 25.38   | 0 | 00:55 |
| 0 1.14     | 0.000    |      |         |   |       |
| DP_OS8     | JUNCTION | 0.00 | 59.07   | 0 | 00:43 |
| 0 1.42     | 0.000    |      |         |   |       |
| DP_OS9     | JUNCTION | 0.00 | 135.58  | 0 | 01:08 |
| 0 6.68     | 0.000    |      |         |   |       |
| DP_UEC_A20 | JUNCTION | 0.00 | 34.76   | 0 | 00:39 |
| 0 0.812    | 0.000    |      |         |   |       |

*SWMM Model Proposed – 100 Year*

|                   |          |        |         |   |       |
|-------------------|----------|--------|---------|---|-------|
| DP_UEC_B10        | JUNCTION | 0.00   | 283.88  | 0 | 01:07 |
| 0 13              | 0.000    |        |         |   |       |
| DP_UEC_B20        | JUNCTION | 0.00   | 169.58  | 0 | 00:40 |
| 0 3.98            | 0.000    |        |         |   |       |
| DP_UEC_B30        | JUNCTION | 0.00   | 66.13   | 0 | 00:36 |
| 0 1.13            | 0.000    |        |         |   |       |
| DP_UEC_B40        | JUNCTION | 0.00   | 23.06   | 0 | 00:36 |
| 0 0.396           | 0.000    |        |         |   |       |
| Dr_A10            | JUNCTION | 106.35 | 106.35  | 0 | 00:42 |
| 2.83 2.83         | 0.000    |        |         |   |       |
| Dr_B10            | JUNCTION | 41.35  | 41.35   | 0 | 00:37 |
| 0.898 0.898       | 0.000    |        |         |   |       |
| J.B_Main.1        | JUNCTION | 0.00   | 2633.62 | 0 | 01:32 |
| 0 137             | 0.000    |        |         |   |       |
| J.B_Main.2        | JUNCTION | 0.00   | 2525.61 | 0 | 01:28 |
| 0 129             | 0.000    |        |         |   |       |
| J.B_Main.3        | JUNCTION | 0.00   | 2416.89 | 0 | 01:27 |
| 0 122             | 0.000    |        |         |   |       |
| J.B_Main.4        | JUNCTION | 0.00   | 2318.98 | 0 | 01:25 |
| 0 116             | 0.000    |        |         |   |       |
| J.B_Main.5        | JUNCTION | 0.00   | 2087.98 | 0 | 01:25 |
| 0 101             | 0.000    |        |         |   |       |
| J.B_Side.120      | JUNCTION | 0.00   | 151.53  | 0 | 00:46 |
| 0 4.42            | 0.000    |        |         |   |       |
| J.B_Upper.Main_.2 | JUNCTION | 0.00   | 79.28   | 0 | 00:54 |
| 0 3.03            | 0.000    |        |         |   |       |
| J.B_Upper.Main_1  | JUNCTION | 0.00   | 219.24  | 0 | 00:53 |
| 0 7.61            | 0.000    |        |         |   |       |
| J.UEC_B.1         | JUNCTION | 0.00   | 89.18   | 0 | 00:36 |
| 0 1.53            | 0.000    |        |         |   |       |
| J_LC.G.H          | JUNCTION | 0.00   | 84.15   | 0 | 00:41 |
| 0 2.28            | 0.000    |        |         |   |       |
| J_LC_A10          | JUNCTION | 0.00   | 366.35  | 0 | 00:42 |
| 0 9.16            | 0.000    |        |         |   |       |
| J_LC_A25          | JUNCTION | 0.00   | 48.69   | 0 | 00:39 |
| 0 1.2             | 0.000    |        |         |   |       |
| J_OS1             | JUNCTION | 0.00   | 230.58  | 0 | 00:58 |
| 0 8.58            | 0.000    |        |         |   |       |
| J_OS2             | JUNCTION | 0.00   | 55.71   | 0 | 00:54 |
| 0 2.4             | 0.000    |        |         |   |       |
| J_OS4             | JUNCTION | 0.00   | 59.67   | 0 | 00:44 |
| 0 1.3             | 0.000    |        |         |   |       |
| J_OS6             | JUNCTION | 0.00   | 26.86   | 0 | 00:54 |
| 0 1.14            | 0.000    |        |         |   |       |
| J_OS7             | JUNCTION | 0.00   | 25.38   | 0 | 00:55 |
| 0 1.14            | 0.000    |        |         |   |       |
| J_OS8             | JUNCTION | 0.00   | 59.06   | 0 | 00:43 |
| 0 1.42            | 0.000    |        |         |   |       |
| J_OS9             | JUNCTION | 0.00   | 157.50  | 0 | 01:05 |
| 0 7.49            | 0.000    |        |         |   |       |
| J1                | JUNCTION | 0.00   | 47.34   | 0 | 01:05 |
| 0 1.64            | 0.000    |        |         |   |       |
| J2                | JUNCTION | 0.00   | 68.34   | 0 | 01:16 |
| 0 2.84            | 0.000    |        |         |   |       |

*SWMM Model Proposed – 100 Year*

|         |       |          |        |        |   |       |
|---------|-------|----------|--------|--------|---|-------|
| J3      |       | JUNCTION | 0.00   | 365.48 | 0 | 00:44 |
| 0       | 12    | 0.000    |        |        |   |       |
| J4      |       | JUNCTION | 0.00   | 410.63 | 0 | 00:46 |
| 0       | 13.3  | 0.000    |        |        |   |       |
| LC_A10  |       | JUNCTION | 89.75  | 89.75  | 0 | 00:35 |
| 1.42    | 1.42  | 0.000    |        |        |   |       |
| LC_A20  |       | JUNCTION | 70.78  | 70.78  | 0 | 00:40 |
| 1.8     | 1.8   | 0.000    |        |        |   |       |
| LC_A25  |       | JUNCTION | 48.69  | 48.69  | 0 | 00:39 |
| 1.2     | 1.2   | 0.000    |        |        |   |       |
| LC_A30  |       | JUNCTION | 202.69 | 202.69 | 0 | 00:36 |
| 3.23    | 3.23  | 0.000    |        |        |   |       |
| LC_B10  |       | JUNCTION | 50.36  | 50.36  | 0 | 01:08 |
| 2.67    | 2.67  | 0.000    |        |        |   |       |
| LC_B100 |       | JUNCTION | 10.11  | 10.11  | 0 | 01:07 |
| 0.61    | 0.61  | 0.000    |        |        |   |       |
| LC_B110 |       | JUNCTION | 65.28  | 65.28  | 0 | 00:41 |
| 1.64    | 1.64  | 0.000    |        |        |   |       |
| LC_B120 |       | JUNCTION | 103.80 | 103.80 | 0 | 00:44 |
| 2.86    | 2.86  | 0.000    |        |        |   |       |
| LC_B130 |       | JUNCTION | 42.94  | 42.94  | 0 | 00:48 |
| 1.63    | 1.63  | 0.000    |        |        |   |       |
| LC_B140 |       | JUNCTION | 46.69  | 46.69  | 0 | 00:39 |
| 1.12    | 1.12  | 0.000    |        |        |   |       |
| LC_B150 |       | JUNCTION | 59.16  | 59.16  | 0 | 00:40 |
| 1.4     | 1.4   | 0.000    |        |        |   |       |
| LC_B160 |       | JUNCTION | 131.96 | 131.96 | 0 | 00:36 |
| 2.27    | 2.27  | 0.000    |        |        |   |       |
| LC_B170 |       | JUNCTION | 8.74   | 8.74   | 0 | 00:42 |
| 0.264   | 0.264 | 0.000    |        |        |   |       |
| LC_B180 |       | JUNCTION | 143.01 | 143.01 | 0 | 00:37 |
| 2.69    | 2.69  | 0.000    |        |        |   |       |
| LC_B190 |       | JUNCTION | 142.63 | 142.63 | 0 | 00:35 |
| 2.11    | 2.11  | 0.000    |        |        |   |       |
| LC_B20  |       | JUNCTION | 71.02  | 71.02  | 0 | 00:54 |
| 2.97    | 2.97  | 0.000    |        |        |   |       |
| LC_B30  |       | JUNCTION | 99.79  | 99.79  | 0 | 00:40 |
| 2.32    | 2.32  | 0.000    |        |        |   |       |
| LC_B40  |       | JUNCTION | 210.35 | 210.35 | 0 | 00:39 |
| 4.81    | 4.81  | 0.000    |        |        |   |       |
| LC_B50  |       | JUNCTION | 150.29 | 150.29 | 0 | 00:38 |
| 3.3     | 3.3   | 0.000    |        |        |   |       |
| LC_B60  |       | JUNCTION | 44.51  | 44.51  | 0 | 00:59 |
| 1.99    | 1.99  | 0.000    |        |        |   |       |
| LC_B70  |       | JUNCTION | 154.75 | 154.75 | 0 | 00:46 |
| 4.57    | 4.57  | 0.000    |        |        |   |       |
| LC_B80  |       | JUNCTION | 120.82 | 120.82 | 0 | 00:49 |
| 4.18    | 4.18  | 0.000    |        |        |   |       |
| LC_B90  |       | JUNCTION | 137.94 | 137.94 | 0 | 00:48 |
| 4.5     | 4.5   | 0.000    |        |        |   |       |
| LC_C10  |       | JUNCTION | 79.80  | 79.80  | 0 | 00:39 |
| 1.85    | 1.85  | 0.000    |        |        |   |       |
| LC_D10  |       | JUNCTION | 58.99  | 58.99  | 0 | 00:43 |
| 1.67    | 1.67  | 0.000    |        |        |   |       |

*SWMM Model Proposed – 100 Year*

|            |        |          |         |         |   |       |
|------------|--------|----------|---------|---------|---|-------|
| LC_F10     |        | JUNCTION | 153.24  | 153.24  | 0 | 00:37 |
| 3.11       | 3.11   | 0.000    |         |         |   |       |
| LC_F20     |        | JUNCTION | 21.43   | 21.43   | 0 | 00:54 |
| 0.935      | 0.935  | 0.000    |         |         |   |       |
| LC_G10     |        | JUNCTION | 58.97   | 58.97   | 0 | 00:42 |
| 1.66       | 1.66   | 0.000    |         |         |   |       |
| LC_H10     |        | JUNCTION | 25.24   | 25.24   | 0 | 00:40 |
| 0.611      | 0.611  | 0.000    |         |         |   |       |
| LC_I10     |        | JUNCTION | 87.28   | 87.28   | 0 | 00:39 |
| 2.1        | 2.1    | 0.000    |         |         |   |       |
| LC_I20     |        | JUNCTION | 121.23  | 121.23  | 0 | 00:40 |
| 2.98       | 2.98   | 0.000    |         |         |   |       |
| OS_B1      |        | JUNCTION | 7.25    | 7.25    | 0 | 00:41 |
| 0.154      | 0.154  | 0.000    |         |         |   |       |
| OS_B2      |        | JUNCTION | 32.70   | 32.70   | 0 | 00:41 |
| 0.615      | 0.615  | 0.000    |         |         |   |       |
| OS1        |        | JUNCTION | 230.59  | 230.59  | 0 | 00:58 |
| 8.58       | 8.58   | 0.000    |         |         |   |       |
| OS10       |        | JUNCTION | 2.67    | 2.67    | 0 | 00:44 |
| 0.0948     | 0.0948 | 0.000    |         |         |   |       |
| OS10_In    |        | JUNCTION | 0.00    | 27.74   | 0 | 00:59 |
| 0          | 1.24   | 0.000    |         |         |   |       |
| OS2        |        | JUNCTION | 55.71   | 55.71   | 0 | 00:54 |
| 2.4        | 2.4    | 0.000    |         |         |   |       |
| OS3        |        | JUNCTION | 1832.34 | 1832.34 | 0 | 01:27 |
| 87.7       | 87.7   | 0.000    |         |         |   |       |
| OS4        |        | JUNCTION | 59.67   | 59.67   | 0 | 00:44 |
| 1.3        | 1.3    | 0.000    |         |         |   |       |
| OS5        |        | JUNCTION | 4.20    | 4.20    | 0 | 00:46 |
| 0.138      | 0.138  | 0.000    |         |         |   |       |
| OS6        |        | JUNCTION | 26.86   | 26.86   | 0 | 00:54 |
| 1.14       | 1.14   | 0.000    |         |         |   |       |
| OS7        |        | JUNCTION | 25.38   | 25.38   | 0 | 00:55 |
| 1.14       | 1.14   | 0.000    |         |         |   |       |
| OS8        |        | JUNCTION | 59.07   | 59.07   | 0 | 00:43 |
| 1.42       | 1.42   | 0.000    |         |         |   |       |
| OS9        |        | JUNCTION | 135.58  | 135.58  | 0 | 01:08 |
| 6.68       | 6.68   | 0.000    |         |         |   |       |
| Out_Dr_A10 |        | JUNCTION | 0.00    | 106.35  | 0 | 00:42 |
| 0          | 2.83   | 0.000    |         |         |   |       |
| Out_Dr_B10 |        | JUNCTION | 0.00    | 145.46  | 0 | 00:42 |
| 0          | 3.73   | 0.000    |         |         |   |       |
| Out_LC_A10 |        | JUNCTION | 0.00    | 366.35  | 0 | 00:42 |
| 0          | 9.16   | 0.000    |         |         |   |       |
| Out_LC_A25 |        | JUNCTION | 0.00    | 48.69   | 0 | 00:39 |
| 0          | 1.2    | 0.000    |         |         |   |       |
| Out_LC_B   |        | JUNCTION | 0.00    | 3134.90 | 0 | 01:29 |
| 0          | 162    | 0.000    |         |         |   |       |
| Out_LC_C   |        | JUNCTION | 0.00    | 79.80   | 0 | 00:39 |
| 0          | 1.85   | 0.000    |         |         |   |       |
| Out_LC_E   |        | JUNCTION | 0.00    | 58.99   | 0 | 00:43 |
| 0          | 1.67   | 0.000    |         |         |   |       |
| Out_LC_F   |        | JUNCTION | 0.00    | 153.24  | 0 | 00:37 |
| 0          | 3.11   | 0.000    |         |         |   |       |

*SWMM Model Proposed – 100 Year*

|             |       |          |        |         |   |       |
|-------------|-------|----------|--------|---------|---|-------|
| Out_LC_G10  |       | JUNCTION | 0.00   | 58.97   | 0 | 00:42 |
| 0           | 1.66  | 0.000    |        |         |   |       |
| Out_LC_H10  |       | JUNCTION | 0.00   | 25.24   | 0 | 00:40 |
| 0           | 0.611 | 0.000    |        |         |   |       |
| Out_UEC_A   |       | JUNCTION | 0.00   | 228.30  | 0 | 01:10 |
| 0           | 10.9  | 0.000    |        |         |   |       |
| Out_UEC_B   |       | JUNCTION | 0.00   | 461.89  | 0 | 00:42 |
| 0           | 18.6  | 0.000    |        |         |   |       |
| Out_UEC_C10 |       | JUNCTION | 0.00   | 72.76   | 0 | 00:41 |
| 0           | 1.87  | 0.000    |        |         |   |       |
| Out_UEC_D10 |       | JUNCTION | 0.00   | 30.73   | 0 | 00:37 |
| 0           | 0.718 | -0.000   |        |         |   |       |
| UEC_A10     |       | JUNCTION | 114.80 | 114.80  | 0 | 00:43 |
| 3.19        | 3.19  | 0.000    |        |         |   |       |
| UEC_A20     |       | JUNCTION | 34.76  | 34.76   | 0 | 00:39 |
| 0.812       | 0.812 | 0.000    |        |         |   |       |
| UEC_B10     |       | JUNCTION | 91.59  | 91.59   | 0 | 00:40 |
| 2.18        | 2.18  | 0.000    |        |         |   |       |
| UEC_B20     |       | JUNCTION | 100.29 | 100.29  | 0 | 00:38 |
| 2.11        | 2.11  | 0.000    |        |         |   |       |
| UEC_B30     |       | JUNCTION | 66.13  | 66.13   | 0 | 00:36 |
| 1.13        | 1.13  | 0.000    |        |         |   |       |
| UEC_B40     |       | JUNCTION | 23.06  | 23.06   | 0 | 00:36 |
| 0.396       | 0.396 | 0.000    |        |         |   |       |
| UEC_C10     |       | JUNCTION | 42.23  | 42.23   | 0 | 00:41 |
| 1.15        | 1.15  | 0.000    |        |         |   |       |
| UEC_D10     |       | JUNCTION | 30.73  | 30.73   | 0 | 00:37 |
| 0.718       | 0.718 | 0.000    |        |         |   |       |
| Out.Dr      |       | OUTFALL  | 0.00   | 145.39  | 0 | 00:43 |
| 0           | 3.73  | 0.000    |        |         |   |       |
| Out_C.D     |       | OUTFALL  | 0.00   | 138.35  | 0 | 00:42 |
| 0           | 3.52  | 0.000    |        |         |   |       |
| Out_LC.B.F  |       | OUTFALL  | 0.00   | 3168.16 | 0 | 01:30 |
| 0           | 166   | 0.000    |        |         |   |       |
| Out_LC.G.H  |       | OUTFALL  | 0.00   | 84.02   | 0 | 00:43 |
| 0           | 2.28  | 0.000    |        |         |   |       |
| Out_LC_I    |       | OUTFALL  | 0.00   | 205.82  | 0 | 00:42 |
| 0           | 5.08  | 0.000    |        |         |   |       |
| UEC_Out     |       | OUTFALL  | 0.00   | 457.16  | 0 | 00:47 |
| 0           | 18.6  | 0.000    |        |         |   |       |

\*\*\*\*\*  
Node Flooding Summary  
\*\*\*\*\*

No nodes were flooded.

\*\*\*\*\*  
Outfall Loading Summary  
\*\*\*\*\*

-----

*SWMM Model Proposed – 100 Year*

| Outfall Node | Flow Freq Pcnt | Avg Flow CFS | Max Flow CFS | Total Volume 10 <sup>6</sup> gal |
|--------------|----------------|--------------|--------------|----------------------------------|
| Out.Dr       | 28.37          | 20.33        | 145.39       | 3.727                            |
| Out_C.D      | 25.57          | 21.30        | 138.35       | 3.521                            |
| Out_LC.B.F   | 98.94          | 258.92       | 3168.16      | 165.559                          |
| Out_LC.G.H   | 25.65          | 13.75        | 84.02        | 2.280                            |
| Out_LC_I     | 34.00          | 23.13        | 205.82       | 5.083                            |
| UEC_Out      | 98.62          | 29.17        | 457.16       | 18.593                           |
| System       | 51.86          | 366.61       | 3737.45      | 198.763                          |

\*\*\*\*\*  
 Link Flow Summary  
 \*\*\*\*\*

| Link                     | Type    | Maximum  Flow  CFS | Time of Max Occurrence days hr:min | Maximum  Veloc  ft/sec | Max/Full Flow |
|--------------------------|---------|--------------------|------------------------------------|------------------------|---------------|
| Ch.Dr_A.Main10<br>0.67   | CONDUIT | 106.06             | 0 00:43                            | 5.14                   | 0.46          |
| Ch.LC_A.Main10<br>0.26   | CONDUIT | 275.66             | 0 00:43                            | 7.14                   | 0.08          |
| Ch.LC_A.Side10<br>0.21   | CONDUIT | 25.30              | 0 00:59                            | 3.21                   | 0.05          |
| Ch.LC_A.Side11<br>0.13   | CONDUIT | 27.74              | 0 00:59                            | 6.43                   | 0.02          |
| Ch.LC_B.30<br>0.70       | CONDUIT | 308.91             | 0 00:42                            | 6.26                   | 0.50          |
| Ch.LC_B.Side.120<br>0.52 | CONDUIT | 110.52             | 0 00:44                            | 7.58                   | 0.28          |
| Ch.LC_B.Side.121<br>0.95 | CONDUIT | 147.14             | 0 00:55                            | 1.98                   | 0.91          |
| Ch.LC_B.Side.140<br>0.15 | CONDUIT | 8.40               | 0 00:52                            | 2.51                   | 0.03          |
| Ch.Lc_B.Side.150<br>0.33 | CONDUIT | 52.72              | 0 00:44                            | 6.24                   | 0.13          |
| Ch.LC_B.Side.160<br>0.67 | CONDUIT | 141.27             | 0 00:39                            | 6.94                   | 0.46          |
| Ch.LC_B.Side.90<br>0.64  | CONDUIT | 133.27             | 0 00:40                            | 7.10                   | 0.43          |
| Ch.LC_B.Side.91<br>0.78  | CONDUIT | 262.69             | 0 00:43                            | 10.37                  | 0.61          |
| Ch.LC_B.Side122<br>0.93  | CONDUIT | 267.83             | 0 00:40                            | 8.35                   | 0.86          |



*SWMM Model Proposed – 100 Year*

|      |                 |         |         |   |       |       |      |
|------|-----------------|---------|---------|---|-------|-------|------|
| 0.21 | Ch.LC_B.Side130 | CONDUIT | 42.84   | 0 | 00:51 | 5.38  | 0.05 |
| 0.23 | Ch.LC_B.Side20  | CONDUIT | 318.59  | 0 | 01:10 | 3.55  | 0.09 |
| 0.38 | Ch.LC_B.Side50  | CONDUIT | 228.55  | 0 | 01:04 | 3.69  | 0.16 |
| 0.42 | Ch.LC_B.Side10  | CONDUIT | 383.48  | 0 | 01:12 | 5.44  | 0.20 |
| 0.62 | Ch.LC_D.Main10  | CONDUIT | 79.71   | 0 | 00:40 | 4.34  | 0.39 |
| 0.47 | Ch.LC_D.Main11  | CONDUIT | 58.99   | 0 | 00:43 | 4.56  | 0.24 |
| 0.69 | Ch.LC_G.Main10  | CONDUIT | 58.97   | 0 | 00:42 | 2.75  | 0.49 |
| 0.36 | Ch.LC_H.Main10  | CONDUIT | 25.23   | 0 | 00:40 | 2.69  | 0.15 |
| 0.71 | Ch.LC_I.Main1   | CONDUIT | 120.16  | 0 | 00:43 | 5.41  | 0.52 |
| 0.13 | Ch.OS_B1        | CONDUIT | 7.24    | 0 | 00:42 | 2.53  | 0.02 |
| 0.27 | Ch.OS_B2        | CONDUIT | 32.41   | 0 | 00:43 | 5.03  | 0.09 |
| 0.27 | Ch.OS2          | CONDUIT | 55.14   | 0 | 01:01 | 5.19  | 0.08 |
| 0.16 | Ch.UEC_A.Main10 | CONDUIT | 152.94  | 0 | 01:18 | 2.42  | 0.05 |
| 0.87 | Ch.UEC_A.Main11 | CONDUIT | 228.28  | 0 | 01:11 | 7.76  | 0.76 |
| 0.29 | Ch.UEC_A.Main20 | CONDUIT | 34.72   | 0 | 00:40 | 4.93  | 0.10 |
| 0.28 | Ch.UEC_B        | CONDUIT | 457.16  | 0 | 00:47 | 5.90  | 0.11 |
| 0.12 | Ch.UEC_B.Main10 | CONDUIT | 85.45   | 0 | 00:40 | 5.40  | 0.02 |
| 0.79 | Ch.UEC_B.Side10 | CONDUIT | 283.88  | 0 | 01:07 | 11.05 | 0.63 |
| 0.57 | Ch.UEC_B.Side20 | CONDUIT | 169.58  | 0 | 00:40 | 10.31 | 0.33 |
| 0.51 | Ch.UEC_C.Main10 | CONDUIT | 72.64   | 0 | 00:43 | 5.09  | 0.27 |
| 0.31 | Ch.UEC_D.Main10 | CONDUIT | 30.57   | 0 | 00:41 | 4.00  | 0.11 |
| 0.07 | Ch_1            | CONDUIT | 44.49   | 0 | 01:20 | 2.56  | 0.01 |
| 0.09 | Ch_2            | CONDUIT | 67.44   | 0 | 01:24 | 2.80  | 0.02 |
| 0.27 | Ch_3            | CONDUIT | 364.19  | 0 | 00:47 | 4.67  | 0.10 |
| 0.29 | Ch_4            | CONDUIT | 409.09  | 0 | 00:49 | 4.87  | 0.11 |
| 0.11 | Ch_LC_A10       | CONDUIT | 365.48  | 0 | 00:44 | 7.63  | 0.02 |
| 0.89 | Ch_Main_1       | CONDUIT | 2633.57 | 0 | 01:33 | 8.96  | 0.72 |

*SWMM Model Proposed – 100 Year*

|                         |         |         |   |       |       |      |
|-------------------------|---------|---------|---|-------|-------|------|
| Ch_Main_2<br>0.95       | CONDUIT | 2515.30 | 0 | 01:34 | 6.77  | 0.88 |
| Ch_Main_3<br>0.89       | CONDUIT | 2415.99 | 0 | 01:28 | 10.12 | 0.74 |
| Ch_Main_4<br>0.93       | CONDUIT | 2317.57 | 0 | 01:28 | 8.90  | 0.83 |
| Ch_Main_5<br>0.94       | CONDUIT | 2085.84 | 0 | 01:29 | 7.88  | 0.85 |
| Ch_Main_6<br>0.77       | CONDUIT | 2085.51 | 0 | 01:26 | 7.14  | 0.63 |
| Ch_OS10<br>0.04         | CONDUIT | 2.67    | 0 | 00:44 | 2.01  | 0.00 |
| Ch_OS6<br>0.12          | CONDUIT | 26.09   | 0 | 01:05 | 3.83  | 0.00 |
| Ch_Upper.Main_1<br>0.56 | CONDUIT | 211.84  | 0 | 01:03 | 5.43  | 0.22 |
| Ch_Upper.Main_2<br>0.45 | CONDUIT | 78.62   | 0 | 00:59 | 3.09  | 0.12 |
| Culv_LC_A10<br>0.35     | CONDUIT | 366.35  | 0 | 00:42 | 21.64 | 0.32 |
| Culv_LC_A20<br>0.38     | CONDUIT | 48.69   | 0 | 00:39 | 14.13 | 0.35 |
| Culv_OS1<br>0.69        | CONDUIT | 230.58  | 0 | 00:58 | 14.76 | 0.82 |
| Culv_OS2<br>0.56        | CONDUIT | 55.71   | 0 | 00:54 | 9.76  | 0.61 |
| Culv_OS4<br>0.75        | CONDUIT | 59.67   | 0 | 00:44 | 3.87  | 0.91 |
| Culv_OS6<br>0.23        | CONDUIT | 26.86   | 0 | 00:54 | 10.90 | 0.12 |
| Culv_OS7<br>0.42        | CONDUIT | 25.38   | 0 | 00:55 | 6.83  | 0.36 |
| Culv_OS8<br>0.71        | CONDUIT | 59.06   | 0 | 00:43 | 5.25  | 0.86 |
| Culv_OS9<br>0.73        | CONDUIT | 135.57  | 0 | 01:08 | 8.23  | 0.88 |
| Dummy_Dr_A10            | DUMMY   | 106.35  | 0 | 00:42 |       |      |
| Dummy_Dr_B10            | DUMMY   | 41.35   | 0 | 00:37 |       |      |
| Dummy_LC_A10            | DUMMY   | 89.75   | 0 | 00:35 |       |      |
| Dummy_LC_A20            | DUMMY   | 70.78   | 0 | 00:40 |       |      |
| Dummy_LC_A25            | DUMMY   | 48.69   | 0 | 00:39 |       |      |
| Dummy_LC_A30            | DUMMY   | 202.69  | 0 | 00:36 |       |      |
| Dummy_LC_B10            | DUMMY   | 50.36   | 0 | 01:08 |       |      |
| Dummy_LC_B100           | DUMMY   | 10.11   | 0 | 01:07 |       |      |
| Dummy_LC_B110           | DUMMY   | 65.28   | 0 | 00:41 |       |      |
| Dummy_LC_B120           | DUMMY   | 103.80  | 0 | 00:44 |       |      |
| Dummy_LC_B130           | DUMMY   | 42.94   | 0 | 00:48 |       |      |
| Dummy_LC_B140           | DUMMY   | 46.69   | 0 | 00:39 |       |      |
| Dummy_LC_B150           | DUMMY   | 59.16   | 0 | 00:40 |       |      |
| Dummy_LC_B160           | DUMMY   | 131.96  | 0 | 00:36 |       |      |
| Dummy_LC_B170           | DUMMY   | 8.74    | 0 | 00:42 |       |      |
| Dummy_LC_B180           | DUMMY   | 143.01  | 0 | 00:37 |       |      |
| Dummy_LC_B190           | DUMMY   | 142.63  | 0 | 00:35 |       |      |
| Dummy_LC_B20            | DUMMY   | 71.02   | 0 | 00:54 |       |      |

*SWMM Model Proposed – 100 Year*

|               |         |         |   |       |      |      |
|---------------|---------|---------|---|-------|------|------|
| Dummy_LC_B30  | DUMMY   | 99.79   | 0 | 00:40 |      |      |
| Dummy_LC_B40  | DUMMY   | 210.35  | 0 | 00:39 |      |      |
| Dummy_LC_B50  | DUMMY   | 150.29  | 0 | 00:38 |      |      |
| Dummy_LC_B60  | DUMMY   | 44.51   | 0 | 00:59 |      |      |
| Dummy_LC_B70  | DUMMY   | 154.75  | 0 | 00:46 |      |      |
| Dummy_LC_B80  | DUMMY   | 120.82  | 0 | 00:49 |      |      |
| Dummy_LC_B90  | DUMMY   | 137.94  | 0 | 00:48 |      |      |
| Dummy_LC_C10  | DUMMY   | 79.80   | 0 | 00:39 |      |      |
| Dummy_LC_D10  | DUMMY   | 58.99   | 0 | 00:43 |      |      |
| Dummy_LC_F10  | DUMMY   | 153.24  | 0 | 00:37 |      |      |
| Dummy_LC_F20  | DUMMY   | 21.43   | 0 | 00:54 |      |      |
| Dummy_LC_G10  | DUMMY   | 58.97   | 0 | 00:42 |      |      |
| Dummy_LC_H10  | DUMMY   | 25.24   | 0 | 00:40 |      |      |
| Dummy_LC_I10  | DUMMY   | 87.28   | 0 | 00:39 |      |      |
| Dummy_LC_I20  | DUMMY   | 121.23  | 0 | 00:40 |      |      |
| Dummy_OS_B1   | DUMMY   | 7.25    | 0 | 00:41 |      |      |
| Dummy_OS_B2   | DUMMY   | 32.70   | 0 | 00:41 |      |      |
| Dummy_OS1     | DUMMY   | 230.59  | 0 | 00:58 |      |      |
| Dummy_OS10    | DUMMY   | 2.67    | 0 | 00:44 |      |      |
| Dummy_OS2     | DUMMY   | 55.71   | 0 | 00:54 |      |      |
| Dummy_OS3     | DUMMY   | 1832.34 | 0 | 01:27 |      |      |
| Dummy_OS4     | DUMMY   | 59.67   | 0 | 00:44 |      |      |
| Dummy_OS5     | DUMMY   | 4.20    | 0 | 00:46 |      |      |
| Dummy_OS6     | DUMMY   | 26.86   | 0 | 00:54 |      |      |
| Dummy_OS7     | DUMMY   | 25.38   | 0 | 00:55 |      |      |
| Dummy_OS8     | DUMMY   | 59.07   | 0 | 00:43 |      |      |
| Dummy_OS9     | DUMMY   | 135.58  | 0 | 01:08 |      |      |
| Dummy_UEC_A10 | DUMMY   | 114.80  | 0 | 00:43 |      |      |
| Dummy_UEC_A20 | DUMMY   | 34.76   | 0 | 00:39 |      |      |
| Dummy_UEC_B   | DUMMY   | 91.59   | 0 | 00:40 |      |      |
| Dummy_UEC_B20 | DUMMY   | 100.29  | 0 | 00:38 |      |      |
| Dummy_UEC_B30 | DUMMY   | 66.13   | 0 | 00:36 |      |      |
| Dummy_UEC_B40 | DUMMY   | 23.06   | 0 | 00:36 |      |      |
| Dummy_UEC_C10 | DUMMY   | 42.23   | 0 | 00:41 |      |      |
| Dummy_UEC_D10 | DUMMY   | 30.73   | 0 | 00:37 |      |      |
| Over.Dr_B     | CONDUIT | 145.39  | 0 | 00:43 | 3.96 | 0.06 |
| 0.18          |         |         |   |       |      |      |
| Over.LC.G     | CONDUIT | 84.02   | 0 | 00:43 | 2.82 | 0.04 |
| 0.15          |         |         |   |       |      |      |
| Over.LC_B     | CONDUIT | 3134.31 | 0 | 01:31 | 5.84 | 0.68 |
| 0.80          |         |         |   |       |      |      |
| Over.LC_D     | CONDUIT | 138.35  | 0 | 00:42 | 2.10 | 0.16 |
| 0.33          |         |         |   |       |      |      |
| Over.LC_F     | CONDUIT | 151.72  | 0 | 00:39 | 2.90 | 0.11 |
| 0.26          |         |         |   |       |      |      |
| Over_LC_A25   | CONDUIT | 48.53   | 0 | 00:41 | 3.41 | 0.45 |
| 0.62          |         |         |   |       |      |      |
| Over_OS4      | CONDUIT | 45.43   | 0 | 01:04 | 2.19 | 0.01 |
| 0.04          |         |         |   |       |      |      |
| Over_OS5      | CONDUIT | 2.80    | 0 | 01:30 | 0.93 | 0.00 |
| 0.01          |         |         |   |       |      |      |
| Over_OS8_1    | CONDUIT | 54.34   | 0 | 00:55 | 1.50 | 0.02 |
| 0.09          |         |         |   |       |      |      |

SWMM Model Proposed – 100 Year

|                       |         |        |   |       |       |      |
|-----------------------|---------|--------|---|-------|-------|------|
| Pipe.LC_A.20<br>0.69  | CONDUIT | 205.85 | 0 | 00:42 | 9.97  | 0.83 |
| Pipe.LC_B.110<br>0.64 | CONDUIT | 65.24  | 0 | 00:41 | 13.63 | 0.74 |
| Pipe.LC_B.120<br>0.63 | CONDUIT | 476.24 | 0 | 00:46 | 25.35 | 0.72 |
| Pipe.LC_B.40<br>0.54  | CONDUIT | 210.23 | 0 | 00:40 | 19.46 | 0.57 |
| Pipe.LC_B.70<br>0.79  | CONDUIT | 154.74 | 0 | 00:46 | 14.61 | 0.96 |
| Pipe.LC_B.80<br>0.70  | CONDUIT | 120.81 | 0 | 00:49 | 22.92 | 0.83 |
| Pipe.LC_F.10<br>0.76  | CONDUIT | 326.45 | 0 | 00:45 | 5.93  | 0.59 |
| Pipe.LC_I<br>0.62     | CONDUIT | 205.82 | 0 | 00:42 | 11.23 | 0.70 |
| Pipe.UEC_B.30<br>0.47 | CONDUIT | 66.13  | 0 | 00:36 | 20.42 | 0.44 |
| Pipe.UEC_B40<br>0.43  | CONDUIT | 23.06  | 0 | 00:36 | 7.87  | 0.39 |

\*\*\*\*\*  
Conduit Surcharge Summary  
\*\*\*\*\*

No conduits were surcharged.

Analysis begun on: Mon Dec 16 16:33:51 2024  
Analysis ended on: Mon Dec 16 16:33:52 2024  
Total elapsed time: 00:00:01



## Appendix D

# Pond Calculations




## Appendix E

# Culvert Calculations



## Appendix F Site Drainage Maps



### LEGEND

- SITE BOUNDARY
- ROADWAYS
- PROPOSED TRAILS
- EXISTING DRAINAGE
- DRAINAGE WETLAND
- LOW DENSITY
- MEDIUM DENSITY
- MED-HIGH DENSITY
- HIGH DENSITY
- COMMERCIAL
- BUSINESS PARK
- SCHOOL
- HOTEL
- DETENTION POND
- PARK/POCKET PARK
- DETENTION POND
- ENTRY SIGNAGE

| LAND USE SUMMARY                     |                  |               |               |       |            |      |
|--------------------------------------|------------------|---------------|---------------|-------|------------|------|
| LAND USE CATEGORY                    | ACREAGE          | SITE PERCENT  | DENSITY RANGE |       | UNIT RANGE |      |
| RESIDENTIAL PARCELS                  |                  |               |               |       |            |      |
| LOW DENSITY RESIDENTIAL              | 137.1 AC.        | 7.5%          | 1.00          | 2.99  | 137        | 410  |
| MEDIUM DENSITY RESIDENTIAL           | 466.7 AC.        | 25.6%         | 3.00          | 4.99  | 1400       | 2329 |
| MED-HIGH DENSITY RESIDENTIAL         | 119.7 AC.        | 6.6%          | 5.00          | 7.99  | 599        | 956  |
| HIGH DENSITY RESIDENTIAL             | 81.6 AC.         | 4.5%          | 8.00          | 14.00 | 653        | 1142 |
| <b>RESIDENTIAL PARCELS SUB-TOTAL</b> | <b>805.1 AC.</b> | <b>44.2%</b>  |               |       | 2789       | 4838 |
| NON-RESIDENTIAL PARCELS              |                  |               |               |       |            |      |
| COMMERCIAL                           | 34.2 AC.         | 1.9%          |               |       |            |      |
| BUSINESS PARKS                       | 479.9 AC.        | 26.3%         |               |       |            |      |
| SCHOOLS                              | 92.6 AC.         | 5.1%          |               |       |            |      |
| MIXED-USE                            | 22.9 AC.         | 1.3%          |               |       |            |      |
| <b>NON-RESIDENTIAL SUB-TOTAL</b>     | <b>629.6 AC.</b> | <b>34.5%</b>  |               |       |            |      |
| ROAD RIGHT-OF-WAY (MAJOR ROADS)      | 73.2 AC.         | 4.0%          |               |       |            |      |
| PARKS/POCKET PARKS                   | 17.5 AC.         | 1.0%          |               |       |            |      |
| TOTAL OPEN SPACE                     | 297.0 AC.        | 16.3%         |               |       |            |      |
| <b>TOTAL</b>                         | <b>1822.4 AC</b> | <b>100.0%</b> |               |       | 2789       | 4838 |

NOTE - OPEN SPACE INCLUDES: DETENTION, DRAINAGE CORRIDORS, GENERAL OPEN SPACE, AND EASEMENTS.



## SKETCH PLAN



# FLYING HORSE EAST

### EL PASO COUNTY, COLORADO



J:\2024\12\10\24\CAD\Drawings\concept\wpd.dwg Saved: Dec 18, 24 2:56 PM Plotter: ...





VICINITY MAP

LEGEND:


- EXISTING MAJOR CONTOUR ——— 5250 ———
- EXISTING MINOR CONTOUR - - - - -
- EXISTING CULVERT
- DIRECTIONAL FLOW ARROW
- EMERGENCY OVERFLOW ARROW
- MAJOR BASIN LINE
- 100YR ZONE A FLOODPLAIN
- SWMM CONVEYANCE ELEMENT
- OUTFALL
- DESIGN POINT
- PROPOSED BASIN LABEL 

|    |
|----|
| XX |
| XX |

 BASIN DESIGNATION
- AREA (AC.) 

|    |    |
|----|----|
| XX | XX |
|----|----|

 IMPERVIOUSNESS



please label FEMA floodplain, typical per DCMV1 4.2

DRAWN BY: FM JOB DATE: 2024  
 APPROVED: WML JOB NUMBER: 2402059.3  
 CAD DATE: 12/19/2024 1:08:02 PM  
 CAD FILE: J:\2024\2402059.3\CAD\Dwgs\C\EXISTING\_WATERSHED.dwg


| NO. | DATE | BY | REVISION DESCRIPTION |
|-----|------|----|----------------------|
|     |      |    |                      |




FLYING HORSE EAST MDDP  
 FLYING HORSE DEVELOPMENT, LLC  
 COLORADO SPRINGS, CO

EXISTING DRAINAGE MAP

SHEET NO.  
 EX1



| SUBBASIN ID | DESIG POINTS | 5-YEAR FLOWRATE (CFS) | 100-YEAR FLOWRATE (CFS) |
|-------------|--------------|-----------------------|-------------------------|
| OS1         | DP-OS1       | 9.22                  | 230.99                  |
| OS2         | DP-OS2       | 6.00                  | 55.02                   |
| OS3         | DP-OS3       | 82.90                 | 1831.23                 |
| OS4         | DP-OS4       | 1.62                  | 59.67                   |
| OS5         | DP-OS5       | 0.15                  | 4.20                    |
| OS6         | DP-OS6       | 0.43                  | 26.86                   |
| OS7         | DP-OS7       | 1.88                  | 25.47                   |
| OS8         | DP-OS8       | 3.86                  | 58.70                   |
| OS9         | DP-OS9       | 4.20                  | 136.42                  |
| LC-A10      | OUT-LC-A10   | 1.42                  | 62.55                   |
| LC-A20      | OUT-LC-A20   | 0.26                  | 11.42                   |
| LC-B        | OUT-LC-B     | 9.42                  | 698.54                  |
| LC-C        | OUT-LC-C     | 0.39                  | 26.19                   |
| LC-D        | OUT-LC-D     | 1.21                  | 25.11                   |
| LC-E        | OUT-LC-E     | 1.45                  | 31.60                   |
| LC-F        | OUT-LC-F     | 1.44                  | 111.12                  |
| LC-G        | OUT-LC-G     | 0.28                  | 21.94                   |
| LC-H        | OUT-LC-H     | 0.26                  | 18.92                   |
| LC-I        | OUT-LC-I     | 0.77                  | 61.26                   |
| UEC-A       | OUT-UEC-A    | 1.04                  | 49.42                   |
| UEC-B       | OUT-UEC-B    | 0.96                  | 87.55                   |
| UEC-C       | OUT-UEC-C    | 0.13                  | 12.30                   |
| UEC-D       | OUT-UEC-D    | 0.73                  | 15.19                   |
| DR-A        | OUT-DR-A     | 0.44                  | 37.13                   |
| DR-B        | OUT-DR-B     | 0.22                  | 17.72                   |



VICINITY MAP

LEGEND:

- EXISTING MAJOR CONTOUR ——— 5250 ———
- EXISTING MINOR CONTOUR - - - - -
- EXISTING CULVERT
- DIRECTIONAL FLOW ARROW
- EMERGENCY OVERFLOW ARROW
- MAJOR BASIN LINE
- 100YR ZONE A FLOODPLAIN
- SWMM CONVEYANCE ELEMENT
- OUTFALL
- DESIGN POINT
- PROPOSED BASIN LABEL 

|    |
|----|
| XX |
| XX |
| XX |

 BASIN DESIGNATION  
AREA (AC.) 

|    |
|----|
| XX |
| XX |
| XX |

 IMPERVIOUSNESS

PLAN  
SCALE: 0 400 800  
NORTH

DRAWN BY: FM  
APPROVED: WML  
CAD DATE: 12/19/2024 1:08:02 PM  
CAD FILE: J:\2024\2402059.3\CAD\Dwgs\C\EXISTING\_WATERSHED.dwg

JOB DATE: 2024  
JOB NUMBER: 2402059.3

BAR IS ONE INCH ON OFFICIAL DRAWINGS.  
IF NOT ONE INCH, ADJUST SCALE ACCORDINGLY.

| NO. | DATE | BY | REVISION DESCRIPTION |
|-----|------|----|----------------------|
|     |      |    |                      |
|     |      |    |                      |
|     |      |    |                      |





FLYING HORSE EAST MDDP  
FLYING HORSE DEVELOPMENT, LLC  
COLORADO SPRINGS, CO

EXISTING DRAINAGE MAP

SHEET NO.  
EX2

Xref: xgl-1-dm01: FEL\_SURFACE



VICINITY MAP

LEGEND:

- EXISTING MAJOR CONTOUR ——— 5250 ———
- EXISTING MINOR CONTOUR - - - - -
- EXISTING CULVERT
- DIRECTIONAL FLOW ARROW
- EMERGENCY OVERFLOW ARROW
- MAJOR BASIN LINE
- 100YR ZONE A FLOODPLAIN
- SWMM CONVEYANCE ELEMENT
- OUTFALL
- DESIGN POINT
- PROPOSED BASIN LABEL 

|    |
|----|
| XX |
| XX |

 BASIN DESIGNATION
- AREA (AC.) 

|    |    |
|----|----|
| XX | XX |
|----|----|


 IMPERVIOUSNESS

Identify the total flow at outfalls leaving the site.

please show the proposed location of the full spectrum ponds

Please provide a boundary line to delineate the three drainage basins (upper east chico, drennan, and livestock)

please show proposed roadway locations



DRAWN BY: FM JOB DATE: 2024  
 APPROVED: WML JOB NUMBER: 2402059.3  
 CAD DATE: 12/19/2024 5:41:40 PM  
 CAD FILE: J:\2024\2402059.3\CAD\Dwgs\C\PROPOSED\_WATERSHED.dwg


| NO. | DATE | BY | REVISION DESCRIPTION |
|-----|------|----|----------------------|
|     |      |    |                      |



FLYING HORSE EAST MDDP  
 FLYING HORSE DEVELOPMENT, LLC  
 COLORADO SPRINGS, CO


PROPOSED DRAINAGE MAP

SHEET NO.  
 PR1



| SUBBASIN ID | DESIG POINTS | 5-YEAR FLOWRATE (CFS) | 100-YEAR FLOWRATE (CFS) |
|-------------|--------------|-----------------------|-------------------------|
| OS1         | DF-OS1       | 9.17                  | 230.59                  |
| OS2         | DF-OS2       | 8.27                  | 55.71                   |
| OS3         | DF-OS3       | 83.24                 | 1832.34                 |
| OS4         | DF-OS4       | 1.62                  | 59.67                   |
| OS5         | DF-OS5       | 0.15                  | 4.20                    |
| OS6         | DF-OS6       | 0.43                  | 26.86                   |
| OS7         | DF-OS7       | 1.84                  | 25.38                   |
| OS8         | DF-OS8       | 4.08                  | 54.07                   |
| OS9         | DF-OS9       | 3.80                  | 135.58                  |
| OS10        | DF-OS10      | 0.95                  | 2.67                    |
| OS-B1       | DF-OS-B1     | 0.08                  | 7.25                    |
| OS-B2       | DF-OS-B2     | 0.59                  | 32.70                   |

| SUBBASIN ID | DESIG POINTS | 5-YEAR FLOWRATE (CFS) | 100-YEAR FLOWRATE (CFS) |
|-------------|--------------|-----------------------|-------------------------|
| LC-A10      | OUT-LC-A10   | 31.12                 | 89.75                   |
| LC-A20      | DF-LC-A20    | 22.05                 | 70.78                   |
| LC-A25      | OUT-LC-A25   | 16.06                 | 48.69                   |
| LC-A30      | DF-LC-A30    | 50.19                 | 202.69                  |
| LC-B10      | OUT-LC-B     | 1.17                  | 59.36                   |
| LC-E20      | DF-LC-E20    | 8.45                  | 71.02                   |
| LC-E30      | DF-LC-E30    | 20.33                 | 99.79                   |
| LC-B40      | DF-LC-B40    | 68.69                 | 210.35                  |
| LC-B50      | DF-LC-B50    | 40.74                 | 150.29                  |
| LC-B60      | DF-LC-B60    | 2.14                  | 44.51                   |
| LC-B70      | DF-LC-B70    | 34.93                 | 154.75                  |
| LC-B80      | DF-LC-B80    | 24.60                 | 120.82                  |
| LC-B90      | DF-LC-B90    | 29.93                 | 137.94                  |
| LC-B100     | DF-LC-B100   | 0.25                  | 10.11                   |
| LC-B110     | DF-LC-B110   | 14.08                 | 65.28                   |
| LC-B120     | DF-LC-B120   | 19.04                 | 103.80                  |
| LC-B130     | DF-LC-B130   | 12.69                 | 42.94                   |
| LC-B140     | DF-LC-B140   | 11.79                 | 46.69                   |
| LC-B150     | DF-LC-B150   | 13.18                 | 59.16                   |
| LC-B160     | DF-LC-B160   | 30.50                 | 131.96                  |
| LC-B170     | DF-LC-B170   | 1.71                  | 8.74                    |
| LC-B180     | DF-LC-B180   | 31.29                 | 143.01                  |
| LC-B190     | DF-LC-B190   | 41.78                 | 142.63                  |
| LC-C10      | OUT-LC-C     | 20.27                 | 79.80                   |
| LC-D10      | OUT-LC-D     | 11.34                 | 58.99                   |
| LC-F10      | OUT-LC-F     | 48.28                 | 153.24                  |
| LC-F20      | DF-LC-F20    | 1.65                  | 21.43                   |
| LC-G10      | OUT-LC-G10   | 18.87                 | 58.97                   |
| LC-H10      | OUT-LC-H10   | 5.22                  | 25.24                   |
| LC-I10      | DF-LC-I      | 25.93                 | 87.28                   |
| LC-I20      | DF-LC-I20    | 35.85                 | 121.23                  |
| UEC-A10     | DF-UEC-A10   | 32.34                 | 114.80                  |
| UEC-A20     | OUT-UEC-A    | 8.92                  | 34.76                   |
| UEC-B10     | DF-UEC-B10   | 24.45                 | 91.59                   |
| UEC-B20     | DF-UEC-B20   | 30.59                 | 100.29                  |
| UEC-B30     | DF-UEC-B30   | 20.75                 | 66.13                   |
| UEC-B40     | DF-UEC-B40   | 4.99                  | 23.06                   |
| UEC-C10     | DF-UEC-C10   | 12.08                 | 42.23                   |
| UEC-D10     | DF-UEC-D10   | 9.12                  | 30.73                   |
| Dr-A10      | OUT-Dr-A10   | 31.27                 | 106.35                  |
| Dr-B10      | OUT-Dr-B10   | 11.07                 | 41.35                   |



VICINITY MAP

LEGEND:

- EXISTING MAJOR CONTOUR ——— 5250 ———
- EXISTING MINOR CONTOUR - - - - -
- EXISTING CULVERT
- DIRECTIONAL FLOW ARROW
- EMERGENCY OVERFLOW ARROW
- MAJOR BASIN LINE
- 100YR ZONE A FLOODPLAIN
- SWMM CONVEYANCE ELEMENT
- OUTFALL
- DESIGN POINT
- PROPOSED BASIN LABEL BASIN DESIGNATION
- AREA (AC.) IMPERVIOUSNESS

PLAN  
SCALE: 0 800'  
400'

NORTH

DRAWN BY: FM  
APPROVED: WML  
CAD DATE: 12/19/2024 5:41:40 PM  
CAD FILE: J:\2024\2402059.3\CAD\Dwgs\C\PROPOSED\_WATERSHED.dwg

JOB DATE: 2024  
JOB NUMBER: 2402059.3

BAR IS ONE INCH ON OFFICIAL DRAWINGS.  
IF NOT ONE INCH, ADJUST SCALE ACCORDINGLY.

| NO. | DATE | BY | REVISION DESCRIPTION |
|-----|------|----|----------------------|
|     |      |    |                      |
|     |      |    |                      |
|     |      |    |                      |



FLYING HORSE EAST MDDP  
FLYING HORSE DEVELOPMENT, LLC  
COLORADO SPRINGS, CO

PROPOSED DRAINAGE MAP

SHEET NO.  
PR2