

# SP19006-R3-GEC-redlines Summary

---

2 (1)

---



**Subject:** Engineer  
**Page Index:** 2  
**Date:** 4/9/2020 1:09:55 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 2 GRADING & EROSION CONTROL NOTES  
& LEGEND

update text

---

4 (1)

---




**Subject:** Engineer  
**Page Index:** 4  
**Date:** 4/9/2020 12:40:39 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [4] 4 ER01

Add note about existing vegetation

---

7 (1)

---




**Subject:** Engineer  
**Page Index:** 7  
**Date:** 4/9/2020 11:16:44 AM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 7 ER04

call out channel stabilization

---

11 (1)

---




**Subject:** Engineer  
**Page Index:** 11  
**Date:** 4/9/2020 12:28:46 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [11] 11 ER08

Show Curtis Rd on key

---

12 (1)

---



**Subject:** Engineer  
**Page Index:** 12  
**Date:** 4/9/2020 1:27:03 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [12] 12 DT01

Provide Pond details, including forebay details,  
outlet structure details, spillway details, etc.

# SP19006-R3-SWMP-redlines.pdf Markup Summary

1 (1)



**Subject:** Engineer  
**Page Index:** 1  
**Date:** 4/9/2020 8:07:29 AM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 1


Item 1. Change this to To Be Determined. The SWMP Admin can be under the contractor but will likely be a different contact than the main contractor contact

4 (2)



**Subject:** Engineer  
**Page Index:** 4  
**Date:** 4/9/2020 8:07:05 AM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 4

Item 1. Change this to To Be Determined. The SWMP Admin can be under the contractor but will likely be a different contact than the main contractor contact



**Subject:** Engineer  
**Page Index:** 4  
**Date:** 4/9/2020 8:18:16 AM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 4

Item 9. Include method used to determine ground cover (i.e., visual, aerial inspection)

5 (1)



**Subject:** Engineer  
**Page Index:** 5  
**Date:** 4/9/2020 10:47:09 AM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 5

update