

Prevent • Promote • Protect

Environmental Health Division 1675 W. Garden of the Gods Road Suite 2044 Colorado Springs, CO 80907 (719) 578-3199 *phone* (719) 578-3188 *fax* **www.elpasocountyhealth.org**

14725 Trigger Road, AL-23-20

Please accept the following comments from El Paso County Public Health (EPCPH) for the project referenced above:

- Water service for the existing house is by an individual private well.
- Wastewater service for the existing house is an onsite wastewater treatment system (OWTS) permitted, installed, and approved in 2019 for a 4-bedroom house.
- The planned second house will require full compliance with the El Paso County Public Health Onsite Wastewater Treatment System Regulations.

Mike McCarthy El Paso County Public Health 719.575.8602 <u>mikemccarthy@elpasoco.com</u> 06Oct2023