



June 1, 2023

Lekishia Bellamy
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (MVEA)

To El Paso County:

MVEA has these comments about the following:

Project Name: Paint Brush Hills Metro District - Pumphouse 6
Project Number: PPR2318
Description: Proposed development of a pumphouse located at Keynes Dr. in Township 12S, Range 65W, Section 26.

This area is within the MVEA's certificated service area. MVEA will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

MVEA has existing facilities near and within this parcel of land. If there is any damage, removal or relocation of facilities it will be at the expense of the applicant. If any electrical upgrades are needed, please contact our office.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry

Gina Perry
Engineering Coordinator

This Association is an equal opportunity provider and employer.