



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Woodmen Hills Metropolitan District Arroya Water Tanks Site, EX-20-3

Please accept the following comments from El Paso County Public Health for the subdivision exemption referenced above:

- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basins must have mosquito control included as a part of the construction design and maintenance plan to help control mosquito breeding areas and minimize the potential for West Nile Virus.
- The water storage tanks must comply with the design criteria established by the Colorado Department of Public Health and Environment, Water Quality Control Division.

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
26May2020