## Stormwater Detention and Infiltration Design Data Sheet

SDI-Design Data v2.00, Released January 2020

### Stormwater Facility Name: Sterling Ranch East Filing No. 2 FOURSQURE AT STERLING RANCH EAST - Pond 16

## Facility Location & Jurisdiction: Sterling Ranch Metropolitan District - Private Facility

#### User Input: Watershed Characteristics Extended Detention Basin (EDB) EDB 220.90 Watershed Area = acres 4,000 Watershed Length = ft Watershed Length to Centroid = 2,000 ft Watershed Slope = 0.040 ft/ft Watershed Imperviousness = 49.3% percent Percentage Hydrologic Soil Group A = 75.0% percent 25.0% Percentage Hydrologic Soil Group B = percent 0.0% Percentage Hydrologic Soil Groups C/D = percent Target WQCV Drain Time = 40.0 hours Location for 1-hr Rainfall Depths (use dropdown): User Input

After providing required inputs above including 1-hour rainfall depths, click 'Run CUHP' to generate runoff hydrographs using the embedded Colorado Urban Hydrograph Procedure.

Once CUHP has been run and the Stage-Area-Discharge information has been provided, click 'Process Data' to interpolate the Stage-Area-Volume-Discharge data and generate summary results in the table below. Once this is complete, click 'Print to PDF'.

User Defined	User Defined	User Defined	User Defined	
Stage [ft]	Area [ft^2]	Stage [ft]	Discharge [cfs]	
0.00	1,027	0.00	0.00	
0.50	1,027	0.50	0.24	
2.50	18,288	2.50	0.53	
4.50	54,450	4.50	1.37	
6.50	89,516	6.50	2.44	
8.50	106,783	8.50	3.66	
10.50	185,108	10.50	31.93	
12.50	263,928	12.50	124.11	
14.50	343,298	14.50	1656.79	

After completing and printing this worksheet to a pdf, go to: <u>https://maperture.digitaldataservices.com/gvh/?viewer=cswdif</u> Create a new stormwater facility, and attach the PDF of this worksheet to that record.

## Routed Hydrograph Results

							-
Design Storm Return Period =	WQCV	2 Year	5 Year	10 Year	50 Year	100 Year	
One-Hour Rainfall Depth =	N/A	1.19	1.50	1.75	2.25	2.52	in
CUHP Runoff Volume =	3.762	9.710	12.839	15.865	25.112	30.660	acre-ft
Inflow Hydrograph Volume =	N/A	9.710	12.839	15.865	25.112	30.660	acre-ft
Time to Drain 97% of Inflow Volume =	42.1	64.1	67.1	66.3	63.1	61.0	hours
Time to Drain 99% of Inflow Volume =	44.8	69.8	74.0	74.5	73.7	72.6	hours
Maximum Ponding Depth =	5.63	8.19	9.14	9.77	11.20	11.92	ft
Maximum Ponded Area =	1.70	2.39	3.01	3.58	4.86	5.52	acres
Maximum Volume Stored =	3.781	9.140	11.637	13.715	19.722	23.513	acre-ft

# Stormwater Detention and Infiltration Design Data Sheet

