



# HAMMERS CONSTRUCTION, INC.

1411 Woolsey Heights I Colorado Springs, Colorado 80915-5400  
(719) 570-1599 I FAX (719) 570-7008 I [www.hammersconstruction.com](http://www.hammersconstruction.com)

I **SPECIALIZING IN DESIGN / BUILD** I

*Steve Hammers, President*  
*shammers@hammersconstruction.com*

## Drainage Report

### Plot Plan

Drainage report has been removed as it is not required since we are under an acre. We will take consideration of the comments provided during installation.

A final drainage report is required to be submitted even though the overall development is less than one acre. Please resubmit the final drainage report and address all comments in the first submittal.