

APPROVED

DENIED

BY ELC DATE 9/7/17  
FOR 21007 Retaining Wall  
NOTES Change

EL PASO COUNTY  
PLANNING AND COMMUNITY DEVELOPMENT

These retaining walls are not shown on the originally approved site plan. Please indicate the height of the retaining walls. Retaining walls that are greater than or equal to 4 feet in height require a design by a professional engineer and building permit from Regional Building Department.

PLAT #2369

24 R

1002712

Mimi Cough  
11280 Calle Corvo  
TAX ID # 761100202  
Red Rock Valley Est  
Lot 23 Block 5  
ADD 17554  
Plat 2369  
A-5

House

Footprint

023

23

RETAINING WALLS

022

22

An access permit must be granted by the Planning and Community Development Engineering Division prior to the establishment of any driveway onto a County Road.

Diversion of blockage of any drainageway is not permitted without the approval of the Planning and Community Development Engineering Division.

Any approval given by El Paso County does not obviate the need to comply with applicable Federal, State or Local laws and/or regulations.

DESOCIP Not Required  
by ELC on 9/7/17

Please provide dimensions for the proposed parking area shown.

