



Construction Drawings_V2.pdf Markup Summary 12-7-2021

EPC Stormwater - Glenn Reese (4)



Author: EPC Stormwater - Glenn Reese
Subject: Contractor
Page Label: 5
Date: 12/2/2021 11:44:13 AM
Status:
Color: ■
Layer:
Space:

Label TSB B on the plan (assuming it corresponds to EDB B. And what about the other two TSB's onsite? Add a row to this table for each of them.



Author: EPC Stormwater - Glenn Reese
Subject: Contractor
Page Label: 6
Date: 12/2/2021 11:56:13 AM
Status:
Color: ■
Layer:
Space:

Note on page 96 of the FDR, a well screen is recommended for the orifice diameters specified. This bar-type of trash rack will allow large debris (>1.5") between trash rack and orifice place causing orifice to clog more frequently than a well screen.



Author: EPC Stormwater - Glenn Reese
Subject: Contractor
Page Label: 6
Date: 12/2/2021 11:58:29 AM
Status:
Color: ■
Layer:
Space:

Specify installation instructions and mix ratio for soil riprap. As an example, note: "Per MHFD Spec Section 31-37-00, the soil material shall be native or topsoil and mixed with 65% riprap and 35% soil by volume. And soil riprap shall consist of uniform mixture of soil and riprap without voids." And specify the riprap designation per Table 1 of the same spec.



Author: EPC Stormwater - Glenn Reese
Subject: Contractor
Page Label: 6
Date: 12/2/2021 12:00:31 PM
Status:
Color: ■
Layer:
Space:

clarify that this ramp is to be gravel.