

**OFFICE OF THE STATE ENGINEER**  
**COLORADO DIVISION OF WATER RESOURCES**  
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

**WELL PERMIT NUMBER** 292157 - A  
DIV. 2    WD 10    DES. BASIN    MD

APPLICANT

Lot: 1-2 Block: 52 Filing: Subdiv: BRENTWOOD COUNTRY CLUB & CABIN SITES

MEGAN BUCY  
C/O BARNHART PUMP CO  
5015 BLANEY RD E  
PEYTON, CO 80831-

(719) 495-2912

APPROVED WELL LOCATION

EL PASO COUNTY  
SW 1/4 NW 1/4 Section 8  
Township 12 S Range 65 W Sixth P.M.

DISTANCES FROM SECTION LINES

2375 Ft. from North    Section Line  
121 Ft. from West    Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: 525960    Northing: 4319129

**PERMIT TO CONSTRUCT A WELL**

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(c) for the relocation of an existing well, permit no. 292157. The old well must be plugged in accordance with Rule 16 of the Water Well Construction Rules within ninety-one (91) days of completion of the new well. The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was plugged.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than one (1) single family dwelling, the irrigation of not more than 3,000 square feet of home gardens and lawns, and the watering of domestic animals and poultry. This well is to be located on a 0.94 acre parcel of land described as lots 1-2 & 5-6, block 52, Brentwood Country Club & Cabin Sites, El Paso County.
- 5) The total depth of the well shall not exceed 670 feet, which corresponds to the base of the Dawson aquifer. At a minimum, plain casing shall be installed and grouted through all unconsolidated materials and shall extend a minimum of ten feet into the bedrock formation to prevent production from other zones.
- 6) The pumping rate of this well shall not exceed 15 GPM.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.


NOTICE: This permit has been approved for {change-type?}- You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)


NOTE: To ensure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Test Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTE: The Notice to Appeal, above, should reference the following change: the approved well location was determined by applying a move of 40' east from the location of existing permit no. 292157 (CRF 8/21/2013)

APPROVED  
CRF

  
State Engineer

  
By

Receipt No. 3661210B

DATE ISSUED    08-01-2013

EXPIRATION DATE    08-01-2015