


ENG-SP20008-R4-GEC-redlines.pdf Markup Summary


2 (1)



Subject: Text Box
Page Index: 2
Date: 12/1/2021 5:53:45 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [2] 2 GR_01 - GR01


Section B-B?

3 (3)




Subject: Text Box
Page Index: 3
Date: 12/1/2021 5:53:22 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [3] 3 GR_01 - GR02

Section A-A?



Subject: Callout
Page Index: 3
Date: 12/12/2021 3:54:23 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [3] 3 GR_01 - GR02


A drainage easement will be required. Will the lots be buildable/sellable if grading to the north is not completed by the time of lot sale?



Subject: Callout
Page Index: 3
Date: 12/12/2021 3:59:06 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [3] 3 GR_01 - GR02


Additional protection at the bottom is required

4 (3)




Subject: Callout
Page Index: 4
Date: 12/1/2021 5:34:25 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [4] 4 GR_02 SRR and BGP - GESC (1)

don't show curb and gutter and medians...Commented grading had been updated but looks the same.



Subject: Callout
Page Index: 4
Date: 12/1/2021 5:36:26 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [4] 4 GR_02 SRR and BGP - GESC (1)


Add note that flows will continue to Sed Basin 2



Subject: Callout
Page Index: 4
Date: 12/12/2021 4:01:18 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [4] 4 GR_02 SRR and BGP - GESG (1)


See PDR comments. If Briargate will be constructed the culverts should have adequate capacity.

6 (2)



Subject: Callout
Page Index: 6
Date: 12/1/2021 5:46:16 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [6] 6 GR_02 SRR and BGP - GESG (3)


Add note that flows will continue to Sed Basin 2



Subject: Text Box
Page Index: 6
Date: 12/1/2021 5:51:15 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [6] 6 GR_02 SRR and BGP - GESG (3)


Section D-D?

7 (3)




Subject: Callout
Page Index: 7
Date: 12/1/2021 5:49:29 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [7] 7 GR_02 SRR and BGP - GESG (4)

Any bedding under riprap?



Subject: Text Box
Page Index: 7
Date: 12/1/2021 5:50:53 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [7] 7 GR_02 SRR and BGP - GESG (4)

Section C-C?



Subject: Callout
Page Index: 7
Date: 12/12/2021 4:06:51 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [7] 7 GR_02 SRR and BGP - GESG (4)

Additional protection at the bottom is required