

ENG-SP20008-R4-PrelimPlan-redlines.pdf Markup Summary

1 (1)



NO COMMENTS from Planning

Subject: Text Box
Page Index: 1
Date: 12/8/2021 8:21:11 AM
Author: dsdparsons
Color: ■
Layer:
Space:
Page Label: [1] Sheet 1

NO COMMENTS from Planning

3 (4)



Subject: Callout
Page Index: 3
Date: 12/1/2021 4:47:24 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 3 ADJ Owners

Is a continuous accel-decel lane being provided?



Subject: Callout
Page Index: 3
Date: 12/1/2021 4:45:35 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 3 ADJ Owners

Show and label ROW dedication.




Subject: Callout
Page Index: 3
Date: 12/1/2021 4:47:50 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 3 ADJ Owners

These lanes/transitions don't make sense. Show the ultimate road.




Subject:
Page Index: 3
Date: 12/12/2021 12:14:43 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 3 ADJ Owners

4 (13)




Subject: Image
Page Index: 4
Date: 12/6/2021 10:02:08 AM
Author: dsdparsons
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4




Subject: Callout
Page Index: 4
Date: 12/12/2021 12:17:22 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

Label as Existing or proposed ROW




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:24:09 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

101.70 ft




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:25:34 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

41.68 ft




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:25:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

60'-0"




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:28:01 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

100.00 ft




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:27:54 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

40.00 ft




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:27:40 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

60'-0"




Subject: Callout
Page Index: 4
Date: 12/12/2021 12:44:31 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

Label existing 60' and proposed ROW widths and lane widths



Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:38:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

74.00 ft




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:42:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

12'-0"




Subject: Callout
Page Index: 4
Date: 12/12/2021 12:45:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4

These lanes/transitions don't make sense. Show the ultimate road.




Subject: Length Measurement
Page Index: 4
Date: 12/12/2021 12:44:02 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 4


16'-0"




Subject: Dimension
Page Index: 6 50.00'
Date: 12/1/2021 4:55:27 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 6




Subject: Callout
Page Index: 6 Show 15' maintenance access roads on each side of channel
Date: 12/1/2021 4:57:55 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 6




Subject: Length Measurement
Page Index: 6 43.0 ft
Date: 12/12/2021 12:55:27 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 6




Subject:
Page Index: 6
Date: 12/12/2021 12:56:07 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 6




Subject: Callout
Page Index: 6 Lanes don't make sense
Date: 12/12/2021 12:56:21 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 6



Subject: Length Measurement
Page Index: 7 28.04 ft
Date: 12/12/2021 12:59:38 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 7




Subject: Length Measurement
Page Index: 7 12.00 ft
Date: 12/12/2021 12:59:10 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 7



Subject: Length Measurement
Page Index: 7 130'-0"
Date: 12/12/2021 2:15:35 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 7




Subject: Callout
Page Index: 7 Label proposed intersection spacing
Date: 12/12/2021 2:53:22 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 7




Subject: Length Measurement
Page Index: 7 681'-11"
Date: 12/12/2021 2:53:18 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 7


8 (3)



Subject: Length Measurement
Page Index: 8 54'-0"
Date: 12/12/2021 2:14:12 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 8



Subject: Length Measurement
Page Index: 8 80'-0"
Date: 12/12/2021 2:14:44 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 8



Subject: Length Measurement
Page Index: 8
Date: 12/12/2021 2:58:25 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 8


664'-7 1/4"

9 (4)




Subject: Callout
Page Index: 9
Date: 12/1/2021 5:00:13 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] Sheet 9

label the storm drain




Subject: Length Measurement
Page Index: 9
Date: 12/12/2021 2:54:15 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 9

660'-9 3/4"



Subject: Length Measurement
Page Index: 9
Date: 12/12/2021 2:55:40 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 9


806'-3/4"



Subject: Callout
Page Index: 9
Date: 12/12/2021 2:56:23 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 9


Label proposed intersection spacing

10 (4)




Subject: Text Box
Page Index: 10
Date: 12/1/2021 5:09:52 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [1] 10 GR01 - GR01

Update per GEC plan and PDR




Subject:
Page Index: 10
Date: 12/12/2021 2:28:42 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] 10 GR01 - GR01




Subject: Callout
Page Index: 10
Date: 12/12/2021 2:29:20 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] 10 GR01 - GR01

adjust contours




Subject: Arrow
Page Index: 10
Date: 12/12/2021 2:30:39 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] 10 GR01 - GR01

11 (4)




Subject:
Page Index: 11
Date: 12/12/2021 2:31:36 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [2] 11 GR01 - GR02




Subject: Callout
Page Index: 11
Date: 12/12/2021 2:32:26 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [2] 11 GR01 - GR02

Do you want the swale on the lot line? Provide drainage easement if not



Subject: Callout
Page Index: 11
Date: 12/12/2021 3:06:39 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [2] 11 GR01 - GR02


Potentially unstable slopes need to be addressed. How far west does stabilization need to go? Add a note that this will be addressed with final design.



Subject: Callout
Page Index: 11
Date: 12/12/2021 2:51:13 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [2] 11 GR01 - GR02

Please label both ends of the wall


14 (1)



Subject: Callout
Page Index: 14
Date: 12/12/2021 2:34:42 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [5] 14 GR02- BGP and SRR - GP02


Show culvert

15 (2)



Subject: Callout
Page Index: 15
Date: 12/1/2021 5:19:13 PM
Author: CDurham
Color: ■
Layer:
Space:
Page Label: [6] 15 GR02- BGP and SRR - GP03

Show rundown conveyance



Subject: Callout
Page Index: 15
Date: 12/12/2021 2:42:51 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [6] 15 GR02- BGP and SRR - GP03

Add: Permanent FSD

25 (1)



Subject: Callout
Page Index: 25
Date: 12/12/2021 3:06:59 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] Sheet 25

Potentially unstable slopes need to be addressed. How far west does stabilization need to go? Add a note that this will be addressed with final design.