



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Northcrest Personal Storage, PPR-24-12

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Cherokee Metropolitan District will provide water and wastewater services to the site. There is a finding for sufficiency in terms of water quality for CMD which is a Colorado Department of Public Health and Environment, Water Quality Control Division, approved community water system with PWSID# CO-0121125.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality detention basin must be designed to prevent water from stagnating to help reduce mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
07June2024