

V1Financial Assurance Estimate.pdf Markup Summary

Callout (10)




Subject: Callout
Page Label: 4
Author: Carlos
Date: 6/20/2023 9:33:16 AM
Status:
Color: ■
Layer:
Space:

Provide costs for as-built plans and pond certification




Subject: Callout
Page Label: 1
Author: Carlos
Date: 6/20/2023 1:30:24 PM
Status:
Color: ■
Layer:
Space:

Include all inlet protection bmps shown




Subject: Callout
Page Label: 3
Author: dsdlaforce
Date: 6/20/2023 5:17:57 PM
Status:
Color: ■
Layer:
Space:

remove.




Subject: Callout
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:25:57 PM
Status:
Color: ■
Layer:
Space:

provide quantities for the epoxy and thermoplastic pavement markings installed on Grinnell, Goldfield, and Cudahy.




Subject: Callout
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:23:39 PM
Status:
Color: ■
Layer:
Space:

SF2318 & PPR2320




Subject: Callout
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:25:47 PM
Status:
Color: ■
Layer:
Space:

provide crossspan quantities at the access to Goldfield



Subject: Callout
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:28:07 PM
Status:
Color: ■
Layer:
Space:

provide quantity. This can be modified to a lump sum for the total cost.




Subject: Callout
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:36:00 PM
Status:
Color: ■
Layer:
Space:

provide estimate for construction traffic control



Subject: Callout
Page Label: 3
Author: dsdlaforce
Date: 6/21/2023 11:58:20 AM
Status:
Color: ■
Layer:
Space:

Include this retaining wall in Section 3.



Subject: Callout
Page Label: 1
Author: CDurham
Date: 6/26/2023 10:14:18 AM
Status:
Color: ■
Layer:
Space:


Verify quantities of ABC & asphalt. One is CY and one is SY.

Cloud (1)




Subject: Cloud
Page Label: 3
Author: dsdlaforce
Date: 6/20/2023 5:17:49 PM
Status:
Color: ■
Layer:
Space:

Image (2)




Subject: Image
Page Label: 3
Author: dsdlaforce
Date: 6/21/2023 12:01:00 PM
Status:
Color: ■
Layer:
Space:




Subject: Image
Page Label: 2
Author: dsdlaforce
Date: 6/21/2023 12:02:46 PM
Status:
Color: ■
Layer:
Space:

Stamp - Stormwater Comment Legend (1)




Subject: Stamp - Stormwater Comment Legend
Page Label: 1
Author: Mikayla Hartford
Date: 6/20/2023 1:46:05 PM
Status:
Color: ■
Layer:
Space:

SW - Highlight (5)



Subject: SW - Highlight
Page Label: 1
Author: Mikayla Hartford
Date: 6/20/2023 1:37:41 PM
Status:
Color: ■
Layer:
Space:

Surface Roughening




Subject: SW - Highlight
Page Label: 1
Author: Mikayla Hartford
Date: 6/20/2023 1:37:42 PM
Status:
Color: ■
Layer:
Space:

0.0




Subject: SW - Highlight
Page Label: 1
Author: Mikayla Hartford
Date: 6/20/2023 1:39:49 PM
Status:
Color: ■
Layer:
Space:

Permanent Pond/BMP (provide engineer's estimate)



Subject: SW - Highlight
Page Label: 1
Author: Mikayla Hartford
Date: 6/20/2023 1:41:06 PM
Status:
Color: ■
Layer:
Space:

3,595 LF 3.00
 \$ = 3.00
 \$ 3.00



update quantities based on the review comments to the construction drawings.

Subject: Text Box
Page Label: 1
Author: dsdlaforce
Date: 6/20/2023 5:27:15 PM
Status:
Color: ■
Layer:
Space:

update quantities based on the review comments to the construction drawings.

update quantities based on the review comments to the construction drawings.

Subject: Text Box
Page Label: 2
Author: dsdlaforce
Date: 6/21/2023 12:02:05 PM
Status:
Color: ■
Layer:
Space:

Revise quantities. Section 2 should only include storm drain improvements that are public that will be maintained by El Paso County. See comments on the Civil plan set sheet 4 overall utility plan.