


CODE ANALYSIS				
2015 IBC, IFC, IPC, IECC IFGC, IEBC, 2014 NEC, ANSI A117.1-09, AND FRR				
REMODELLING PLANS:				
TENANT:	CLEAR MAX COLLISION		REQUIRED EXITS (TABLE 1006.3.1)	
ADDRESS:	2425 WAYSIDE COURT COLORADO SPRINGS, CO		2 EXIT REQUIRED OCC LOAD GREATER THAN 50 9 EXIT PROVIDED	
SF:	10,397		ALLOWABLE BLDG HT & AREA (TABLE 506.2)	
OCC CODE:	MIXED		TYPE III-B CONST, SPRINKLED, "F-1" OCC	
CONST TYPE:	III-B		1 STORY - 48,000 SF	
OCCUPANCY QTY:	SF	TYPE	SF/OCC	TOTAL
	9,174	F-1	100	92
	1,223	B	100	12
TOTAL OCCUPANTS:			104	
PLUMBING FIXTURE ANALYSIS				
EXISTING NO CHANGE				

STATEMENT OF WORK:
 NO CHANGE TO EXISTING BUILDING,
 INSTALLATION OF PAINT BOOTH AND
 REQUIRED MECHANICAL AND
 ELECTRICAL SYSTEMS ONLY

NO CHANGE OF USE OR OCCUPANCY
CLEAR MAX COLLISION
2425 WAYSIDE COURT
COLORADO SPRINGS, CO
NEW PAINT BOOTH

PCD File # PPR 1916



GENERAL NOTES

----- EXISTING WALLS - TO BE DEMOLISHED
 _____ EXISTING WALLS - TO REMAIN
 //////////////// NEW WALLS - SEE SECTIONS AND FLOOR PLAN


1. NEW CONSTRUCTION SHALL ALIGN AND MATCH EXISTING WORK UNLESS OTHERWISE NOTED
2. ALL EXISTING EQUIPMENT TO BE REMOVED SHALL HAVE ALL RELATED PADS, PIPING, CONTROLS, GAGES, ELECTRICAL SERVICE HANGERS, SUPPORTS, AND ANY MISCELLANEOUS RELATED SERVICE OR, PARTS REMOVED COMPLETELY.
3. AS A MINIMUM STANDARD, ALL WORK AND MATERIALS INSTALLED SHALL BE IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES, REGULATIONS, AND ORDINANCES HAVING JURISDICTION.
4. CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING ALL EXISTING CONDITIONS.
5. INSTALL ALL MANUFACTURED ITEMS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS
6. ANY MISCELLANEOUS ITEMS OR MATERIALS NOT SPECIFICALLY NOTED, BUT REQUIRED FOR PROPER INSTALLATION SHALL BE FURNISHED BY THE CONTRACTOR



VICINITY MAP

DRAWING SCHEDULE		CONTENTS	
SHEET	ARCHITECTURAL	1	CODE ANALYSIS, SITE PLAN, GENERAL NOTES
		2	PLANS
		3	ELEVATIONS
		4	PIT PLAN AND DETAILS




C. PELL, ARCHITECT, LLC
 cpell_arch@yahoo.com
 6354 S. BLACKHAWK WAY, 303-718-1343




CLEAR MAX COLLISION
2425 WAYSIDE COURT

SHEET 1
OF 4

DATE: 28FEB19
 PROJECT: 2018-BAKER-CLEARMAX





C. PELL, ARCHITECT, LLC
cpell_arch@yahoo.com
6354 S. BLACKHAWK WAY, 303-718-1343





CLEAR MAX COLLISION
2425 WAYSIDE COURT

SHEET 2
OF 4


DATE: 28FEB19
PROJECT: 2018-BAKER-CLEARMAX



WEST ELEVATION
3/8"=1'-0"










C. PELL, ARCHITECT, LLC
c.pell_arch@clearmax.com
6354 S. BLACKHAWK WAY, 303-718-1343



CLEAR MAX COLLISION
2425 WAYSIDE COURT


SHEET 3
OF 4

DATE: 28FEB19
PROJECT: 2018-BAKER-CLEARMAX



NO CHANGE TO BUILDING EXCEPT NEW BOOTH

C. PELL, ARCHITECT, LLC
cpell_arch@yahoo.com
6354 S. BLACKHAWK WAY, 303-718-1343




**CLEAR MAX COLLISION
2425 WAYSIDE COURT**

**SHEET 4
OF 4**

DATE: 28FEB19
PROJECT: 2018-BAKER-CLEARMAX

PCD File # PPR 1916

Remove pages 5-9 from this document. It is supposed to be just the floorplan drawings. We have the other drawings in another submittal item so no need for duplication.




A SITE PLAN / ROOF PLAN
 S101 SCALE: 1" = 20'-0"

CODE ANALYSIS
 1991 UBC
 OCCUPANCY: B, FI, S3 TOTAL BUILDING AREA = 10,538 SF.
 B OFFICE AREA = 1261 SF. CONSTRUCTION TYPE V N 2 STORY MAX., 8,000 SF. MAX. OCCUPANT LOAD FACTOR : 13 OCCUPANTS (@1/100), 1 EXIT REQUIRED.
 FI = 4,687 SF. CONSTRUCTION TYPE V N 2 STORY MAX., 8,000 SF. MAX., OCCUPANT LOAD FACTOR : 24 OCCUPANTS (@1/200), 1 EXIT REQUIRED.
 S3 = 4,530 SF. CONSTRUCTION TYPE V N 2 STORY MAX., 8,000 SF. MAX., OCCUPANT LOAD FACTOR : 10 OCCUPANTS (@1/500), 1 EXIT REQUIRED.
 EXIT WIDTH = 0.2'/PERSON = 13.5' MIN. REQ'D., 36' PROVIDED
 ONE HOUR OCCUPANCY SEPERATION WALL REQ'D. BETWEEN B AND FI SPACES
 ONE HOUR OCCUPANCY SEPERATION WALL REQ'D. BETWEEN S3 AND FI SPACES
 AUTOMATIC FIRE SPRINKLER SYSTEM SHALL BE INSTALLED PER 904.2.5.1 N THE FI AREA OF THE BLDG.

15 PARKING SPACES REQ'D.,
 8 FULL SIZE SPACES PROVIDED
 7 COMPACT SPACES PROVIDED
 1 FULL SIZE HANDICAPPED SPACE PROVIDED


BUILDING HEIGHTS NOT TO EXCEED 35'
 ZONE: MID (ADJ. PROPERTIES ZONED MID)
 1.42 ACRES TAX SCHED. NO. 54062-04-026
 LEGAL: LOT 2 INDIAN SPRINGS INDUSTRIAL CENTER

ALL LANDSCAPING TO BE DRIP IRRIGATED
 3314 SF. SODDED FINE FESCUE TURFGRASS ON PREPARED TRI-MIX SOILBED = 53% SITE AREA
 4' HIGH PINON PINE BALLED AND BURLAPPED



B CODE CHECK FLOOR PLAN
 S101 SCALE: 1/16" = 1'-0"

Zone: I-2 CAD-O



29 west Cimarron # 2
 Colorado Springs, Colorado 80903
 719.548.8200 voice
 719.548.8363 fax

preliminary drawings - not for construction

El Paso County Development Review Fee and Surcharge Required

Temporary Use Permit
 Temporary Use Permit
 Residential Plot Plan
 Non-Residential Plot Plan
 Sign Permit
 Signature: [Signature]

APPROVED
 EL PASO COUNTY PLANNING DEPT.
 THIS DAY OF [Month] 200[Year]
 [Signature]

design drawings for
CONTEMPORARY COMMERCIAL CABINETRY
 Wayside court at wayland place
 colorado springs, colorado 80915

project number
 2000-026
 date
 9.30.01
 revision

drawn by
 mfb
 checked by
 mfb
 sheet title
 site / floor plan
 sheet number

S101

D:\A_2000-026-ADKRMANS101.dwg Fri Oct 12 12:58:01 2001
 copyright 2001 by mbA architecture. reproduction and/or unauthorized use of the material herein without the written permission of mbA architecture violates the copyright laws of the united states and will be subject to legal prosecution.

Site Data Table

Property Owner Name and Address

Bryan Dorman
8569 Valley Ranch Pt.
Fountain, CO 80817

Applicant Name and Address

Parcel ID # | 54062-04-026

Zoning District: I-2 CAD-O

Total Acreage: 1.42

Existing Building SF: 10,538 SF

Proposed Use: Vehicle Repair Garage

Required Parking: Land Development Code Requires 1 space/employee on max shift, plus 3 spaces per bay or stall. Calculate and enter required parking based on this requirement. 3 Employees + (4 Bays x 3 Spaces) = 15 Parking Spaces

Provided Parking: 15 Spaces

There were 15 spaces on the original blueprints however there is room for 26 parking spaces on the lot.



Provided Disabled parking spaces: 1 Space

Required Bicycle Parking: Land Development Code requires 5% of the number of the required vehicle parking spaces. At least one bike parking space shall be provided and shown on the site plan. See LDC 6.2.5 for location and design of bike parking.

15 spaces x 0.05 = 0.75 bicycle parking spaces

Single bicycle parking space will be provided indoors.

copy_rn1 2000 by mba architecture. reproduction and/or unauthorized use of the material herein without the written permission of mba architecture violates the copyright laws of the united states and will be subject to legal prosecution.



design drawings for
**CONTEMPORARY
COMMERCIAL CABINERY**
wayside court at wayland place
colorado springs, colorado 80915

project number
2000-026

date
1.21.02

revision
rbd comments 3.15.02


drawn by
mfb
checked by
mfb

sheet title
floor plan

sheet number
A101

① PERIMETER
INSUL.
MIN. 3/4"
R-5

A
A101 FLOOR PLAN
SCALE: 1/8" = 1'-0"



CROSS SECTION @ LINES 2-6

APPROVED BY: [Signature]

NOTES:

- 1) FOR COLUMN AND RAFTER MARK NUMBERS, SEE EITHER SHEET E1 (ROOF FRAMING PLAN).
- 2) FBC___ INDICATES FLANGE BRACING LOCATIONS ON PURLIN ROOFS. FBD___ INDICATES FLANGE BRACING LOCATIONS ON JOIST ROOFS.
- 3) NS/FS INDICATES THAT FLANGE BRACING IS REQUIRED ON BOTH SIDES OF THE FRAME LINE. NOTE FOR EXPANDABLE ENDWALL RIGID FRAMES: IF FLANGE BRACING IS REQUIRED ON BOTH SIDES OF AN EXPANDABLE ENDFRAME, THE OPPOSITE SIDE FLANGE BRACE WILL HAVE TO BE INSTALLED AT THE TIME OF EXPANSION. THESE FLANGE BRACES HAVE BEEN PROVIDED, AS REQUIRED, FOR THIS FUTURE CONDITION.
- 4) IF NS/FS FLANGE BRACING IS NOT INDICATED, ONLY ONE FLANGE BRACE IS REQUIRED AND CAN BE LOCATED ON EITHER SIDE OF THE FRAME.
- 5) "*" INDICATES THE LONG SIDE OF INTERIOR COLUMNS. IF INTERIOR COLUMNS ARE REQUIRED, ORIENT AND ERECT THOSE COLUMNS ACCORDINGLY. NOTE: COLUMNS LOCATED AT THE RIDGE ARE TYPICALLY "FLAT-TOP" COLUMNS, UNLESS INDICATED BY THE "*" SYMBOL.
- 6) RIGID FRAMES SHALL HAVE 50% OF THEIR BOLTS INSTALLED AND TIGHTENED ON BOTH SIDES OF THE WEB ADJACENT TO EACH FLANGE BEFORE THE HOISTING EQUIPMENT IS RELEASED.

BOLT SCHEDULE

MEMBER ID	LOW PLATE		HIGH PLATE		OUTSIDE FLANGE			INSIDE FLANGE			MEMBER WEB			CON ID	BOLT QTY	BOLT DESCRIPTION	BOLT PART#	NUT PART#
	WIDTH	THICK	WIDTH	THICK	WIDTH	THICK	LENGTH	WIDTH	THICK	LENGTH	DEPTH	THICK	LENGTH					
A	8.00	0.50	6.00	0.63	6.00	0.50	279.56	6.00	0.63	246.13	13.13	0.175	245.33	1	8	BOLT/NUT 3/4" X 2 3/4" A325	H0630	H0320
											33.13	0.275	34.23					
											33.13							
B	6.00	0.63	6.00	0.63	6.00	0.25	121.69	6.00	0.31	348.31	32.56	0.225	121.69	2	8	BOLT/NUT 1/2" X 2" A325	H0603	H0300
					6.00	0.31	226.19				29.81	0.200	226.22					
					24.63													
C	8.00	0.50	6.00	0.63	6.00	0.25	279.56	6.00	0.38	246.13	12.63	0.175	245.33	3	8	BOLT/NUT 5/8" X 2 1/4" A325	H0610	H0310
											32.63	0.275	34.23					
											32.63							
D	6.00	0.63	6.00	0.63	6.00	0.25	121.06	6.00	0.31	348.56	32.56	0.225	121.06	4	8	BOLT/NUT 1" X 3 1/4" A325	H0640	H0330
					6.00	0.31	227.06				29.81	0.200	227.09					
					24.63													

PROJECT NAME: **TRACY ACKERMAN**
 COLORADO SPRINGS, CO
 CUSTOMER: **HIGHLAND BUILDERS CORP.**
 COLORADO SPRINGS, CO

ISSUE: CONSTRUCT ANCHOR BOLT
 PERMITS
 FINAL ERECTION

DATE: 1-25-02
 01/21/02

PROJECT NO: **T1L2087A**


SHEET NO: **E2 of 11**

THIS SEAL PERTAINS ONLY TO THE MATERIALS DESIGNED AND SUPPLIED BY NUCOR BUILDING SYSTEMS, A DIVISION OF NUCOR CORPORATION. THIS SEAL DOES NOT SERVE AS OR REPRESENT THE PROJECT ENGINEER OF RECORD AND SHALL NOT BE CONSTRUED AS SUCH.

CROSS SECTION @ LINES 2-3

NOTES:

- 1) FOR COLUMN AND RAFTER MARK NUMBERS, SEE EITHER SHEET E1 (ROOF FRAMING PLAN).
- 2) FBC___ INDICATES FLANGE BRACING LOCATIONS ON PURLIN ROOFS.
FBD___ INDICATES FLANGE BRACING LOCATIONS ON JOIST ROOFS.
- 3) NS/FS INDICATES THAT FLANGE BRACING IS REQUIRED ON BOTH SIDES OF THE FRAME LINE. NOTE FOR EXPANDABLE ENDWALL RIGID FRAMES: IF FLANGE BRACING IS REQUIRED ON BOTH SIDES OF AN EXPANDABLE ENDFRAME, THE OPPOSITE SIDE FLANGE BRACE WILL HAVE TO BE INSTALLED AT THE TIME OF EXPANSION. THESE FLANGE BRACES HAVE BEEN PROVIDED, AS REQUIRED, FOR THIS FUTURE CONDITION.
- 4) IF NS/FS FLANGE BRACING IS NOT INDICATED, ONLY ONE FLANGE BRACE IS REQUIRED AND CAN BE LOCATED ON EITHER SIDE OF THE FRAME.
- 5) RIGID FRAMES SHALL HAVE 50% OF THEIR BOLTS INSTALLED AND TIGHTENED ON BOTH SIDES OF THE WEB ADJACENT TO EACH FLANGE BEFORE THE HOISTING EQUIPMENT IS RELEASED.



BOLT SCHEDULE

CON ID	BOLT QTY	BOLT DESCRIPTION	BOLT PART#	NUT PART#
1	8	BOLT/NUT 3/4" X 2 3/4" A325	H0630	H0320
2	4	BOLT/NUT 1/2" X 2" A325	H0603	H0300
3	2	BOLT/NUT 5/8" X 2 1/4" A325	H0610	H0310
4	8	BOLT/NUT 1" X 3 1/4" A325	H0640	H0330
5	8	BOLT/NUT 1 1/4" X 3 1/2" A325	H0660	H0340

DATE	P.L.E.	ENG	CHK	DWN

NUCOR
BUILDING SYSTEMS GROUP
 305 INDUSTRIAL PARKWAY, WATERLOO, IN 46793
 PHONE: (219) 837-7891 FAX: (219) 837-7384
 PO. BOX 1006, 200 WHEISTONE RD, SWANSEA SC 29160
 PHONE: (803) 566-2100 FAX: (803) 566-2121
 600 APACHE TRAIL, TERRELL TX, 75160
 PHONE: (972) 524-5407 FAX: (972) 524-5417

PROJECT NAME:
TRACY ACKERMAN
 COLORADO SPRINGS, CO
 CUSTOMER:
HIGHLAND BUILDERS CORPORA
 COLORADO SPRINGS, CO

JOB NUMBER:
 T1L2087A

SHEET NO:
 E3 of 11



THIS SEAL PERTAINS ONLY TO THE MATERIALS DESIGNED AND SUPPLIED BY NUCOR BUILDING SYSTEMS, A DIVISION OF NUCOR CORPORATION. THIS SEAL DOES NOT SERVE AS OR REPRESENT THE PROJECT ENGINEER OF RECORD AND SHALL NOT BE CONSTRUED AS SUCH.

AL BLDG DEPT

FEB 27

Markup Summary

5/15/2019 2:23:22 PM (1)



Subject: Text Box
Page Label: 5
Author: Lindsay Darden
Date: 5/15/2019 2:23:22 PM
Color: ■

Remove pages 5-9 from this document. It is supposed to be just the floorplan drawings. We have the other drawings in another submittal item so no need for duplication.