

Prevent • Promote • Protect

Environmental Health Division 1675 W. Garden of the Gods Road Suite 2044 Colorado Springs, CO 80907 (719) 578-3199 *phone* (719) 578-3188 *fax* **www.elpasocountyhealth.org**

17625 Person Drive, AL-24-11

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The property has an existing onsite wastewater treatment system (OWTS) that was permitted and installed for a 4-bedroom house in 1985. The soil treatment area (STA) for the existing house must be located and protected from compaction associated with the construction of the proposed 14,000 sq.ft. structure.
- If an OWTS is planned for the structure, then a New OWTS Permit is required.

Mike McCarthy El Paso County Public Health 719-332-5771 <u>mikemccarthy@elpasoco.com</u> 16August2024